



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

GAF

1 Campus Drive  
Parsippany, NJ 07054

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Matrix™ Roofing Cements and Coatings

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 17-0629.01 and consists of pages 1 through 4.  
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 22-0523.03  
Expiration Date: 08/23/27  
Approval Date: 07/28/22  
Page 1 of 4

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Cement-Adhesive-Coatings  
**Material:** Asphalt

### SCOPE:

This approves “**Matrix™ Roofing Cements and Coatings**” as roof cements, coatings, and adhesives, as described in this Notice of Acceptance. These products have been designed to comply with the Florida Building Code, and the High Velocity Hurricane Zone of the Florida Building Code.

### MANUFACTURING LOCATIONS:

1. Hallandale, FL

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name / Report</u>	<u>Date</u>
PRI Construction Materials	TRA-147-02-01	ASTM D 4586	08/03/17
Technologies, LLC	TRA-153-02-01	ASTM D41	08/03/17
	TRA-156-02-01	ASTM D 4586 / ASTM D 3409	08/03/17
	TRA-160-02-01	ASTM D 4586 / ASTM D 3409	08/03/17

### PHYSICAL PROPERTIES OF COMPONENTS:

**Trade name:** Matrix™ 204 Wet/Dry Roof Cement

**Application Rate:** Apply by trowel or knife at a minimum rate of 1/8” thick, approximately 1 gal./12 sq. ft.

**Specifications:** ASTM D 4586 Type I

**Description:** All-weather flashing cement that adheres to all surfaces, wet or dry. Blended with select asphalts, cellulose fibers, surfactants, mineral stabilizers, and pure hydrocarbon solvents. Used for protecting, waterproofing, patching and sealing old and new roofs.

**Container Size:** 1, 5, 55 gallons. Note all cautions on container label.

**Trade name:** Matrix™ 307 Premium Asphalt Primer

**Application Rate:** Apply by brush or spray at a minimum rate of 1gal./100 ft<sup>2</sup>

**Specifications:** ASTM D 41

**Description:** A general purpose asphalt based primer used as a bonding coat for preparation of roof surfaces prior to the application of subsequent roofing materials.

**Container Size:** 15oz. spray can; 1, 5, 55 gallons. Note all cautions on container label.



NOA No.: 22-0523.03  
Expiration Date: 08/23/27  
Approval Date: 07/28/22  
Page 2 of 4

**Trade name:** Matrix™ 203 Plastic Roof Cement

**Application Rate:** Apply with a trowel or knife at a minimum rate of 1/8" thick, approximately 1 gal./12 sq. ft.

**Specifications:** ASTM D 4586, ASTM D 3409

**Description:** An asbestos free asphaltic base, multipurpose plastic roof cement for repairing leaks, cracks, and holes in concrete, steel, or metal roofs. For use on all flashing around skylights, gutters, and in all crevices. It can also be applied as a heavy-duty foundation coating.

**Container Size** 1, 5, 55 gallons. Note all cautions on container label.

**Trade name:** Matrix™ 201 SBS Flashing Cement

**Application Rate:** Apply with a trowel at a minimum rate of 1/8" thick, approximately 1 gal./12 sq. ft.

**Specifications:** ASTM D 4586, ASTM D 3409

**Description:** Asbestos free flashing compound manufactured with high-grade oxidized base asphalts. Fortified with SBS rubber. Special surfactants make this product applicable in any climate or weather. Manufactured to adhere to all solid surfaces, wet or dry. For use in repairing, sealing, or adhering to all types of roofing. A trowel grade modified adhesive as well as flashing cement. Uses include fixing leaks around vent pipes, skylights, valleys, chimneys, joints, starting shingles as well as patching small holes. May be used to repair modified asphalt sheets as well as conventional roofing. Not for use on coal tar roofs.

**Container Size:** 1, 3, 55 gallons and 10.5 ounce caulking tubes.

**Trade name:** Matrix™ 202 Premium SBS Flashing Cement

**Application Rate:** Apply with a trowel at a minimum rate of 1/8" thick, approximately 1 gal./12 sq. ft.

**Specifications:** ASTM D 4586, ASTM D 3409

**Description:** Asbestos free flashing compound manufactured with high-grade oxidized base asphalts. Fortified with SBS rubber. Special surfactants make this product applicable in any climate or weather. Manufactured to adhere to all solid surfaces, wet or dry. For use in repairing, sealing, or adhering to all types of roofing. A trowel grade modified adhesive as well as flashing cement. Uses include fixing leaks around vent pipes, skylights, valleys, chimneys, joints, starting shingles as well as patching small holes. May be used to repair modified asphalt sheets as well as conventional roofing. Not for use on coal tar roofs.

**Container Size:** 1, 3, 55 gallons and 10.5 ounce caulking tubes.



## LIMITATIONS:

1. **Matrix™ Roofing Cements and Coatings are not approved as and shall not be used as a Roof or Waterproofing System as required by the Florida Building Code Chapter 15 HVHZ.**
2. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
3. Matrix™ Roofing Cements and Coatings listed herein shall not be applied in inclement weather conditions.
4. The product listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance. If a product is not listed as part of roof assemblies Notice of Acceptance, a request may be made to the local building official or the Miami Dade County Product Control Section for approval provided that appropriate documentation is provided.
5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency and shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code. Follow up test results shall be made available to Miami-Dade Product Control Section upon request.
6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
7. The maintenance coating systems listed herein shall not be applied over prepared roofing; i.e., fiber-cement shingles, quarry slate, cement or clay roof tile, metal shingles, wood shingles or shakes.
8. Matrix™ Roofing Cements and Coatings shall be applied in accordance with current application instructions published by the manufacturer.
9. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



**END OF THIS ACCEPTANCE**



NOA No.: 22-0523.03  
Expiration Date: 08/23/27  
Approval Date: 07/28/22  
Page 4 of 4