



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

Vicwest, Inc.  
5050 South Service Road, Unit 200  
Burlington, ON L7L 5Y7 CANADA

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: True Nature North Ridge Slate and True Nature Cedar Creek Shake

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 7.

The submitted documentation was reviewed by Alex Tigera.



NOA No.: 22-0629.01  
Expiration Date: 10/05/28  
Approval Date: 10/05/23  
Page 1 of 7

## ROOFING SYSTEM APPROVAL:

**Category:** Roofing  
**Sub-Category:** Metal, Panels  
**Material:** Steel  
**Deck Type:** Wood  
**Maximum Design Pressure:** -112.5 psf

## TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
True Nature North Ridge Slate	50-11/16" x 13-9/16" 50" x 12" (installed coverage) Thickness 26 ga. Min. 50.7 ksi	TAS 125	PVDF coated ASTM A792 AZ50 steel, slate metal roofing panel.
True Nature Cedar Creek Shake	50-3/4" x 13-9/16" 50" x 12" (installed coverage) Thickness 26 ga. Min. 50.7 ksi	TAS 125	PVDF coated ASTM A792 AZ50 steel, shake metal roofing panel.

## MANUFACTURING LOCATION

1. Stratford, ON CANADA

## EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies, LLC	2362T0007	TAS 125 / UL 1897/ UL 580	11/11/16
	2362T0001	ASTM B 117	05/03/21
Intertek	103884899COQ-005A	ASTM G 155	03/07/23
	103884899COQ-005A	TAS 100	03/07/23



NOA No.: 22-0629.01  
Expiration Date: 10/05/28  
Approval Date: 10/05/23  
Page 2 of 7

## APPROVED ASSEMBLIES:

<b>System 1:</b>	True Nature North Ridge Slate and True Nature Cedar Creek Shake
<b>Deck Type:</b>	Wood, Non-insulated
<b>Deck Description:</b>	New Construction <sup>19</sup> / <sub>32</sub> " or greater plywood or wood plank, or Re-roof <sup>15</sup> / <sub>32</sub> " or greater plywood or wood plank. Plywood shall be minimum PS 1-09 APA span rated, CDX.
<b>Slope Range:</b>	3:12 or greater
<b>Maximum Uplift Pressure:</b>	See Fastening Options Below

---

**Deck Attachment:** In accordance with Applicable Building Code, but in no case shall it be less than 0.113" x 2-3/8" long ring-shank nails spaced 6" o.c. In reroofing, where the deck is less than <sup>19</sup>/<sub>32</sub>" thick (minimum <sup>15</sup>/<sub>32</sub>"), the above attachment method must be in addition to existing attachment.

**Underlayment:** Minimum underlayment shall be an ASTM D 226 Type II installed with a minimum 4" side-laps and 6" end-laps. Underlayment shall be fastened with corrosion resistant tin-caps and 1 1/4" annular ring-shank nails, spaced 6" o.c. at all laps and two staggered rows 12" o.c. in the field of the roll.

Over the mechanically fastened underlayment, apply a minimum of one layer of any Miami-Dade County Product Control Approved self-adhered underlayment having a current NOA.

***Note: Effective with 2023 FBC 8<sup>th</sup> Edition, the mechanically fastened ASTM D 226 Type II will be optional. A Miami Dade Approved self-adhered underlayment may be applied direct to the deck in accordance with the underlayment Notice of Acceptance (NOA).***

**Fire Barrier Board:** Any approved fire barrier having a current NOA. Refer to a current fire directory listing for fire ratings of this roofing system assembly as well as the location of the fire barrier within the assembly. See Limitation # 1.

**Valleys:** Valley construction shall be in compliance with Roofing Application Standard RAS 133 and with Vicwest Inc's current published installation instructions.

**Metal Panels and Accessories:** Install the "True Nature North Ridge Slate and True Nature Cedar Creek Shake" panels and accessories in compliance with Vicwest Inc's current, published installation instructions and details. Flashing, penetrations, valley construction and other details shall be constructed in compliance with the minimum requirements provided in Roofing Application Standards RAS 133.

**Field Condition:** Panels shall be attached with Seven (7) #10 x 1.5" HWH screws beginning 2" from the edge of the flange and proceeding 7-3/4" o.c. thereafter. Adjacent panel interlocks with installed panel. Side laps shall be offset a minimum of 11" from previous course.

**Maximum Design Pressure for Field Condition:** -90 psf.

**Perimeter and Corner Condition:**

Panels shall be attached with Thirteen (13) #10 x 1.5" HWH screws beginning 2" from the edge of the flange and proceeding 3-7/8" o.c. thereafter. Adjacent panel interlocks with installed panel. Side laps shall be offset a minimum of 11" from previous course.

**Maximum Design Pressure for Perimeter and Corner Condition:**

**-112.5 psf.**



## LIMITATIONS:


1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. The maximum designed pressure listed herein shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
3. All panels shall be permanently labeled with the manufacturer's name and/or logo, city and state of manufacturing facility, and the following statement: "Miami-Dade County Product Control Approved" **or** with the Miami-Dade County Product Control Seal as seen below.




4. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.



# **PROFILE DRAWINGS:** **TRUE NATURE NORTH RIDGE SLATE**



# TRUE NATURE CEDAR CREEK SHAKE



**END OF THIS ACCEPTANCE**



**NOA No.: 22-0629.01**  
**Expiration Date: 10/05/28**  
**Approval Date: 10/05/23**  
**Page 7 of 7**