



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Polyglass USA, Inc.
150 Lyon Drive
Fernley, NV 89408

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Polyglass Self-Adhered Roof System over Concrete Deck

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 21-1207.15 and consists of pages 1 through 41.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 22-0706.12
Expiration Date: 11/22/27
Approval Date: 11/10/22
Page 1 of 41

ROOFING ASSEMBLY APPROVAL

Category:	Roofing
Sub-Category:	Modified Bitumen
Materials	SBS/APP
Deck Type:	Concrete
Maximum Design Pressure	-545 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Polyanchor	250' x 48"	ASTM D 4601 Type II	A polymer woven, high performance, synthetic base sheet.
Polyflex SA Base	66' 8" x 3' 3-3/8"	ASTM D 4601 Type II	Self-adhered, fiberglass reinforced, APP modified bitumen base sheet.
Elastoshield VP HT	65' 8" x 3' 3-3/8"	ASTM D 6162, Type III	SBS modified asphalt coated fiberglass/polyester reinforced base sheet.
XtraFlex SBS HT Base 650	65' 8" x 3' 3-3/8"	ASTM D 6162, Type III	SBS modified asphalt coated fiberglass/polyester reinforced base sheet.
Elastobase V	65' 8" x 3' 3-3/8"	ASTM D 6163, Type I	SBS modified asphalt coated fiberglass reinforced base sheet.
Elastoflex SA V	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V FR	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fire-rated, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V PLUS	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V PLUS FR	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fire-rated, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
XtraFlex SBS Base SA	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
XtraFlex SBS Glass Base	65' 8" x 3' 3-3/8"	ASTM D 6163, Type I	SBS modified asphalt coated fiberglass reinforced base sheet.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Elastobase P	65' 8" x 3' 3-3/8"	ASTM D 6164, Type I	SBS modified asphalt coated polyester reinforced base sheet.
Elastoflex SA P	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
Elastoflex SA P FR	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, fire-rated, polyester reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyreflect	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, polymer, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
XtraFlex SBS G SA	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, fire-rated, polyester reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyflex SA P	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyflex SA P FR	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, fire-rated, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyfresko G APP SA	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyfresko G APP SA FR	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, fire-rated, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
XtraFlex APP G SA	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, fire-rated, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
PG 100	1, 3, 5, 50, 55 gal, tube or 17 oz. spray can	ASTM D41	A penetrating solution of solvent and a blend of selected asphalts used to promote adhesion.
PG 350	1, 3, 5, 50, 55 gal. or tube	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
PG 400	1, 3, 5, 50, 55 gal. or tube	ASTM D4586 ASTM D3409	A thick, fibered, rubberized flashing cement for use in dry or damp conditions.
PG 425	1, 3, 5, 50, 55 gal. or tube	ASTM D4586 ASTM D3409	A thick, fibered, rubberized flashing cement for use in dry or damp conditions.
PG 450	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement.
PG 500	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.
POLYPLUS 35	1, 3, 5, 50, 55 gal. or tube	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.
POLYPLUS 45	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement.
POLYPLUS 50	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.
XtraFlex 10	1, 3, 5, 50, 55 gal, tube or 17 oz. spray can	ASTM D41	A penetrating solution of solvent and a blend of selected asphalts used to promote adhesion.
XtraFlex 35	1, 3, 5, 50, 55 gal. or tube	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.
XtraFlex 50 Premium Modified Wet/Dry Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.
WB-3000	5 gallon pail	Proprietary	A low-VOC, water-based acrylic primer to enhance adhesion of self-adhered membranes.



APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
Polytherm-H	Polyisocyanurate foam insulation	Polyglass USA, Inc.
Polytherm	Polyisocyanurate foam insulation	Polyglass USA, Inc.
Polytherm G	Polyisocyanurate foam insulation	Polyglass USA, Inc.
XtraFlex Polyiso	Polyisocyanurate foam insulation	Polyglass USA, Inc.
XtraFlex Polyiso G	Polyisocyanurate foam insulation	Polyglass USA, Inc.
ISO 95+GL	Polyisocyanurate foam insulation	Firestone Bldg. Pro. Co.
Structodek High Density Fiberboard Roof Insulation	High Density Wood Fiber insulation board.	Blue Ridge Fiberboard, Inc.
DensDeck	Gypsum insulation board	Georgia-Pacific Gypsum LLC
DensDeck Prime	Gypsum insulation board	Georgia-Pacific Gypsum LLC
SECUROCK Gypsum-Fiber Roof Board	Fiber reinforced insulation board	United States Gypsum Corporation
ENRGY 3	Polyisocyanurate foam insulation	Johns Manville Corp.
ACFoam-II	Polyisocyanurate foam insulation	Atlas Roofing Corp.
ACFoam-III	Polyisocyanurate foam insulation	Atlas Roofing Corp.
H-Shield	Polyisocyanurate foam insulation	Hunter Panels, a division of Carlisle Construction Materials, LLC.
H-Shield CG	Polyisocyanurate foam insulation	Hunter Panels, a division of Carlisle Construction Materials, LLC .
Multi-Max FA-3	Polyisocyanurate foam insulation	Rmax, A Business unit of Sika Corporation
Insulfoam EPS	Expanded polystyrene board	Insulfoam, a Div. of Carlisle Const. Materials
DEXcell FA Glass Mat Rood Board	Gypsum board	National Gypsum Company a dba of New NGC, Inc.



APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Polygrip Fasteners #14	Insulation fastener for wood, steel and concrete decks	Various	Polyglass USA, Inc.
2.	Polygrip Fasteners #15	Insulation fastener for wood, steel and concrete decks	Various	Polyglass USA, Inc.
3.	Polygrip Hex Plate	Galvalume hex stress plate.	2 7/8" x 3-1/4"	Polyglass USA, Inc.
4.	Dekfast DF-#14-PH3	Insulation fastener for wood, steel and concrete decks	Various	SFS Group USA, Inc.
5.	Dekfast DF-#15-PH3	Insulation fastener for wood, steel and concrete decks	Various	SFS Group USA, Inc.
6.	isofast PLT-S-2-3/4x2-3/4	Galvalume 19 ga. steel insulation and membrane attachment stress plate	2 3/4" x 2 3/4"	SFS Group USA, Inc.
7.	Dekfast PLT-H-2-7/8	Galvalume hex stress plate.	2 7/8" x 3 1/4"	SFS Group USA, Inc.
8.	#14 Roofgrip	Insulation fastener for wood, steel and concrete decks.	Various	OMG, Inc.
9.	#15 Roofgrip	Insulation fastener for wood, steel and concrete decks.	Various	OMG, Inc.
10.	Flat Bottom Metal Plate	A2-SS aluminized steel plate	3" square	OMG, Inc.
11.	Dekfast Galvalume Steel 3 in. Round	3" round galvalume AZ50 steel plate	3" round	SFS Group USA, Inc.
12.	Trufast #14 HD Fastener	Insulation fastener for wood, steel and concrete decks	Various	Altenloh, Brinck & Co. U.S., Inc.
13.	Trufast 3" Metal Insulation Plates	Round Galvalume steel plate	3" round	Altenloh, Brinck & Co. U.S., Inc.
14.	ICP Adhesives CR-20	A two component, low rise, polyurethane foam adhesive		ICP Adhesives and Sealants, Inc.
15.	Insta Stik Quik Set Insulation Adhesive	A single component urethane foam adhesive.		DuPont de Nemours, Inc.
16.	OlyBond	A two component, low rise, polyurethane foam adhesive		OMG, Inc.



APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
17.	OlyBond 500	A two component, low rise, polyurethane foam adhesive		OMG, Inc.
18.	OlyBond 500 Green	A two component, low rise, polyurethane foam adhesive		OMG, Inc.
19.	Millennium One-Step Foamable Adhesive	A two component, low rise, polyurethane foam adhesive		H.B. Fuller Company
20.	Millennium One Step Green Foamable Adhesive	A two component, low rise, polyurethane foam adhesive		H.B. Fuller Company
21.	Millennium PG-1 Pump Grade Adhesive	A two component, low rise, polyurethane foam adhesive		H.B. Fuller Company



APPROVED SURFACING:

TABLE 4

Chosen components must be applied according to manufacturer’s application instructions.

<u>Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Application Rate</u>	<u>Specification</u>	<u>Manufacturer</u>
1.	Gravel	To be installed in a flood coat of approved asphalt at 60 lbs/sq	400 lbs/sq	N/A	Generic
2.	Slag	To be installed in a flood coat of approved asphalt at 60 lbs/sq	300 lbs/sq	N/A	Generic
3.	KM Acryl 15	A premium white or tinted elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
4.	KM Acryl 15 QS	A premium white or tinted quick setting, elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
5.	KM Acryl 25	A premium white or tinted elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
6.	KM Acryl 25 QS	A premium white or tinted quick setting, elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
7.	KM-PS #220	A single component, solvent, white or tinted, silicone coating.	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.
8.	KM-PS #250	A premium grade high solids, white or tinted, single component, moisture cure, fluid applied silicone coating.	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.



APPROVED SURFACING:

TABLE 4

Chosen components must be applied according to manufacturer’s application instructions.

<u>Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Application Rate</u>	<u>Specification</u>	<u>Manufacturer</u>
9.	PG 300	An asphalt cutback fibered roof coating. May be applied by brush or spray equipment to rejuvenate aged BUR.	1½-2 gal/sq	ASTM D4479	Polyglass USA, Inc.
10.	PG 600	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.
11.	PG 650	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
12.	PG 700	A premium white or tinted elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
13.	PG 700 QS	A premium white or tinted quick setting, elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
14.	PG 800	An asphalt based, non-fibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
15.	PolyBrite 70	A premium white or tinted elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
16.	PolyBrite 70 QS	A premium white or tinted quick setting, elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.



APPROVED SURFACING:

TABLE 4

Chosen components must be applied according to manufacturer’s application instructions.

<u>Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Application Rate</u>	<u>Specification</u>	<u>Manufacturer</u>
17.	PolyBrite 90	A premium grade high solids, white or tinted, single component, moisture cure, fluid applied silicone coating.	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.
18.	PolyBrite 95	A single component, white or tinted, solvent, moisture cure silicone coating.	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.
19.	POLYPLUS 60	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.
20.	POLYPLUS 65	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
21.	XtraFlex 60 Aluminum Roof Coating	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.
22.	XtraFlex 65 Aluminum Roof Coating Fibered	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
23.	XtraFlex 70 Premium Acrylic FR Roof Coating	A premium white or tinted elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
24.	XtraFlex 80 Emulsion Roof Coating	An asphalt based, non-fibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
25.	XtraFlex 30 Bituminous Roof Coating Fibered	An asphalt cutback fibered roof coating. May be applied by brush or spray equipment to rejuvenate aged BUR	1½-2 gal/sq	ASTM D4479	Polyglass USA, Inc.
26.	XtraFlex SRC 8000	A single component, white or tinted, solvent, moisture cure silicone coating.	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.
27.	XtraFlex SRC 9600	A premium grade high solids, white or tinted, single component, moisture cure, fluid applied silicone coating	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Name/Report</u>	<u>Report No.</u>	<u>Date</u>
Factory Mutual Research Corporation	4470	2W7A7.AM	08.04.94
	4450	2D5A9.AM	06.22.99
	4470	3001334	02.15.00
	4470	3000857	01.12.00
	4470	3004091	01.12.00
	4470	3014692	08.05.03
	4450	3014751	08.27.03
	4450	3019317	06.30.04
	4470	3023458	07.18.06
	4470	3024311	11/01/06
	4470	3012321	07.29.07
	4470	3031350	09/27/07
	4470	3032172	06.12.09
	4470	3036182	07/31/09
	4470	3049631	04.21.14
	4470	RR202591	10.22.15
	Trinity ERD	TAS 114	11752.09.99-1
TAS 114		02764.09.05	09.09.05
TAS 114		P1734.07.06-R1	02.27.07
TAS 114		P1738.02.07	02.05.07
TAS 114		P13770.09.09	09.10.09
FM 4470 & TAS 114		P30550.12.09-1	12.02.09
FM 4470 & TAS 114		P30550.12.09-2	12.02.09
FM 4470 & TAS 114		02762.03.05-R2	04/01/10
FM 4470 & TAS 114		P33970.03.11	03.15.11
TAS 114		11757.04.01-1-R1	04.30.13
TAS 117		PLYG-SC15760.10.17	10.06.17



APPROVED ASSEMBLIES:

- Membrane Type:** SBS/APP
- Deck Type 3I:** Concrete Decks, Insulated
- Deck Description:** 2500 psi structural concrete or concrete plank
- System Type A(1):** One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

Primer: Primed with PG 100 or XtraFlex 10 and allowed to dry prior to application of vapor barrier.
(Optional)

Vapor Barrier: One ply of Elastoflex SA P, Elastoflex SA V PLUS, or XtraFlex SBS Base SA self-adhered.
(Optional)

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Insulfoam EPS Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: All insulation shall be applied with Insta Stik Quik Set Insulation Adhesive in continuous ¾ to 1” beads/ribbons or ICP Adhesives CR-20 in continuous 1.5” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: DensDeck Prime shall be primed with PG 100 or XtraFlex 10.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
 Or
 One ply of Elastobase V, Elastoshield VP HT, XtraFlex SBS Glass Base or XtraFlex SBS HT Base 650 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, or XtraFlex APP G SA



**Surfacing:
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:**

-60.0 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(2): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

Primer: Concrete deck shall be primed with PG 100 or XtraFlex 10.
(Optional)

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Multi-Max FA-3, H-Shield, Polytherm-H Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: Apply insulations in Insta Stik Quik Set Insulation Adhesive in continuous ¾ to 1” beads/ribbons spaced 12” o.c. Additional layers of insulation to be adhered with Insta Stik Quik Set Insulation Adhesive in continuous ¾ to 1” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -67.5 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(3): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

Vapor Barrier: Cold-applied base sheet approved for use with roof cover, adhered to concrete deck primed with PG 100 or XtraFlex 10.
(Optional)

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam-II, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-III, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 Minimum 1.5” thick	N/A	N/A

Note: Apply insulation in ICP Adhesives CR-20 in continuous 3” to 3-1/2” beads/ribbons spaced 12” o.c. Additional layers of insulation to be adhered with ICP Adhesives CR-20 in continuous 3” to 3-1/2” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -55.0 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(4): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

Primer: Primed with PG 100 or XtraFlex 10 and allowed to dry prior to application of vapor barrier.
(Optional)

Vapor Barrier: One ply of Elastoflex SA P self-adhered.
(Optional)

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Insulfoam EPS Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: All insulation shall be applied with Insta Stik Quik Set Insulation Adhesive in continuous ¾ to 1” beads/ribbons or ICP Adhesives CR-20 in continuous 1.5” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: DensDeck Prime shall be primed with PG 100 or XtraFlex 10.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA, self-adhered.

Or

(For use with DensDeck Prime only) One ply of Elastobase V, Elastoshield VP HT, XtraFlex SBS Glass Base or XtraFlex SBS HT Base 650 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, or XtraFlex APP G SA.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -75.0 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(5): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Insulfoam EPS (Requires Top Layer of Insulation) Minimum 2” thick	N/A	N/A
Structodeck High Density Fiberboard Roof Insulation Minimum ½” thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Structodeck High Density Fiberboard Roof Insulation Minimum ½” thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A

Note: Apply insulation in OlyBond 500 or OlyBond 500 Green Adhesive in continuous ¾” to 1” beads/ribbons spaced 12” o.c. Additional layers of insulation to be adhered with OlyBond 500 or OlyBond 500 Green Adhesive in continuous ¾” to 1” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Primer:
(Optional)** Apply WB-3000 at 1 gal. per 300 sq. ft. to DensDeck or DensDeck Prime prior to application of self-adhered base sheets.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
 Or
 One ply of Elastobase V, Elastoshield VP HT, XtraFlex SBS Glass Base or XtraFlex SBS HT Base 650 adhered to coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:
(Optional)** One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.



**Surfacing:
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:**

-120.0 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(6): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY-3, ISO 95+ GL, H-Shield, Polytherm-H Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A

Note: Apply insulation in OlyBond 500 or OlyBond 500 Green Adhesive in continuous ¾” to 1” beads/ribbons spaced 12” o.c. Additional layers of insulation to be adhered with OlyBond 500 or OlyBond 500 Green Adhesive in continuous ¾” to 1” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft. prior to application of self-adhered base sheets.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA, self-adhered.
 Or
 One ply of Elastobase V, Elastoshield VP HT, XtraFlex SBS Glass Base or XtraFlex SBS HT Base 650 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, XtraFlex SBS G SA, self-adhered.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -127.5 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(7): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-II, ACFoam-III, H-Shield, Polytherm-H Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A

Note: Apply insulation in OlyBond 500 or OlyBond 500 Green Adhesive in continuous ¾” to 1” beads/ribbons spaced 12” o.c. Additional layers of insulation to be adhered with OlyBond 500 or OlyBond 500 Green Adhesive in continuous ¾” to 1” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Primer:
(Optional)** Apply WB-3000 at 1 gal. per 300 sq. ft.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

**Ply Sheet:
(Optional)** One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -150.0 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(8): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Insulfoam EPS Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Structodek High Density Fiberboard Roof Insulation Minimum ½” thick	N/A	N/A

Note: Apply insulation in Insta Stik Quik Set Insulation Adhesive in continuous ¾ to 1” beads/ribbons spaced 12” o.c. Additional layers of insulation to be adhered with Insta Stik Quik Set Insulation Adhesive in continuous ¾ to 1” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
 Or
 One ply of Elastoshield VP HT or XtraFlex SBS HT Base 650 adhered to coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:
(Optional)** One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -157.5 psf (See General Limitation #9).



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(9): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Polytherm, Polytherm-H, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-II, ACFoam-III, H-Shield Minimum 1.0” thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Polytherm, Polytherm-H, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-II, ACFoam-III, H-Shield Minimum 1.0” thick	N/A	N/A

Note: Apply insulation in Millennium One-Step Foamable Adhesive, Millennium One Step Green Foamable Insulation Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500, OlyBond 500 Green, Insta Stik Quik Set Insulation Adhesive in ¾” to 1” ribbons spaced 12” o.c. or with ICP Adhesives CR-20 in 2.5” ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Top insulation layer shall be primed with PG 100 or XtraFlex 10.

Base Sheet: One ply of Polyflex SA Base, self adhered.

Primer: Base sheet shall be primed with PG 100 or XtraFlex 10.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -170.0 psf (See General Limitation #9).



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(10): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Polytherm, Polytherm-H, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-II, ACFoam-III, H-Shield Minimum 1.0” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, DEXcell FA Glass Mat Rood Board or SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: Apply insulation in Millennium One-Step Foamable Adhesive, Millennium One Step Green Foamable Insulation Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500, OlyBond 500 Green or Insta Stik Quik Set Insulation Adhesive in ¾” to 1” ribbons spaced 12” o.c. or with ICP Adhesives CR-20 in 2.5” ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Top insulation layer shall be primed with PG 100 or XtraFlex 10.

Base Sheet: One ply of Polyflex SA Base, self adhered.

Primer: Base sheet shall be primed with PG 100 or XtraFlex 10.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -172.5 psf (See General Limitation #9).



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(11): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply.

Primer: (Optional) Concrete deck shall be primed with PG 100 or XtraFlex 10 and allowed to dry prior to application of vapor barrier.

Vapor Barrier: (Optional) One ply of Elastoflex SA P, self-adhered.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Insulfoam EPS Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Apply insulation in ICP Adhesives CR-20 in continuous 3" to 3-1/2" beads/ribbons spaced 12" o.c. Additional layers of insulation to be adhered with ICP Adhesives CR-20 in continuous 3" to 3-1/2" beads/ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: (Optional) Apply WB-3000 at 1 gal. per 300 sq. ft.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: (Optional) One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -195.0 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(12): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam–II, ACFoam-III, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, H-Shield, Polytherm H, ENRGY 3 Minimum 2” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: All insulation shall be adhered in full asphalt applied at 25 lb/sq. or with Insta Stik Quik Set Insulation Adhesive in continuous ¾ to 1” beads/ribbons, OlyBond 500 or OlyBond 500 Green in continuous ¾” to 1” beads/ribbons, or ICP Adhesives CR-20 in continuous 3” to 3-1/2” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -225 psf (See General Limitation #9).



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(13): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply

Primer: Concrete deck shall be primed with PG 100 or XtraFlex 10 and allowed to dry prior to application of vapor barrier.

Vapor Barrier: One ply of Elastoflex SA P, self-adhered.
(Optional)

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-III, H-Shield CG, Multi-Max FA-3 Minimum 1.5” thick	N/A	N/A

Note: Apply insulation in ICP Adhesives CR-20 in continuous 3” to 3-1/2” beads/ribbons spaced 12” o.c. Additional layers of insulation to be adhered with ICP Adhesives CR-20 in continuous 3” to 3-1/2” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA self-adhered.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -227.5 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(14): All layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation.

All General and System limitations apply.

Primer: Concrete deck shall be primed with PG 100 or XtraFlex 10.
(Optional)

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam-II, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-III, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 Minimum 1.5” thick	N/A	N/A

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam-II, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-III, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 Minimum 1.5” thick	N/A	N/A

Note: Apply insulation in Millennium One-Step Foamable Adhesive, Millennium One Step Green Foamable Insulation Adhesive or Millennium PG-1 Pump Grade Adhesive in continuous ½” to ¾” beads/ribbons spaced 12” o.c. Additional layers of insulation to be adhered with Millennium One-Step Foamable Adhesive, Millennium One Step Green Foamable Insulation Adhesive or Millennium PG-1 Pump Grade Adhesive in continuous ½” to ¾” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.



**Surfacing:
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:**

-232.5 psf (See General Limitation #9).



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(15): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ACFoam-III, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, H-Shield, Polytherm-H Minimum 2” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: All insulation shall be adhered with hot asphalt at a rate of 25 lbs/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -232.5 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(16): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam–II, ACFoam-III, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G Minimum 2” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: All insulation shall be adhered with OlyBond at rate of 1 gal/ 100ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -232.5 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(17): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-IV Minimum 2.0” thick	N/A	N/A
Multi-Max FA-3 Minimum 1.5” thick	N/A	N/A
ACFoam-III, Polytherm G, XtraFlex Polyiso G Minimum 1.3” thick	N/A	N/A
ISO 95+ GL, H-Shield, Polytherm-H, H-Shield CG, JM ISO 3, ENRGY 3 Minimum 1.0” thick	N/A	N/A

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: All insulation shall be applied in ICP Adhesives CR-20 in continuous 1.5” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)
Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V PLUS or XtraFlex SBS Base SA self-adhered.
Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V PLUS or XtraFlex SBS Base SA self-adhered.
(Optional)
Membrane: One ply of Elastoflex SA P, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, or XtraFlex APP G SA self-adhered.
Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)
Maximum Design Pressure: -240.0 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(18): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply.

Primer: Concrete deck shall be primed with PG 100 or XtraFlex 10.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-III, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 Minimum 1.5” thick	N/A	N/A
DensDeck Minimum ½” thick	N/A	N/A

Note: Apply insulation in ICP Adhesives CR-20 in continuous 3” to 3-1/2” beads/ribbons spaced 12” o.c. to substrate. Additional layers of insulation to be adhered with ICP Adhesives CR-20 in continuous 3” to 3-1/2” beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Primer:
(Optional)** Apply WB-3000 at 1 gal. per 300 sq. ft.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

**Ply Sheet:
(Optional)** One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -262.5 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(19): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ACFoam-III, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G Minimum 2” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: Apply insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

**Primer:
(Optional)** Apply WB-3000 at 1 gal. per 300 sq. ft.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

**Ply Sheet:
(Optional)** One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -435.0 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(20): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply.

Primer: Concrete deck shall be primed with PG 100 or XtraFlex 10.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, ACFoam-III, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 Minimum 1.5” thick	N/A	N/A

Note: Apply insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Primer:
(Optional)** Apply WB-3000 at 1 gal. per 300 sq. ft.

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

**Ply Sheet:
(Optional)** One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -480 psf (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type C(1): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ENRGY-3, ACFoam-II, ACFoam-III, Polytherm, Polytherm G, XtraFlex Polyiso, XtraFlex Polyiso G, H-Shield, Polytherm-H Minimum 1.5” thick	1 or 4 with 11; 12 with 13, 2, 6 or 7	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Primer: Apply WB-3000 at 1 gal. per 300 sq. ft.
(Optional)

Base Sheet: One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.
(Optional)

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

Surfacing: Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
(Optional)

Maximum Design Pressure: -82.5 psf; (See General limitation #7.)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type C(2): All layers of insulation are mechanically attached to roof deck. Membranes subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1.5” thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	1 with 3; 4 with 7; 12 with 13	1:1.33 ft ²

Base Sheet: One ply of Elastobase V, Elastoshield VP HT, XtraFlex SBS Glass Base or XtraFlex SBS HT Base 650 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs. /sq.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -82.5 psf; (See General limitation #7.)



Membrane Type: SBS/APP
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type D: All insulation is loosed laid with preliminary attachment to deck. Base sheet is subsequently mechanically fastened through insulation to the roof deck. Membranes subsequently adhered.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1” thick	N/A	N/A
<u>(Optional) Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Minimum ¼” thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Base Sheet: One ply of Elastobase V, Elastobase P, Elastoshield VP HT, Polyanchor, XtraFlex SBS Glass Base or XtraFlex SBS HT Base 650 fastened to the deck as described below.

Fastening: Attach base sheet using OMG #14 Roofgrip or #15 Roofgrip Fasteners and Flat Bottom Metal Plates spaced 12” o.c. in a 4” lap and 12” o.c. in two equally spaced staggered rows in the center of the sheet.

Ply Sheet: One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -60 psf; (See General limitation #7.)



Membrane Type: SBS/APP
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(1): Base sheet self-adhered. Membranes subsequently adhered.

All General and System Limitations apply.

Note: Concrete deck shall be primed with PG 100 or XtraFlex 10 and allowed to dry prior to application of base sheet.

Base Sheet: One ply of Polyflex SA Base, self adhered.

**Ply Sheet:
(Optional)** One ply of Polyflex SA Base, self adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, or Xtraflex SBS G SA self adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -52.5 psf (See General Limitation #9.)



Membrane Type: SBS/APP
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(2): Base sheet self-adhered. Membranes subsequently adhered.

All General and System Limitations apply.

Note: Concrete deck shall be primed with PG 100 or XtraFlex 10 and allowed to dry prior to application of base sheet.

Primer: Top insulation layer shall be primed with PG 100 or XtraFlex 10.

Base Sheet: One ply of Polyflex SA Base, self adhered.

Primer: Base sheet shall be primed with PG 100 or XtraFlex 10.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design
Pressure:** -117.5 psf (See General Limitation #9.)



Membrane Type: SBS/APP
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(3): Base sheet self-adhered. Membranes subsequently adhered.

All General and System Limitations apply.

Note: Concrete deck shall be primed with PG 100 or XtraFlex 10 and allowed to dry prior to application of base sheet.

**Base Sheet:
(Optional)** One ply of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

**Ply Sheet:
(Optional)** One or more plies of Elastoflex SA V, Elastoflex SA V FR, Elastoflex SA V PLUS, Elastoflex SA V PLUS FR or XtraFlex SBS Base SA self-adhered.

Membrane: One ply of Elastoflex SA P, Elastoflex SA P FR, Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polyreflect, XtraFlex APP G SA, or XtraFlex SBS G SA, self-adhered.

**Surfacing:
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -315 psf (See General Limitation #9.)



CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE