



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NEOGARD, A Division of Hemple (USA) Inc.
2728 Empire Central
Dallas, TX 75235

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Elasta-Gard and Permthane Aliphatic II Coatings Systems.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 22-0825.01
Expiration Date: 09/29/27
Approval Date: 09/29/22
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Materials: Polyurethane

SCOPE:

This approves “Elasta-Gard and Permathane Aliphatic II Coatings Systems” as roof coating systems as manufactured by NEOGARD, A Division of Hemple (USA) Inc. as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

PHYSICAL PROPERTIES OF COMPONENTS

Coating System Name: Elasta-Gard and Permathane Aliphatic II Coatings Systems
Topcoat Trade Name: 7490-CA
Thickness: See specific substrate scope of use below.
Specifications: ASTM D 6083
Description: A single-component, aliphatic polyurethane coating applied membrane to the following substrates at an application rate of:

- Spray Polyurethane Foam: Apply 70620-CA base coat at a minimum rate of 1.5 gal./100ft² to yield an average thickness of 24 wet mils followed by 7490-CA at a minimum rate of 1.5 gal./100ft² to yield an average thickness of 24 wet mils of the topcoat.
- SBS or APP Granular Modified Bitumen: Apply 7780/7781 primer at a minimum rate of .33 gal./100ft² followed by two coats of 70620-CA base coat each applied at a minimum rate of 1.0 gal./100ft² to yield an average thickness of 16 wet mils per coat followed by 7490-CA at a minimum rate of 1.66 gal./100ft² to yield an average thickness of 24 wet mils of the topcoat.
- EPDM: Apply 7780/7781 primer at a minimum rate of .25 gal./100ft² followed by 70620-CA base coat at a minimum rate of 1.5 gal./100ft² to yield an average thickness of 24 wet mils followed by 7490-CA at a minimum rate of 1.5 gal./100ft² to yield an average thickness of 24 wet mils of the topcoat.
- Hypalon: Apply 7797/7798 primer at a minimum rate of .25 gal./100ft² followed by 70620-CA base coat at a minimum rate of 1.5 gal./100ft² to yield an average thickness of 24 wet mils followed by 7490-CA at a minimum rate of 1.5 gal./100ft² to yield an average thickness of 24 wet mils of the topcoat.
- Concrete*: Apply 7797/7798 primer at a minimum rate of .33 gal./100ft² followed by 70620-CA base coat at a minimum rate of 1.5 gal./100ft² to yield an average thickness of 24 wet mils followed by 7490-CA at a minimum rate of 1.5 gal./100ft² to yield an average thickness of 24 wet mils of the topcoat.

*Note: See Limitation #1.

Container Size: 5 and 55 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly Product Control Notice of Acceptance.



NOA No.: 22-0825.01
Expiration Date: 09/29/27
Approval Date: 09/29/22
Page 2 of 3

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies LLC	2241T0002	ASTM D 6083	04/15/22

MANUFACTURING LOCATION:

1. Dallas, TX

LIMITATIONS:

1. **Elasta-Gard and Permthane Aliphatic II Coatings Systems is not approved as and shall not be used as a Roof or Waterproofing System as required by the Florida Building Code Chapter 15 HVHZ.**
2. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
3. Elasta-Gard and Permthane Aliphatic II Coatings Systems shall not be applied in inclement weather conditions.
4. Elasta-Gard and Permthane Aliphatic II Coatings Systems shall not be applied over asphaltic shingles, metal shingles, fiber-cement shingles, quarry slate, cement or clay roofing tile, or wood shingles or shakes.
5. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
7. Elasta-Gard and Permthane Aliphatic II Coatings Systems shall be applied in accordance with manufacturer's published application instructions.
8. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade Product Control upon request.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
10. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE

