



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Chem Link, Inc.
353 E. Lyon Street
Schoolcraft, MI 49087

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: DuraLink 35

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 22-1005.03
Expiration Date: 01/12/28
Approval Date: 01/12/23
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Polyether

SCOPE:

This approves roofing maintenance coating systems using **DuraLink 35** as described in this Notice of Acceptance. This product has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

MANUFACTURING LOCATION

1. Schoolcraft, MI

EVIDENCE SUMMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies, LLC	1538T0012	ASTM C920	05/10/22

PRODUCT DESCRIPTION

DuraLink 35

<u>Description</u>	<u>Test</u>	<u>Properties</u>
Vertical Slump	ASTM C639	0
Horizontal Slump	ASTM C639	Pass
Extrusion Rate	ASTM C1183	52 ml/min.
Hardness	ASTM C661	36 (Hardness Reading)
Effects on Heat Aging (Percent Weight Loss)	ASTM C1246	1%
Tack-Free Time	ASTM C679	1 (hr)
Adhesion in Cohesion	ASTM C719	
Mortar primed with NovaPrime		0 in ²
Unprimed Glass		0 in ²
Unprimed Anodized Aluminum		0 in ²
Adhesion-in-Peel	ASTM C794	Dry Wet
Mortar primed with NovaPrime		20 lbf 13 lbf
Unprimed Glass		17 lbf 12 lbf
Unprimed Anodized Aluminum		14 lbf 10 lbf
Adhesion-in-Peel, exposed to UV through Glass	ASTM C794/ C1442	
Unprimed Glass		18 lbf
Visual Inspection for cracking	ASTM C793	
After Accelerated Weathering		Pass
After cold exposure and low temp bend		Pass

LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Chem Link, Inc. products shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
4. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
5. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance
7. DuraLink 35 shall be applied in accordance with manufacturer's published application instructions.

END OF THIS ACCEPTANCE

