



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Siplast, Inc.
1111 Highway 67 South
Arkadelphia, AR 71923

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Siplast Modified Bitumen Roof Systems over LWC Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No.17-1221.10 and consists of pages 1 through 15.
The submitted documentation was reviewed by. Jorge L. Acebo.



NOA No.: 22-1020.04
Expiration Date: 04/14/28
Approval Date: 04/13/23
Page 1 of 15

ROOFING SYSTEM APPROVAL

<u>Category:</u>	Roofing
<u>Sub-Category:</u>	Modified Bitumen
<u>Deck Type:</u>	Lightweight Concrete
<u>Material:</u>	SBS
<u>Maximum Design Pressure:</u>	-247.5 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Parabase	3' x 108'	ASTM D4601	Asphalt coated fiberglass base sheet for mechanically fastened applications.
Parabase FS	3' x 108'	ASTM D4601	Asphalt coated fiberglass base sheet with a polyolefin back surfacing for mechanically fastened applications.
Parabase Plus	3.28' x 102.3' 28 lbs./sq.	ASTM D4601	Elastomeric asphalt coated base sheet.
Paradiene 20	3.28' x 50' 90 lbs./sq.	ASTM D6163	Asphalt elastomer sheet with random fiberglass mat reinforcement used as the base ply of a Paradiene 20/30 system.
Paradiene 20 HT	3.28' x 50' 90 lbs./sq.	ASTM D6163	Asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply of a Paradiene 20/30 system.
Paradiene 20 EG	3.28' x 33.5' 90 lbs./sq.	ASTM D6163	Heavy duty asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply in Paradiene systems.
Paradiene 20 HV	3.28' x 33.5' 90 lbs./sq.	ASTM D6163	Heavy duty asphalt elastomer sheet with random fiberglass mat reinforcement used as a base ply of a Paradiene 20/30 system.
Paradiene 20 PR	3.28' x 50' 55 lbs./sq.	ASTM D6164	Asphalt elastomer sheet with polyester fiberglass scrim composite reinforcement used as the top ply of a Paradiene 20/20 PR system having a gravel surfacing. Has additional puncture resistance.
Paradiene 20 TG	3.28' x 33.5' 70 lbs./sq.	ASTM D6163	Asphalt elastomer sheet with random fiberglass reinforcement used as the base ply of a Paradiene 20/30 TG Series system.
Paradiene 20 TG F	3.28' x 33.5' 70 lbs./sq.	ASTM D6163	Asphalt elastomer sheet with random fiberglass reinforcement used as the base ply of a Paradiene 20/30 TG Series system.
Paradiene 20 HT TG	3.28' x 33.5' 70 lbs./sq.	ASTM D6163	Asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply of a Paradiene 20/30 system.
Paradiene 20 EG TG	3.28' x 33.5' 100 lbs./sq.	ASTM D6163	Heavy duty asphalt elastomer sheet with fiberglass scrim reinforced for use as a base ply in Paradiene 20TG/30TG systems.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Paradiene 20 HV TG	3.28' x 33.5' 100 lbs./sq.	ASTM D6163	Heavy duty asphalt elastomer sheet with random fiberglass mat reinforcement used as a base ply of a Paradiene 20TG/30TG system.
Paradiene 20 PR TG	3.28' x 33.5' 96 lbs./sq.	ASTM D6164	High performance SBS modified bitumen finish ply designed for use in gravel surfaced. Used as a surface ply of a Paradiene 20/20TG system.
Paradiene 20 TS	3.28' x 33.5' 76 lbs./sq.	ASTM D6163	High performance, semi adhered SBS modified bitumen with random fiberglass mat reinforcement used as a base ply of Paradiene 20/30 systems.
Paradiene 30 FR	3.28' x 33.5' 85 lbs./sq.	ASTM D6163	Asphalt elastomer sheet with mineral surfacing and random glass mat reinforcement, for use as the top ply of a Paradiene 20/30 system.
Paradiene 30 HT FR	3.28' x 33.5' 87 lbs./sq.	ASTM D6163	Fire-rated asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 FR TG	3.28' x 25.25' 80 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing and random fiberglass mat reinforcement for use as the top ply sheet of a Paradiene 20/30 TG Series system.
Paradiene 30 HT FR TG	3.28' x 25.25' 80 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene TG Series system.
Paradiene 40 FR	3.28' x 26' 115 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing, glass mat/glass scrim reinforced.
Paradiene 40 FR TG	3.28' x 26' 115 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing, glass mat/glass scrim reinforced.
Parafor 50 LT	3.28' x 17.5' 114 lbs./sq.	ASTM D6162	Heavy duty asphalt elastomer sheet with mineral surfacing, polyester mat scrim reinforced.
Parafor 50 TG	3.28' x 17.5' 114 lbs./sq.	ASTM D6162	Heavy duty asphalt elastomer sheet with mineral surfacing, polyester mat scrim reinforced.
IREX 40	3.28' x 34' 89 lbs./sq.	ASTM D6163	High-melt asphalt sheet with random fiberglass mat reinforcement for use as the base ply sheet for a Veral system.
IREX HT	3.28' x 34' 89 lbs./sq.	ASTM D6163	High-melt asphalt sheet with fiberglass scrim reinforcement for use as a base ply sheet for the Veral system.
Veral Aluminum	3.28' x 33.5' 90 lbs./sq.	ASTM D6298	Aluminum clad asphalt elastomer sheet with woven fiberglass reinforcement for use as the top ply sheet of a Veral system.
PA 311/ 311 M	5 or 55 gal.	ASTM D4479	Blend of adhesive asphalts and quick-drying solvents.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**TABLE 1**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
PA 828	5 gal.	ASTM D4586	Flashing Cement
PA 1021	5 gal.	ASTM D4586	Asphalt cutback reinforced general purpose cement with non-asbestos fibers.
PA 1125	5 or 55 gal.	ASTM D41	Asphalt primer.
PC – 227	5 or 55 gal	ASTM D6083	Elastomeric roof coating.

APPROVED INSULATIONS:**TABLE 2**

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
DensDeck	Water resistant gypsum.	G-P Gypsum Corp.

APPROVED FASTENERS / ADHESIVES:**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	NVS Fastener	Galvanized steel base ply fastener for lightweight concrete deck	N/A	Siplast, Inc.
2.	Zono-tite Fastener	Galvanized steel base ply fastener for lightweight concrete deck	N/A	Siplast, Inc.
3.	CR Base Sheet Fastener (1.2")	Galvanized steel base ply fastener for lightweight concrete deck	1.125" head x 1.2" length.	OMG, Inc.
4.	OMG XHD	Extra Heavy Duty Fastener for Steel and Wood Decks	Various	OMG, Inc.
5.	OMG 3" Metal Plate	Barbed Steel Plates	2-3/4" Round	OMG, Inc.
6.	Parafast XHD Fastener	Extra Heavy Duty Fastener for Steel and Wood Decks	Various	Siplast, Inc.
7.	Base Sheet Plate	Galvalume stress plate for use with OMG C-R Base Sheet Fasteners	2.75"	OMG, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
FM Approvals	FM 4470	J.I. 2Y1A1.AM	04/15/96
	FM 4470	J.I. 3Z3A7.AM	04/12/96
	FM 4454	3005387	04/26/00
	FM 4454	3008210	04/10/01
	FM 4454	3011768	02/14/02
	FM 4454	3018480	11/10/03
	FM 4470	3026749	07/27/06
	FM 4470	3023458	07/18/06
	FM 4470	3014692	08/05/03
Trinity-ERD	TAS 117	C8500SC.11.07	11/30/07
PRI Construction Materials Technologies LLC	ASTM D1876	SRI-026-02-01	09/16/11
	TAS 114-J	SRI-025-02-04	06/10/11
	TAS 114-D	SRI-058-02-01	05/19/13
	ASTM D3019	SRI-101-02-01	02/17/17
	ASTM D6083	SRI-101-02-02	04/21/17
	ASTM D6163	SRI-104-02-01	01/25/18
	ASTM D6164	SRI-105-02-02	01/03/18
	ASTM D6163	SRI-106-02-01	01/03/18
	ASTM D4601	SRI-115-02-01	05/22/18
	ASTM D4601	SRI-115-02-02	05/22/18
	ASTM D4601	SRI-115-02-03	08/15/18
	ASTM D6163	SRI-116-02-02.1	08/15/18
	ASTM D6163	SRI-125-02-03	08/21/19
	ASTM D6163	SRI-126-02-03	08/21/19
	ASTM D6162	SRI-127-02-03	09/09/19
	ASTM D6298	824T0098	03/21/23

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
FM Approval Deck Limitations	N/A	E(1), E(2), E(6), F(1)	01/01/13



APPROVED ASSEMBLIES:

Membrane Type:	SBS
Deck Type 4I:	Lightweight Concrete, Insulated
Deck Description:	Cellular or Aggregate Lightweight Concrete
System Type E(1):	Base sheet mechanically fastened.
Deck Types:	<p>Min. 22 ga., Type B vented, Grade 40 steel deck shall be secured 6" o.c. to structural supports spaced a maximum of 5 ft on centers with 3/8" puddle welds and washers. Deck was washed with distilled vinegar. Min. 1" Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 44 lb/ft³ and 300 psi Insulcel Lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 2" topcoat cast of min. 44 lb/ft³ and 300 psi Insulcel Lightweight or of min. 61 lb/ft³ and 250 psi ZIC insulating concrete (1:4). Allowed to cure for 3 days. (Maximum Design Pressure –75 psf.; See General Limitation #7)</p> <p>Or</p> <p>Min. 22 ga., Type B vented Grade 40 steel deck secured 3-3/4" o.c. to structural supports spaced a maximum of 5 ft on centers with 3/8" puddle welds and washers. Deck was washed with distilled vinegar. Min. 1" Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 61 lbs./ft³ and 250 psi ZIC insulating concrete (1:4) and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 2" topcoat cast of min. 61 lbs./ft³ and 250 psi ZIC insulating concrete (1:4). Allowed to cure for 3 days. (Maximum Design Pressure –60 psf.; See General Limitation #7)</p> <p>This Tested Assembly has been analyzed for allowable deck stress. See evidence submitted table.</p>
All General and System limitations apply.	
Base Sheet:	One ply of Parabase, Parabase FS or Parabase Plus mechanically fastened as detailed below
Fastening:	Fasten base sheet with Zono-tite Fastener on a 3" side lap fastened 7" o.c. on lap and three equally spaced rows 10" o.c. in the field. Fastener heads primed with PA-1125.
Ply Sheet:	Paradiene 20 TG, 20 TG F, 20 HV TG, 20 HT TG or 20 EG TG adhered by torch or Paradiene 20, 20 HT, 20 HV or 20 EG adhered with approved mopping asphalt at an application rate of 20-40 lbs./sq. or with PA 311/311M adhesive at a rate of 1.5-2 gal/sq.
Membrane:	Paradiene 30 FR, 30 HT FR, 40 FR or Parafor 50 LT adhered with approved mopping asphalt at an application rate of 20-40 lbs./sq. or PA 311/311M adhesive at a rate of 1.5-2 gal/sq. or Paradiene 30 FR TG, 30 HT FR TG or Parafor 50 TG adhered by torch.
Note:	See manufacturer's specifications for specific application requirements.
Surfacing:	<u>Optional</u> when granular surfaced membranes are used <u>Required with non-granular</u> surfaced membranes. Install one of the following: <ol style="list-style-type: none">400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal./sq.400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.
Maximum Design Pressure:	See Deck Type Options Above

Membrane Type:	SBS Foil
Deck Type 4I:	Lightweight Concrete, Insulated
Deck Description:	Cellular or Aggregate Lightweight Concrete
System Type E(2):	Base sheet mechanically fastened.
Deck Types:	<p>Min. 22 ga., Type B vented, Grade 40 steel deck shall be secured 6" o.c. to structural supports spaced a maximum of 5 ft on centers with 3/8" puddle welds and washers. Deck was washed with distilled vinegar. Min. 1" Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 44 lbs./ft³ and 300 psi Insulcel Lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 2" topcoat cast of min. 44 lbs./ft³ and 300 psi Insulcel Lightweight or of min. 61 lb/ft³ and 250 psi ZIC insulating concrete (1:4). Allowed to cure for 3 days. (Maximum Design Pressure –75 psf.; See General Limitation #7)</p> <p>Or</p> <p>Min. 22 ga., Type B vented, Grade 40 steel deck secured 3-3/4" o.c. to structural supports spaced a maximum of 5 ft on centers with 3/8" puddle welds and washers. Deck was washed with distilled vinegar. Min. 1" Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 61 lbs./ft³ and 250 psi ZIC insulating concrete (1:4) and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 2" topcoat cast of min. 61 lbs./ft³ and 250 psi ZIC insulating concrete (1:4). Allowed to cure for 3 days. (Maximum Design Pressure –60 psf.; See General Limitation #7)</p> <p>This Tested Assembly has been analyzed for allowable deck stress. See evidence submitted table.</p>
All General and System limitations apply.	
Base Sheet:	One ply of Parabase, Parabase FS or Parabase Plus mechanically fastened as detailed below:
Fastening:	Fasten base sheet with Zono-tite Fasteners on a 3" side lap fastened 7" o.c. on lap and three equally spaced rows 10" o.c. in the field. Fastener heads primed with PA-1125.
Ply Sheet:	<p>Paradiene 20 TG, 20 TG F, 20 HV TG, 20 HT TG, or 20 EG TG adhered by torch or Paradiene 20, 20 HT, 20 HV or 20 EG, adhered with approved mopping asphalt at an application rate of 20-25 lbs./sq.</p> <p>or</p> <p>IREX 40 or IREX HT adhered in approved mopping asphalt at an application rate of 20-25 lbs./sq. or by torch.</p>
Membrane:	Veral Aluminum adhered in approved mopping asphalt at an application rate of 20-40 lbs./sq. or by torch
Note:	Refer to manufacturer's specifications for specific application requirements.
Surfacing:	<p><u>Optional</u> when granular surfaced membranes are used <u>Required with non-granular</u> surfaced membranes. Install one of the following:</p> <ol style="list-style-type: none"> 1. 400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal./sq. 2. 400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.
Maximum Design Pressure:	See Deck Type Options Above

Membrane Type: SBS/SBS Foil

Deck Type 4I: Lightweight Concrete, Insulated

Deck Description: NVS Lightweight Concrete

System Type E(3): Base sheet mechanically fastened.

Deck Type Structural Concrete deck or existing BUR over structural concrete deck. Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 300 psi NVS lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 1" topcoat cast of min. 300 psi NVS lightweight concrete. Allowed to cure for 3 days.

All General and System limitations apply.

Base Sheet: One ply of Parabase, Parabase FS or Parabase Plus mechanically attached using NVS Base Sheet Fasteners or CR Base Sheet Fasteners (1.2") with Base Sheet Plates spaced 7½" o.c. in the 4" wide side lap and 10" o.c. in two equally spaced and staggered rows in the field of the sheets.

Ply Sheet: Paradiene 20 TG, 20 TG F, 20 HV TG, 20 HT TG or 20 EG TG adhered by torch or Paradiene 20, 20 HT, 20 HV or 20 EG adhered with approved mopping asphalt at an application rate of 20-40 lbs./sq. or with PA 311/311C adhesive at a rate of 1.5-2 gal/sq.

Or

(For Veral System) IREX 40 or IREX HT adhered in approved mopping asphalt at an application rate of 20-40 lbs./sq. or by torch.

Membrane: Paradiene 30 FR, 30 HT FR, 40 FR or Parafor 50 LT adhered with approved mopping asphalt at an application rate of 20-40 lbs./sq. or PA 311/311M adhesive at a rate of 1.5-2 gal/sq. or Paradiene 20 PR TG, 30 FR TG, or 30 HT FR TG adhered by torch.

Or

Veral Aluminum adhered in approved mopping asphalt at an application rate of 20-40 lbs./sq. or by torch.

Note: **Refer to manufacturer's specifications for specific application requirements.**

Surfacing: Optional when granular surfaced membranes are used Required with non-granular surfaced membranes. Install one of the following:

1. 400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal./sq.
2. 400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.

Maximum Design Pressure: -45 psf. (See General Limitation #7)

Membrane Type: SBS/SBS Foil
Deck Type 4I: Lightweight Concrete, Insulated
Deck Description: NVS Lightweight Concrete
System Type E(4): Base sheet mechanically fastened.
Deck Type: Structural Concrete deck or existing BUR over structural concrete deck. Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 300 psi NVS Lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 1" topcoat cast of min. 300 psi NVS Lightweight concrete. Allowed to cure for 3 days.

All General and System limitations apply.

Base Sheet: One ply of Parabase, Parabase FS or Parabase Plus mechanically fastened as detailed below:

Fastening: Fasten base sheet with NVS Fasteners on a 3" side lap fastened 7" o.c. on lap and three equally spaced rows 10" o.c. in the field.

Ply Sheet: Paradiene 20 TG, 20 HV TG, 20 HT TG, or 20 EG TG adhered by torch or Paradiene 20, 20 HT, 20 HV or 20 EG, adhered with approved mopping asphalt at an application rate of 20-40 lbs./sq. or PA 311 at a rate of 1.5-2 gal/sq.

Or

(For Veral system) IREX 40 or IREX HT adhered in approved mopping asphalt at an application rate of 20-40 lbs./sq. or by torch.

Membrane: Paradiene 30 FR, 30 HT FR, 40 FR or Parafor 50 LT adhered with approved mopping asphalt at an application rate of 20-40 lbs./sq. or PA 311/311M adhesive at a rate of 1.5-2 gal/sq. or Paradiene 20 PR TG, 30 FR TG, 30 HT TG, 30 HT FR TG or Parafor 50 TG adhered by torch.

Or

Veral Aluminum adhered in approved mopping asphalt at an application rate of 20-40 lbs./sq. or by torch.

Note: See manufacturer's specifications for specific application requirements.

Surfacing: Optional when granular surfaced membranes are used Required with non-granular surfaced membranes. Install one of the following:

1. 400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal/sq.
2. 400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.

Maximum Design Pressure:

-75 psf. (See General Limitation #7)

Membrane Type: SBS/SBS Foil

Deck Type 4I: Lightweight Concrete, Insulated

Deck Description: NVS Lightweight Concrete

System Type E(5): Base sheet mechanically fastened.

Deck Type: Structural Concrete deck or IREX 40 torch adhered over primed structural concrete deck. Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 390 psi NVS lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 1-1/4" topcoat cast of min. 390 psi NVS lightweight concrete. Allowed to cure for 3 days.

All General and System limitations apply.

Base Sheet: One ply of Parabase, Parabase FS or Parabase Plus mechanically fastened as detailed below.

Fastening: Fasten base sheet with NVS Fasteners along the 3" side lap fastened 6" o.c. on lap and five equally spaced rows 6" o.c. in the field.

Ply Sheet: Paradiene 20 TG, 20 HV TG, 20 HT TG, 20 TG or 20 EG TG adhered by torch.

Membrane: Paradiene 30 FR TG, 30 HT FR TG or Parafor 50 TG adhered by torch.

Note: See manufacturer's specifications for specific application requirements.

Surfacing: Optional when granular surfaced membranes are used Required with non-granular surfaced membranes. Install one of the following:

1. 400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal./sq.
2. 400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.

Maximum Design Pressure: -135 psf. (See General Limitation #7)

Membrane Type: SBS/SBS Foil

Deck Type 4I: Lightweight Concrete, Insulated

Deck Description: NVS Lightweight Concrete

System Type E(6): Base sheet mechanically fastened.

Deck Type: Min. 22 ga., Type B vented, Grade 40 steel deck attached with 3/8" puddle welds at every corrugation to steel supports spaced a maximum of 6 ft o.c. Deck side laps fastened at 24" o.c. with #10 TEK screws. One layer 5/8" thick DensDeck fastened to deck with Siplast Parafast XHD Fasteners or OMG XHD fasteners with 3" Metal Plates at a fastener density of 1:1.6 ft². A two-ply ASTM D 2178 Type IV fully adhered to DensDeck with hot asphalt. Insulperm insulation panels shall be placed in a 1/8" to 1/4" slurry-coat of min. 75 lbs./ft³ and 300 psi NVS lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 1" topcoat cast of 60 lbs./ft³ and 300 psi NVS Lightweight Insulating concrete. Allow to cure for 3 days.

This Tested Assembly has been analyzed for allowable deck stress. See evidence submitted table.

All General and System limitations apply.

Base Sheet: One ply of Parabase, Parabase FS or Parabase Plus mechanically fastened as detailed below:

Fastening: Fasten base sheet with NVS Fastener on a 3" side lap fastened 7" o.c. on lap and three equally spaced rows 10" o.c. in the field.

Ply Sheet: Paradiene 20 TG, 20 TG F, 20 HV TG, 20 HT TG or 20 EG TG adhered by torch or Paradiene 20, 20 HT, 20 HV or 20 EG adhered with approved mopping asphalt at an application rate of 20-40 lbs./sq.
Or
(For Veral system) IREX 40 or IREX HT adhered in approved mopping asphalt at an application rate of 20-40 lbs./sq. or by torch.

Membrane: Paradiene 30 FR, 30 HT FR, 40 FR or Parafor 50 LT adhered with approved mopping asphalt at an application rate of 20-40 lbs./sq. or PA 311/311M adhesive at a rate of 1.5-2 gal/sq. or Paradiene 20 PR TG, 30 CR TG, 30 FR TG, , 30 HT TG, 30 HT FR TG or Parafor 50 TG adhered by torch.
Or
Veral Aluminum adhered in approved mopping asphalt at an application rate of 20-40 lbs./sq. or by torch

Note: **See manufacturer's specifications for specific application requirements.**

Surfacing: Optional when granular surfaced membranes are used Required with non-granular surfaced membranes. Install one of the following:

1. 400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal./sq.
2. 400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.

Maximum Design Pressure: -75 psf. (See General Limitation #7)

Membrane Type:	SBS/SBS Foil
Deck Type 4I:	Lightweight Concrete, Insulated
Deck Description:	Cellular lightweight concrete (Insulcel)
System Type F(1):	Base sheet mechanically fastened.
Deck Type:	<p>Min. 22 ga., Type B vented, Grade 40 steel deck shall be secured 6" o.c. to structural supports spaced a maximum of 6 ft. on centers with 3/8" puddle welds and washers. Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 44 lbs./ft³ and 300 psi Insulcel lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 2" topcoat cast of min. 44 lbs./ft³ and 300 psi Insulcel lightweight insulating concrete. Insulcel RT Surface Treatment pellets are applied a rate of 4 lbs./sq. to the freshly poured lightweight concrete. After three days of curing the lightweight concrete the pellets are melted by torch.</p> <p>This Tested Assembly has been analyzed for allowable deck stress. See evidence submitted table.</p>
Base Sheet:	Paradiene 20 TS is adhered by torch.
Membrane:	Paradiene 30 FR TG, or 30 HT FR TG adhered by torch.
Note:	See manufacturer's specifications for specific application requirements.
Surfacing:	<p><u>Optional</u> when granular surfaced membranes are used <u>Required with non-granular</u> surfaced membranes. Install one of the following:</p> <ol style="list-style-type: none"> 1. 400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal./sq. 2. 400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.
Maximum Design Pressure:	-97.5 psf. (See General Limitation #9)

Membrane Type:	SBS/SBS Foil
Deck Type 4I:	Lightweight Concrete, Insulated
Deck Description:	Cellular lightweight concrete (Insulcel)
System Type F(2):	Base sheet mechanically fastened.
Deck Type:	Min. 2500 psi structural concrete deck. Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 44 lbs./ft ³ and 300 psi Insulcel lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 2" topcoat cast of min. 44 lbs./ft ³ and 300 psi Insulcel lightweight insulating concrete. Insulcel RT Surface Treatment pellets are applied a rate of 4 lbs./sq. to the freshly poured lightweight concrete. After three days of curing the lightweight concrete the pellets are melted by torch.
Base Sheet:	Paradiene 20 TS is adhered by torch.
Membrane:	Paradiene 30 FR TG or 30 HT FR TG adhered by torch.
Note:	See manufacturer's specifications for specific application requirements.
Surfacing:	<u>Optional</u> when granular surfaced membranes are used <u>Required with non-granular</u> surfaced membranes. Install one of the following: <ol style="list-style-type: none"> 1. 400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal./sq. 2. 400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.
Maximum Design Pressure:	-97.5 psf. (See General Limitation #9)

Membrane Type:	SBS/SBS Foil
Deck Type 4I:	Lightweight Concrete, Insulated
Deck Description:	Cellular lightweight concrete (Insulcel)
System Type F(3):	Base sheet mechanically fastened.
Deck Type:	Min. 2500 psi structural concrete deck. IREX 40 torch adhered to primed concrete deck (optional). Min. 1" Insulperm insulation panels shall be placed in a minimum 1/8" slurry-coat of min. 478 psi Insulcel lightweight insulating concrete and allowed to cure overnight. The following day the rigid insulation shall be covered with a minimum 2" topcoat cast of min. 478 psi Insulcel lightweight insulating concrete. Insulcel RT Surface Treatment pellets are applied a rate of 4 lbs./sq. to the freshly poured lightweight concrete. After three days of curing the lightweight concrete pellets are melted by torch.
Base Sheet:	Paradiene 20 TS is adhered by torch.
Ply Sheet: (Optional)	Paradiene 20, 20 HT, 20 HV, 20EG, 20 PR or 20 HT fully bonded to Paradiene 20 TS with PA-311 or Paradiene 20 TG, 20 HV TG, 20 EG TG, 20 PR TG, 20 HT TG or 20 TG F fully bonded to Paradiene 20 TS by torch (option 3) Paradiene 20 TG F fully bonded by torch when used with a torch cap.
Membrane:	Paradiene 30 FR, 30 HT FR, , 40 FR, Paradiene or Parafor 50 LT fully bonded in PA-311 adhesive at a rate of 1.5 gal/100 ft ² . Paradiene 30 FR TG, , Paradiene 40 FR TG, or Parafor 50 TG fully bonded by torch.
Note:	See manufacturer's specifications for specific application requirements.
Surfacing:	<u>Optional</u> when granular surfaced membranes are used <u>Required with non-granular</u> surfaced membranes. Install one of the following: <ol style="list-style-type: none"> 1. 400 lbs./sq. gravel in a flood coat of PA-311 or PA-311 M adhesive at an application rate of 3 gal./sq. 2. 400 lbs./sq. gravel in a flood coat of asphalt applied at a rate of 60 lbs./sq.
Maximum Design Pressure:	-247.5 psf. (See General Limitation #9)

LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For Systems where specific lightweight insulating concrete is referenced consult current lightweight insulating concrete NOA for specific deck construction and limitations. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant
(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE