



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Fluid Applied Roofing LLC
830 Space Dr.
Beavercreek, OH 45434

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Fluid Applied Roofing ProCoat Coatings Systems.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 4.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 22-1117.04
Expiration Date: 12/29/27
Approval Date: 12/29/22
Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Materials: Polyurethane-Acrylic

SCOPE:

This approves “Fluid Applied Roofing ProCoat Coatings Systems” as roof maintenance coating systems as manufactured by Fluid Applied Roofing LLC, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1			
<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
ProCoat Finish <i>Manufacturing Location #1</i>	5 or 55, 275 gal.	ASTM D6083	A single component polyurethane-acrylic roof maintenance coating.
FiberSeal Base <i>Manufacturing Location #1</i>	5 or 55, 275 gal.	Proprietary	A single component polyurethane-acrylic surface prep base coating. FiberSeal base shall always be applied with ProCoat Finish as a topcoat.
Rinseable Primer™ <i>Manufacturing Location #2</i>	5 gal.	Proprietary	A rinseable primer surface prep for select single ply membranes; to be used before application of coatings.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies LLC	2426T0001	ASTM D6083	10/10/22
	2426T0004	Physical Properties	10/05/22
	2624T0007	Physical Properties	10/06/22

MANUFACTURING LOCATION:

1. Sandusky, OH
2. Ambridge, PA



NOA No.: 22-1117.04
Expiration Date: 12/29/27
Approval Date: 12/29/22
Page 2 of 4

PHYSICAL PROPERTIES OF COMPONENTS

Coating System Name:	Fluid Applied Roofing ProCoat Coatings Systems
Topcoat Trade Name:	ProCoat Finish
Thickness:	See specific substrate scope of use below.
Specifications:	ASTM D 6083
Description	<p>A single-component, polyurethane-acrylic coating applied membrane to the following substrates as specified below:</p> <ul style="list-style-type: none">• <u>PVC Single-Ply</u>: Apply FiberSeal Base coat at a minimum rate of 1.75 gal./100 ft² to yield an average thickness of 24 wet mils followed by ProCoat Finish at a minimum rate of 1.5 gal./100 ft² to yield an average thickness of 24 wet mils of the topcoat.• <u>SBS Granular Modified Bitumen</u>: Apply FiberSeal Base coat at a minimum rate of 1.75 gal./100 ft² to yield an average thickness of 24 wet mils followed by ProCoat Finish at a minimum rate of 1.5 gal./100 ft² to yield an average thickness of 24 wet mils of the topcoat.• <u>EPDM Single-Ply</u>: Prime existing membrane with Rinseable Primer™ then apply FiberSeal Base coat at a minimum rate of 1.75 gal./100 ft² to yield an average thickness of 24 wet mils followed by ProCoat Finish at a minimum rate of 1.5 gal./100 ft² to yield an average thickness of 24 wet mils of the topcoat.• <u>Galvanized Steel</u>: Apply ProCoat Base coat at a minimum rate of 1.75 gal./100 ft² to yield an average thickness of 24 wet mils followed by ProCoat Finish at a minimum rate of 1.5 gal./100 ft² to yield an average thickness of 24 wet mils of the topcoat.• <u>TPO Single-Ply</u>: Prime existing membrane with Rinseable Primer™ then apply FiberSeal Base coat at a minimum rate of 1.75 gal./100 ft² to yield an average thickness of 24 wet mils followed by ProCoat Finish at a minimum rate of 1.5 gal./100 ft² to yield an average thickness of 24 wet mils of the topcoat.
Container Size:	5, 55 and 275 gallons. Note all precautions on container.
Systems Approvals:	Methods of application and quantities shall comply with specific Roof Assembly Product Control Notice of Acceptance.

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. Fluid Applied Roofing ProCoat Coatings Systems shall not be applied in inclement weather conditions.
3. Fluid Applied Roofing ProCoat Coatings Systems shall not be applied over asphaltic shingles, metal shingles, fiber-cement shingles, quarry slate, cement or clay roofing tile, or wood shingles or shakes.
4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
5. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
6. Fluid Applied Roofing ProCoat Coatings Systems shall be applied in accordance with manufacturer's published application instructions.
7. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade Product Control upon request.
8. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
9. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 22-1117.04
Expiration Date: 12/29/27
Approval Date: 12/29/22
Page 4 of 4