



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

SRS Distribution Inc.
7440 S. Hwy 121
McKinney, TX 75070

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: SRS TopShield Ice & Water G300 Underlayment

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 21-1229.04 and consists of pages 1 through 4.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 23-0209.02
Expiration Date: 01/25/28
Approval Date: 03/23/23
Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: SBS

SCOPE:

This acceptance is for **SRS TopShield Ice & Water G300 Underlayment**, for use with approved prepared roof assemblies where the applicable TAS/ASTM specific underlayment is specified and installed with prescribed approved adhesives, fasteners and fastener densities, as described in this Notice of Acceptance; designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
TopShield Ice & Water G300 <i>Manufacturing Location #1 & #2</i>	3' x 66'8" rolls 3' x 33'4" rolls	ASTM D1970	Fine granular surfaced, fiberglass reinforced, bituminous sheet material with a self-adhesive bottom layer, for use as an underlayment in sloped roof assemblies. Designed as an ice and water shield, and a shingle roofing underlayment.

MANUFACTURING LOCATION:

1. Greencastle, PA
2. Belton, TX

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
NEMO ETC, LLC.	4j-TAR-20-SSUDL-02.A	ASTM D1970	03/29/21

INSTALLATION REQUIREMENTS – SRS TopShield Ice & Water G300 SELF-ADHERED UNDERLAYMENT:

1. SRS TopShield Ice & Water G300 self adhering underlayment shall be installed in strict compliance with applicable Building Codes.
2. Observe and comply with roofing practices and guidelines as outlined by the National Roofing Contractors Associations (NRCA) when installing SRS self adhering underlayment.
3. During installation, comply with Occupational Safety and Health Administration (OSHA) safety standards; use common sense measures and adequate safety precautions to prevent accidents.
4. TopShield Ice & Water G300 shall be an acceptable underlayment for asphaltic shingles, wood shakes and shingles, and slate or simulated slate roof assemblies.



NOA No.: 23-0209.02
Expiration Date: 01/25/28
Approval Date: 03/23/23
Page 2 of 4

INSTALLATION REQUIREMENTS – SRS TopShield Ice & Water G300 SELF-ADHERED

UNDERLAYMENT: (CONTINUED)

5. Re-fasten any loose decking panels, and check for protruding nail heads prior to the application of the SRS self adhering underlayment.
6. SRS TopShield Ice & Water G300 self adhering underlayment shall not be adhered directly over any pre-existing roof membrane.
7. All approved substrates are to be clean, dry and free of any loose debris or moisture prior to the application of the SRS TopShield Ice & Water G300 self adhering underlayment. Refer applicable building codes prior to installation to verify acceptable substrates.
8. Prime all metal collars, flashing, valleys, liner, drip edge and concrete deck substrate with ASTM D 41 primer, water based acrylic or water based polymer modified primer.
9. Contractor may cut the underlayment into sections for workability and allow to relax prior to application.
10. Place the underlayment over metal drip edge in accordance with RAS 111.
11. Install the first course of underlayment parallel to the eave edge.
12. Apply the underlayment, working from the center of the material continuously to the ends of the sheet (half of the length of the sheet is the center); taking care to avoid wrinkles and ridges.
13. Remove the underlayment release film rapidly in a continuous fashion. Ensure the bottom adhesive side of the membrane does not adhere to its self. In the event this transpires, separate the two layers immediately. After some time, it may become impossible to do so without damaging the material.
14. It is recommended that end laps be staggered a minimum of 18" from the preceding course.
15. The Underlayment is to be back nailed along the head lap. The nails shall be, 11 gauge 1¹/₄" approved ring shank type applied with a minimum of a 1⁵/₈" approved tin cap or approved capnail as required per the High Velocity Hurricane Zone (HVHZ) section of the FBC, at a minimum rate of 9" o.c. The head lap of the preceding layer of underlayment is to cover the area being back nailed.
16. Roll or broom the entire membrane surface paying special attention to all overlap areas "side laps, end laps, T-joints" to ensure adhesion with acceptable substrates. A minimum of a 28 lb weighted roller may be used for steep slope applications. The use of a soft bristled push broom is acceptable on steeper slopes. The above mentioned procedures are necessary in order to apply uniform pressure and allow for contact of the membranes.
17. Apply 1/8" thick uniform layer of SBS trowel grade modified bitumen asphalt adhesive / flashing cement throughout the contact area of the 6" granule over granule and fabric over fabric end laps. Once the aforementioned procedure has been completed, the membrane must then be hand rolled in place in order to ensure contact of membrane and achieve a minimum of 1/8th asphaltic bleed out in designated area.
18. SRS TopShield Ice & Water G300 self adhering underlayment shall be applied to protrusions, slope changes, valleys, curbs, and other roof top penetrations before any other sections of the roof.
19. When applying the underlayment in the valley, start at the low point and work to the high point, rolling the membrane from the center outward in each direction.
20. For ridge applications, center the underlayment and roll from the center outward in both directions.
21. Flash vent pipes, stacks, chimneys and penetrations in compliance with Roof Assembly current Product Control Notice of Acceptance and applicable Building Code.
22. All protrusions or drains shall be initially taped with a 6" piece of like kind membrane. The flashing tape shall be pressed in place and formed around the protrusion to ensure a tight fit. A second layer of like kind membrane shall be applied over the flashing detail.

GENERAL LIMITATIONS – SRS TopShield Ice & Water G300 SELF-ADHERED UNDERLAYMENT:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. SRS TopShield Ice & Water G300 self adhering underlayment shall be applied only when material interface temperatures are 40⁰ F and rising.
4. SRS TopShield Ice & Water G300 self-adhered underlayment shall not be installed when any form of moisture such as water, dew, rain, etc. is present on the substrate.
5. SRS TopShield Ice & Water G300 self-adhered underlayment is to be applied to a smooth, clean and dry surface, with the deck free from irregularities.
6. Ensure roof has positive drainage prior to installation of SRS TopShield Ice & Water G300 self-adhered underlayment.
7. SRS TopShield Ice & Water G300 self-adhered underlayment shall not be applied over a pre-existing roof membrane or system.
8. Care should be taken during the loading procedure to keep foot traffic to a minimum and avoid dropping the roof covering directly on the underlayment.
9. SRS TopShield Ice & Water G300 shall not be left exposed as a temporary roof for longer than 30 days after application. The manufacturer reserves the right to change product exposure period at any time; not to exceed the preceding maximum time limitations.
10. If SRS TopShield Ice & Water G300 self-adhered underlayment or the ASTM standards are not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the product, wind uplift resistance, and fire testing results.
11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

MANUFACTURER’S CONSIDERATIONS:

1. Code body requirements supersede manufacturer’s recommendations and installation guidelines.

BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of these materials.

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 23-0209.02
Expiration Date: 01/25/28
Approval Date: 03/23/23
Page 4 of 4