



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Sika Corporation**  
**201 Polito Ave**  
**Lyndhurst, NJ. 07071**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Sikalastic 320 NS/SL

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 17-0522.03 and consists of pages 1 through 5.  
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 23-0303.08  
Expiration Date: 03/08/28  
Approval Date: 03/16/23  
Page 1 of 5

## ROOFING ASSEMBLY APPROVAL

**Category:** Roofing  
**Sub-Category:** Waterproofing  
**Materials:** Polyurethane  
**Deck Type:** Concrete  
**Maximum Design Pressure** N/A

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
Sikalastic 320 NS	Available in 5 or 55 gallon Drums	ASTM C836	Liquid applied, bitumen modified, coal tar free, moisture cured polyurethane that may be applied to green or damp concrete.
Sikalastic 320 SL	Available in 5 or 55 gallon Drums	ASTM C836	Liquid applied, bitumen modified, coal tar free, moisture cured polyurethane that may be applied to green or damp concrete.
Sikadrain Drainboard	n/a	n/a	Lightweight waterproofing membrane protection board. Offers protection and draining during backfilling or application of a structural concrete.

### EVIDENCE SUBMITTED:

<b><u>Test Agency</u></b>	<b><u>Test Identifier</u></b>	<b><u>Test Name/Report</u></b>	<b><u>Date</u></b>
PRI Construction Materials Technologies, LLC	LPI-079-02-01	ASTM C 836	09/29/17
	LPI-080-02-01	ASTM C 836	09/29/17
Miami Curtainwall Consultants, Corp.	MCWC-180220	TAS 114 App D	02/27/18




NOA No.: 23-0303.08  
Expiration Date: 03/08/28  
Approval Date: 03/16/23  
Page 2 of 5

## **APPROVED APPLICATIONS:**

<b>Deck Type 1</b>	Concrete Decks, Roof Plaza Decks, Parking Decks
<b>Deck Description:</b>	Min. 2500 psi, dual slab construction
<b>System Types F(1):</b>	Sikalastic 320
<b>Substrate Preparation:</b>	All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants. Substrate shall be smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions.
<b>Coating:</b>	Wipe detailing clean with Xylol or Toluol prior to application of membrane.  Apply Sikalastic 320NS/SL by spray, roller squeegee or trowel at minimum rate of 60 mils (25 ft <sup>2</sup> /gal) in accordance with manufacture's published literature.
<b>Integrity Test:</b>	Required, and shall be performed in accordance with ASTM D 5957 by an approved lab. Water maybe maintained for a period longer than 24 hours if required.
<b>Inspection:</b>	Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.
<b>Protection Board:</b>	Cured membrane must be protected with Sika Drainboard, Protection board or other Sika approved protection board.
<b>Surfacing:</b>	Structural Concrete Slab, minimum 2500 psi, in compliance with applicable Building Code.
<b>Maximum Design Pressure</b>	N/A

<b>Deck Type 1</b>	Concrete Decks, Roof Plaza Decks, Parking Decks, Planters
<b>Deck Description:</b>	Min. 2500 psi
<b>System Types F(2):</b>	Sikalastic 320
<b>Substrate Preparation:</b>	All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants. Substrate shall be smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions.
<b>Primer (Optional):</b>	Apply Sikalastic PF Lo-VOC Primer to concrete surface per manufactures published installation instructions.
<b>Coating:</b>	Wipe detailing clean with Xylol or Toluol prior to application of membrane. Apply Sikalastic 320NS/SL by spray, roller squeegee or trowel at minimum rate of 60 mils (25 ft <sup>2</sup> /gal) in accordance with manufacture's published literature.
<b>Integrity Test:</b>	Required, and shall be performed in accordance with ASTM D 5957 by an approved lab. Water maybe maintained for a period longer than 24 hours if required.
<b>Inspection:</b>	Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.
<b>Maximum Design Pressure</b>	-150 psf (See General Limitation #9)

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
  2. Required integrity flood testing report shall be provided to the Building Official for review at time of final inspection.
  3. A non-skid surfacing is required for all pedestrian areas, plaza decks or balconies.
  4. All work shall be performed by a Contractor licensed to do roofing/waterproofing and be a Manufacturer Trained 'Qualified Applicator' familiar with the details and approved by Sika Corporation., and only with approved equipment. Sika Corporation shall supply a list of approved applicators to the authority having jurisdiction.
  5. Flashings shall be installed according to the manufacturers published standard details, specific details, approved by Sika Corporation, shall be submitted to the Building Official for review.
  6. Sika Corporation, Sikalastic NS/SL shall not be installed without consultation with Sika Corporation, if ambient or surface temperature is below 40°F. Do not apply to wet or frozen concrete surface.
  7. Sika Corporation, Sikalastic NS/SL shall not be installed over lightweight insulating concrete.
  8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and the wind load requirements of applicable Building Code.
  9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
  10. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below
- A black oval seal with a white border. Inside, the text "MIAMI-DADE COUNTY" is written in white, bold, uppercase letters. Below it, the word "APPROVED" is written in white, bold, uppercase letters.
11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 23-0303.08  
Expiration Date: 03/08/28  
Approval Date: 03/16/23  
Page 5 of 5