



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Greenpro Ventures Private Limited**  
**7<sup>th</sup> Floor, Indra Complex, Sindhavaima Cross Road**  
**Vadodara, Gujarat 390004 INDIA**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: GP RU Roofing Underlayments

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5.

The submitted documentation was reviewed by Alex Tigera.

02/13/25



NOA No.: 23-0329.08  
Expiration Date: 02/13/30  
Approval Date: 02/13/25  
Page 1 of 5

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Underlayment  
**Material:** Polypropylene

### SCOPE:

This acceptance is for **GP RU Roofing Underlayments** as described in this Notice of Acceptance, for use with approved prepared roof assemblies where ASTM D8257 underlayment is specified and installed with prescribed approved fasteners and fastener densities.

### PRODUCT DESCRIPTION:

<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
<b>GP RU 425</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.
<b>GP RU 450</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.
<b>GP RU 475</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.
<b>GP RU 500</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.



NOA No.: 23-0329.08  
Expiration Date: 02/13/30  
Approval Date: 02/13/25  
Page 2 of 5

## PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
<b>GP RU 550</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.
<b>GP RU 600</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.
<b>GP RU 750</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.
<b>GP RU 800</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.
<b>GP RU 900</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.
<b>GP RU 1200</b> <i>Manufacturing Location #1</i>	4' x 250' rolls	ASTM D8257	Four-layered synthetic roofing underlayment comprised of a non-woven fabric on the exposed side, a polymeric laminate/bonding layer, a woven polypropylene base, and a polymeric laminate/coating layer on the sheathing side.

## MANUFACTURING LOCATION:

1. Thondavadi Village, India



NOA No.: 23-0329.08  
Expiration Date: 02/13/30  
Approval Date: 02/13/25  
Page 3 of 5

## EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
NEMO ETC, LLC.	4j-GPV-SSUDL-001.A	ASTM D8257	01/09/25

## INSTALLATION SPECIFICATIONS:

### **GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200**

1. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 shall be installed in strict compliance with applicable Building Code requirements with prescribed approved fasteners and fastener densities.
2. For slopes 2:12 through 4:12 and greater GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 shall be installed with a minimum 12-inch vertical lap and 8-inch horizontal laps.
3. For slopes 4:12 and greater GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 shall be installed with a minimum 6-inch vertical lap and 4-inch horizontal laps.
4. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 shall be fastened with corrosion resistant roofing nails having a 3/8-inch diameter head using the nail pattern printed on the product. Low profile plastic or metal cap corrosion resistant nails with 1-inch caps may be used when preferred or required by local codes.
5. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 is a component used in roof assemblies. Roof assemblies are approved under specific assembly Noticed of Acceptance.
6. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 may be used with Asphaltic and Synthetic shingles, Metal roofing, Tile, Slate and Cedar Shakes.
7. For fire classification of specific roof assemblies using GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 refer to a current Approved Roofing Materials Directory for fire ratings of this product.

## BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.



NOA No.: 23-0329.08  
Expiration Date: 02/13/30  
Approval Date: 02/13/25  
Page 4 of 5

## **LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 shall be applied to a smooth, clean and dry surface with deck free of irregularities. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application.
4. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 shall not be hot mopped, refer to manufacturer's published literature for product compatibility.
5. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 shall not be applied over an existing roof membrane as a recover system.
6. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 shall not be left exposed as a temporary roof for longer than 90 days of application.
7. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 is a component used in roof system assemblies. Roof system assemblies are approved under a specific Notice of Acceptance. Refer to Prepared Roofing system Product Control Notice of Acceptance for listed approval of this product with specific prepared roofing products.
8. GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 may be used with any approved roof covering Notice of Acceptance listing GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 as a component part of an assembly in the Notice of Acceptance. If GP RU 425, GP RU 450, GP RU 475, GP RU 500, GP RU 550, GP RU 600, GP RU 750, GP RU 800, GP RU 900, and GP RU 1200 is not listed; a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
9. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



**END OF THIS ACCEPTANCE**



**NOA No.: 23-0329.08**  
**Expiration Date: 02/13/30**  
**Approval Date: 02/13/25**  
**Page 5 of 5**