



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Huttig Building Products Inc.
555 Maryville University Drive, Suite 400
St. Louis, MO 63141

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: 1-5/8" Galvanized Tin Caps

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 18-0214.01 and consists of pages 1 through 3.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 23-0725.01
Expiration Date: 07/26/28
Approval Date: 08/31/23
Page 1 of 3

ROOFING COMPONENT APPROVAL:

Category: Roofing
Sub Categories: Roofing Fasteners
Materials: Steel

MANUFACTURING LOCATIONS:

1. Liaocheng Shandong, China

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

PLATES:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
1-5/8" Galvanized Tin Caps	1-5/8" (42.23mm) Diameter 0.0125" (0.32 mm) Min. Thickness.	TAS 114 Appendix E	Circular disk made from corrosion resistant galvanized steel. To be used as a stress distribution plate in conjunction with approved fasteners as a fastening system for approved Anchor Sheets, Base Sheets and Underlayments of various types and materials.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Intertek	TAS 114 Appendix E	H3269.01-106-18 R1/R3	06/18/18
	TAS 114 Appendix E	H3269.02-106-18 R1	01/29/18
	TAS 114 Appendix E	P837201-106-18 R0	06/12/23



NOA No.: 23-0725.01
Expiration Date: 07/26/28
Approval Date: 08/31/23
Page 2 of 3

APPROVED APPLICATIONS:


Tradename: 1-5/8" Galvanized Tin Caps

Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and Approved attachment patterns.
Product meets TAS 114 Appendix E Section 2 (ASTM G 85) for 280 hours and 1000 hours.

Deck: Wood

DETAIL DRAWING

TIN CAP Drawing



END OF THIS ACCEPTANCE



NOA No.: 23-0725.01
Expiration Date: 07/26/28
Approval Date: 08/31/23
Page 3 of 3