

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION 11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/economy

RFK Metal Roofing, Inc. 18855 SW 264 Street Homestead, FL 33031

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas, where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Jax Beach Series 1.5" Clipless Snaplock x 24ga. Steel Panel over Wood Deck

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 6. The submitted documentation was reviewed by Sifang Zhao, P.E.



09/21/2023

NOA-No.: 23-0801.10 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 1 of 6

ROOFING ASSEMBLY APPROVAL:

Category:	Roofing
Sub-Category:	Non-Structural Metal Roofing
Material:	Steel
Deck Type:	Wood
Maximum Design Pressure	–161.00 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

Product	Dimensions	Test <u>Specifications</u>	Product <u>Description</u>
Jax Beach Series 1.5" Clipless Snaplock x 24ga. Steel Panel	Length: various Height: 1.5" Width: 15-19" Thickness: 24ga. Min. Yield Strength: 51 ksi.	TAS 110	Corrosion resistant performed standing seam, coated, pre-finished steel panels.

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:

Product	Dimensions	Test <u>Specifications</u>	Product <u>Description</u>	<u>Manufacturer</u>
Bostik 70-050A	N/A	various Silyl Modified Polymer Adhesive		Bostik, Inc.
Evidence Submi	TTED:			
Test Age	<u>ncy</u>	<u>Test Identifi</u>	er <u>Test Name/Report</u>	Date
Architectural Testing		D4563.01-450 C6413.02-450		07/15/14 08/19/14
PRI Construction Mate Technologies	erials		ASTM B 117 ASTM G152	04/11/08 05/12/08



APPROVED ASSEMBLIES:

Wood, Non-Insulated		
New Construction $^{19}/_{32}$ " or greater plywood or wood plank, or for re-roofing 15/32" or greater plywood.		
2": 12" or greater		
See Table A below		
In accordance with applicable Building Code, but in no case shall it be less than 8d ring shank nails spaced 6" o.c. In reroofing, where the deck is less than $^{19}/_{32}$ " thick (Minimum $^{15}/_{32}$ ") The above attachment method must be in addition to existing attachment.		
Minimum underlayment shall be an ASTM D 226 Type II installed with a minimum 4" side-laps and 6" end-laps. Underlayment shall be fastened with corrosion resistant tin-caps and 1¼" annular ring-shank nails, spaced 6" o.c. at all laps and two staggered rows 12" o.c. in the field of the roll. Or, any Miami-Dade County Product Control Approved underlayment having a current NOA.		
Any approved fire barrier having a current NOA. Refer to a current fire directory listing for fire ratings of this roofing system assembly as well as the location of the fire barrier within the assembly. See Limitation # 1.		
Valley construction shall be in compliance with Roofing Application Standard RAS 133 and with the current published installation instructions and details in DMC Association of Regional Manufacturers Installation Manual.		
Install the "Jax Beach Series 1.5" Clipless Snaplock x 24ga Steel Panel 15" or 19" wide panel" including flashing penetrations, valleys, end laps and accessories in compliance with DMC Association of Regional Manufacturers current, published installation instructions and in compliance with the minimum requirements detailed in Roofing Application Standard RAS 133.		
Panels shall be installed along the clipless seam with corrosion resistant #10 pancake head screws of sufficient length to penetrate through the sheathing a minimum of $^{3}/_{16}$ " at a distance listed below in Table A . A continuous bead of Bostik 70-05A adhesive shall be applied on each side of the male rib before snapping the female end of the adjacent panel in place. See Details herein.		
:		

TABLE A Maximum Design Pressures			
Roof Areas	Field	Perimeter and Corner ¹	
Maximum Design Pressures	–97.25 psf.	–161.00 psf.	
Maximum Fastener Spacing	6" o.c.	3" o.c.	
1. Extrapolation shall not be allowed			



System Limitations


- 1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. The maximum designed pressure listed herein shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
- **3.** Panels may be rolls formed in continuous lengths from eave to ridge. Maximum lengths shall be as described in Roofing Application Standard RAS 133.
- 4. All panels shall be permanently labeled with the manufacturer's name and/or logo, city, state, and the following statement: "Miami-Dade County Product Control Approved" or with the Miami-Dade County Product Control Seal as seen below.




- 5. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule <u>61G20-3</u> of the Florida Administrative Code.
- 6. Panels may be jobsite roll formed with machine model #('s) <u>MPJ5610123</u> from DMC Association of Regional Manufacturers.



PROFILE DRAWING



MIAMI-DADE COUNTY APPROVED NOA-No.: 23-0801.10 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 5 of 6



END OF THIS ACCEPTANCE



NOA-No.: 23-0801.10 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 6 of 6