

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION 11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/economy

RFK Metal Roofing, Inc. 18855 SW 264 Street Homestead, FL 33031

### **SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas, where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

#### DESCRIPTION: DMC 150 SS - 0.032" Aluminum Panel over Wood deck

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 10. The submitted documentation was reviewed by Sifang Zhao, P.E.



09/21/2023

NOA-No.: 23-0801.13 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 1 of 10

# **ROOFING SYSTEM APPROVAL:**

<u>Category:</u>	Roofing
Sub-Category:	Metal, Panels (Non-Structural)
<u>Material:</u>	Aluminum
Deck Type:	Wood
<u>Maximum Design Pressure</u>	-180.00 psf

## TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<b>Product</b>	<b>Dimensions</b>	Test <u>Specifications</u>	Product <u>Description</u>
DMC 150 SS – 0.032" Aluminum Panel	Length: various Height: 1-1/2" Width: 16" Thickness 0.032" Min Yield Strength: 16ksi	TAS 110	Aluminum standing seam metal panel.
26 ga. DMC 150SS Fixed Clip	Length: 2" Height: 1-5/8" Width: 3/4" Thickness: 26ga		Stainless steel panel clip used for the field conditions of DMC 150 SS panel assembly System A.
Continuous Clip	Base: Length: 120" Height: 1-1/4" Width: 1" Thickness: 24ga Upper Clip: Length: 5.045" Height: 0.929" Width: 0.40" Thickness: 26ga		Two-piece panel clip (base and upper clip) used for the perimeter and corner conditions of DMC 150 SS panel assembly System A.
24 ga. DMC 150SS Fixed Clip	Length: 2-1/4" Height: 1-5/8" Base Width: 15/16" Thickness: 24ga		One-piece panel clip used for the field conditions of DMC 150 SS panel assembly System B.
22 ga. DMC 150SS Fixed Clip	Length: 6-1/4" Height: 1-5/8" Base Width: 3/4" Thickness: 22ga		One-piece panel clip used for the perimeter and corner conditions of DMC 150 SS panel assembly System B.



NOA-No.: 23-0801.13 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 2 of 10

<b>Product</b>	<b>Dimensions</b>	Test <u>Specifications</u>	Produc <u>Descripti</u>	
Bostik 70-05A	N/A	TAS 110	Heavy duty construct	tion adhesive.
<b>Evidence Submitted:</b>				
<b>Test Agency</b>		<u>Test Identifier</u>	Test Name/Report	<b>Date</b>
Akzo Nobel Coatings, Inc.		Lab Form	ASTM G 153	
PRI Asphalt Technologies, Inc.		AKZC-001-02-01 AKZC-001-02-02 AKZC-001-02-03 AKZC-001-02-04 AKZC-001-02-05	ASTM B 117	10/08/02
		DMC-005-02-01 DMC-008-02-01	TAS 125 TAS 100	04/26/13 04/24/13
Architecural Testing		56842.01-122-18	TAS 125	08/03/05
Architecural Testing		56842.02-122-18	TAS 100	08/02/05
Hurricane Test Laboratory, Inc.		0287-0513-07	TAS 125	05/10/07

## TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:



NOA-No.: 23-0801.13 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 3 of 10

## **APPROVED ASSEMBLIES:**

System A:	DMC 150SS 0.032" Aluminum 16" wide Panel
Deck Type:	Wood, Non-insulated
<b>Deck Description:</b>	New Construction <sup>19</sup> / <sub>32</sub> " or greater plywood or wood plank.
Slope Range:	2": 12" or greater
Maximum Uplift Pressure:	See Table A below
Deck Attachment:	In accordance with applicable Building Code, but in no case shall it be less than 8d annular ring shank nails spaced 6" o.c. In reroofing, where the deck is less than $^{19}/_{32}$ " thick (Minimum $^{15}/_{32}$ ") The above attachment method must be in addition to existing attachment.
Underlayment:	Minimum underlayment shall be an ASTM D 226 Type II installed with a minimum 4" side- lap and 6" end-laps. Underlayment shall be fastened with corrosion resistant tin-caps and 12 gauge 1 <sup>1</sup> / <sub>4</sub> " annular ring-shank nails, spaced 6" o.c. at all laps and two staggered rows 12" o.c. in the field of the roll or any approved underlayment having a current NOA.
Fire Barrier Board:	Any approved fire barrier having a current NOA. Refer to a current fire directory listing for fire ratings of this roofing system assembly as well as the location of the fire barrier within the assembly. See Limitation # 1.
Valleys:	Valley construction shall be in compliance with Roofing Application Standard RAS 133 and with the current published installation instructions and details in DMC Association of Regional Manufacturers Installation Manual.
Metal Panels and Accessories:	Install the "DMC 150SS 0.032" Aluminum 16" wide Panel " including flashing penetrations, valleys, end laps and accessories in compliance "DMC Association of Regional Manufacturers" current, published installation instructions and in compliance with the minimum requirements detailed in Roofing Application Standard RAS 133.
Field Conditions:	Panels shall be secured along the male rib with approved clips fastened with two corrosion resistant #10 pancake head fasteners of sufficient length to penetrate through the sheathing a minimum of $3/16$ ". The panel clips shall be located at the maximum spacing listed in <b>Table A</b> below.

	TABLE A	
	MAXIMUM DESIGN PRESSURES	
Roof Areas	Field	Perimeter and Corner <sup>1</sup>
Maximum Design Pressures	-71.25 psf	<b>—106.75 psf</b>
Maximum Clip Spacing	12" o.c.	6" o.c. <sup>2</sup>
Clip	26 ga. DMC 150SS Fixed Clip	Continuous Clip
Mechanical Seam	180°	180°
1. Extrapolation shall not be allo	wed	
2. Screws are alternated between	one (1) and two (2) at the o.c. spacing	



System B:	DMC 150SS 0.032" Aluminum 16" wide Panel
Deck Type:	Wood, Non-insulated
<b>Deck Description:</b>	New Construction $^{19}/_{32}$ " or greater plywood or wood plank.
Slope Range:	2": 12" or greater
Maximum Uplift Pressure:	See Table B below
Deck Attachment:	In accordance with applicable Building Code, but in no case shall it be less than 8d annular ring shank nails spaced at a maximum distance specified below in <b>Table B</b> . In reroofing, where the deck is less than $19/32$ " thick (Minimum $15/32$ ") The above attachment method must be in addition to existing attachment.
Underlayment:	Minimum underlayment shall be an ASTM D 226 Type II installed with a minimum 4" side- lap and 6" end-laps. Underlayment shall be fastened with corrosion resistant tin-caps and 12 gauge 1 ¼" annular ring-shank nails, spaced 6" o.c. at all laps and two staggered rows 12" o.c. in the field of the roll or any approved underlayment having a current NOA.
Fire Barrier Board:	Any approved fire barrier having a current NOA. Refer to a current fire directory listing for fire ratings of this roofing system assembly as well as the location of the fire barrier within the assembly. See Limitation # 1.
Valleys:	Valley construction shall be in compliance with Roofing Application Standard RAS 133 and with the current published installation instructions and details in DMC Association of Regional Manufacturers Installation Manual.
Metal Panels and Accessories:	Install the "DMC 150SS 0.032" Aluminum 16" wide Panel " including flashing penetrations, valleys, end laps and accessories in compliance "DMC Association of Regional Manufacturers" current, published installation instructions and in compliance with the minimum requirements detailed in Roofing Application Standard RAS 133.
	Panels shall be secured along the male rib with approved Panel clip listed below in <b>Table B</b> with two corrosion resistant #10 pancake head fasteners of sufficient length to penetrate through the sheathing a minimum of $^{3}/_{16}$ ". The panel clips are to be placed at a spacing listed below in <b>Table B</b> . The female rib of panel is placed over the male/clip assembly and seamed. See Detail B herein.

TABLE B MAXIMUM DESIGN PRESSURES		
Roof Areas	Field	Perimeter and Corner <sup>1</sup>
Maximum Design Pressures	-90.00 psf	-180.00 psf
Plywood Fastener Spacing	6" o.c.	4 o.c.
Сlip Туре	24 ga. DMC 150SS Fixed Clip	22 ga. DMC 150SS Fixed Clip
Maximum Clip Spacing	16" o.c.	8" o.c.
Bostik Seam Sealant	None	(1) 1/4" bead
Mechanical Seam	180°	180°
1. Extrapolation shall not be allowed		



NOA-No.: 23-0801.13 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 5 of 10

### LIMITATIONS


- 1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. The maximum designed pressure listed herein shall be applicable to all roof pressure zones (i.e., field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e., perimeters, extended corners and corners).
- **3.** Panels may be rolls formed in continuous lengths from eave to ridge. Maximum lengths shall be as described in Roofing Application Standard RAS 133
- 4. All panels shall be permanently labeled with the manufacturer's name and/or logo, city and state, and the following statement: "Miami-Dade County Product Control Approved" **or** with the Miami-Dade County Product Control Seal as seen below. All clips shall be permanently labeled with the manufacturer's name and/or logo, and/or model.




- 5. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule **61G20-3** of the Florida Administrative Code.
- 6. Panels may be jobsite roll formed with machine model # ('s) <u>MPJ5610123</u> from DMC Association of Regional Manufacturers.




## **PROFILE DRAWINGS**



DCM 150 SS 0.032" ALUMINUM PANEL










**CONTINUOUS CLIP** 




NOA-No.: 23-0801.13 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 7 of 10



22 GA DMC 150SS FIXED CLIP



NOA-No.: 23-0801.13 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 8 of 10




(Perimeter and Corner Conditions)




NOA-No.: 23-0801.13 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 9 of 10

DETAIL B







(Perimeter and Corner Condition Seam Detail)

## **END OF THIS ACCEPTANCE**

NOA-No.: 23-0801.13 Expiration Date: 09/21/2028 Approval Date: 09/21/2023 Page 10 of 10

