



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/building

Loren Cook Company
2015 E. Dale Street
Springfield, MO 65803

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Models CPV, CPS, and CPF Steel Rooftop Fans

APPROVAL DOCUMENT: Drawing No. **SD130522-18**, titled "Assembly CPV/CPS/CPF Hurricane Rated", sheet 1 through 14 of 14, dated 05/22/13, with revision D dated 11/06/2023, prepared by manufacturer, signed and sealed by Jerry T. Miller, P.E. bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, manufacturing address, model number, the positive and negative design pressure rating, indicate impact rated if applicable, installation instruction drawing reference number, approval number (NOA), the applicable test standards, and the statement reading 'Miami-Dade County Product Control Approved' is to be located on the door's side track, bottom angle, or inner surface of a panel.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews** and **revises** **NOA No. 21-0405.10** and consists of this page 1 and evidence page E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



01/10/24

NOA No. 23-0821.06
Expiration Date: December 19, 2024
Approval Date: January 18, 2024
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS NOA's

A. DRAWINGS (*Submitted under NOA No. 15-0915.10*)

1. Drawing No. **SD130522-18**, titled "Assembly CPV/CPS/CPF Hurricane Rated", sheets 1 through 14 of 14, dated 05/22/13, with revision D, prepared by manufacturer, signed and sealed by Bradley F. Skidmore, P.E.

B. TESTS

1. Test reports on: 1) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
2) Large Missile Impact Test per FBC, TAS 201-94
along with marked up drawings and installation diagram of CPV fans, prepared by Architectural Testing, Inc. Test Report No. **B9387.01-801-18**, dated 04/17/13, signed and sealed by Vinu J. Abraham, P.E. (*Submitted under NOA No. 13-0604.08*)

C. CALCULATIONS (*Submitted under NOA No. 13-0604.08*)

1. Wind loads and anchor verification calculations dated 11/27/13, prepared by manufacturer, signed and sealed by Bradley F. Skidmore, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS (*Submitted under NOA No. 18-1017.05*)

1. Statement letter of conformance, complying with **FBC 6th Edition (2017)** dated 10/10/18, issued by manufacturer, signed and sealed by Bradley F. Skidmore, P.E.
2. Statement letter of no financial interest dated 05/29/13, issued by manufacturer, signed and sealed by Bradley F. Skidmore, P.E. (*Submitted under NOA No. 13-0604.08*)

G. OTHERS

1. Notice of Acceptance No. **15-0915.10**, issued to Loren Cook Company for their Model ASP Steel Rooftop Fan, approved on 11/12/15 and expiring on 12/19/18.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0821.06

Expiration Date: December 19, 2024
Approval Date: January 18, 2024

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

2. NEW EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. **SD130522-18**, titled “Assembly CPV/CPS/CPF Hurricane Rated”, sheet 1 through 14 of 14, dated 05/22/13, with revision D dated 11/06/2023, prepared by manufacturer, signed and sealed by Jerry T. Miller, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. None.


F. STATEMENTS



1. Statement letter of conformance with the 8th edition (2023) of the, issued by Miller Engineering, dated 07/28/2023, signed and sealed by Jerry T. Miller, P.E.
2. Statement letter of no financial interest, issued by Miller Engineering, dated 11/06/2023, signed and sealed by Jerry T. Miller, P.E.
3. Testing contract letter, issued by Intertek, dated 11/17/2023, signed by Cassandra Matthews, Regional Administrative Manager.
4. Statement letter of conformance with the 7th edition (2020) of the FBC, issued by manufacturer, dated March 19, 2021, signed and sealed by Bradley F. Skidmore, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0821.06



Expiration Date: December 19, 2024
Approval Date: January 18, 2024






PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By 
Miami-Dade Product Control



60-150 DIRECT DRIVE ARRANGEMENT


490	111 1/2	56 1/4	90 1/4	75	47 5/8	2375
445	101 3/4	51 3/8	82 1/16	71 9/16	43 5/8	1984
402	92 1/2	46 3/4	74 7/16	64 5/16	39 5/8	1556
365	84 1/2	42 3/4	67 5/8	60 7/16	35 5/8	1277
330	76 3/4	38 7/8	61 5/16	53 13/16	33 5/8	1056
300	71 1/4	35 5/8	55 7/8	51 1/2	30 5/8	897
270	63 3/4	32 3/8	50 9/16	49 1/16	28 3/4	736
245/250	58 1/4	29 5/8	46 9/16	44 3/16	26 3/4	620
220/225	53	27	43 1/2	42 1/8	23 3/4	547
210	49 3/4	25 3/8	41 7/16	41	22 3/4	499
195	46 3/8	23 11/16	37 13/16	38 7/8	20 3/4	450
180	43 1/8	22 1/16	36 1/4	34 11/16	20 3/4	404
165	39 7/8	20 7/16	33 9/16	33 9/16	18 3/4	341
150	37 1/8	19 1/16	31 1/16	32 3/8	18 3/4	297
135	34 3/16	18	28 3/16	31 1/4	18 3/4	260
120	32 9/16	18	26 5/16	28 1/8	18 3/4	225
100	30 3/8	18	23 3/4	26 1/2	18 3/4	165
80	30 3/8	18	23 3/4	26 1/2	18 3/4	165
70	30 3/8	18	23 3/4	26 1/2	18 3/4	165
60	30 3/8	18	23 3/4	26 1/2	18 3/4	165
UNIT	A	B	C	D	E	MAXIMUM
SIZE	MAXIMUM	DIM	DIM	MAXIMUM	DIM	SHIPPING WT.



FASTENER SCHEDULE	
	3/8-16 HEX HEAD BOLT SAE GRADE 2
	SIZE 490: 1/2-13 BOLT SAE GR2 SIZE 60-445: 3/8-16 BOLT SAE GR2
	1/4 X 3/4 SELF-DRILL SCREW ASTM C1513
	#12 X 3/4 SELF-DRILL SCREW ASTM C1513
	SIZE 330-490: 1/2-13 BOLT SAE GR2 SIZE 60-300: 3/8-16 BOLT SAE GR2
SYMBOL	DESCRIPTION

NOTE:
DESIGN PRESSURE: +/- 100 PSF
IMPACT RATING: LARGE MISSILE IMPACT RESISTANT
DESIGN TESTING AND INSTALLATION CONFORMS TO FLORIDA BUILDING CODE
ALL CARBON STEEL IS COATED WITH BAKED POLYESTER POWDER COATING OR EQUAL
ALL CARBON STEEL COMPONENTS HAVE MINIMUM YIELD STRENGTH = 30KSI
SHIPPING WEIGHTS IN POUNDS, LESS MOTOR AND ACCESSORIES
ALL DIMENSIONS IN INCHES

JERRY TRAVIS MILLER- ENGINEER
FLORIDA LICENSE #89925
FLORIDA STATE CERTIFICATE
OF AUTHORITY #RY34386






MAT'L	-	
DRAWN	BFS	5/22/13
DESIGNER	BFS	SHEET 1 OF 14
DO NOT SCALE DRAWING		
TOLERANCES UNLESS OTHERWISE NOTED		
DECIMAL	FRACTIONAL	
.XX=±.063"	≤12"=±1/16"	
.XXX=±.010"	>12" THRU 96"=±1/8"	
.XXX=±.001"	>96" THRU 144"=±1/4"	
ANGULAR	>144"=±3/8"	
±2°	(NC)=NO INSPECTION REQ'D	



ASSEMBLY
CPV/CPS/CPF
HURRICANE RATED

SIZE	DRAWING NO.	REV.
B	SD130522-18	D






DIRECT MOUNT – STEEL STRUCTURE (36KSI)
UNIT MUST BE ATTACHED TO ROOF STRUCTURE
USING SIX GRADE 5 FASTENERS OF SIZE LISTED
BELOW.

ISOLATION RAIL MOUNT
UNIT MUST BE ATTACHED TO ISOLATION RAILS
USING SIX GRADE 5 BOLTS LISTED BELOW. THE
ISOLATORS WILL BE ANCHORED TO THE ROOF
USING FASTENER SIZE LISTED IN TABLE.

ISOLATION BASE MOUNT
UNIT MUST BE ATTACHED TO ISOLATION RAILS
USING SIX GRADE 5 BOLTS LISTED BELOW. THE
ISOLATORS WILL BE ANCHORED TO THE ROOF
USING FASTENER SIZE LISTED IN THE TABLE

UNIT SIZE	DIRECT MOUNT	DIRECT DRIVE ISOLATOR MOUNT FOUR ISOLATORS PER UNIT TWO FASTENERS PER ISOLATOR	BELT DRIVE					
			ISOLATION RAIL AND ISOLATION BASE MOUNT (REQUIRES FOUR ISOLATORS PER UNIT WITH TWO ATTACHMENT ANCHORS FOR EACH ISOLATOR)					
			ISOLATOR TYPE	VERTICAL RESTRAINT CAPACITY	CONCRETE ATTACHMENT ANCHOR SIZE	MINIMUM ENGAGEMENT	STEEL STRUCTURE GRADE 5 BOLT SIZE	WOOD ATTACHMENT LAG BOLT SIZE
60 – 135	3/8	3/8	LIGHT	1000#	3/8	3"	3/8	3/8
150 – 225	1/2		MEDIUM	2300#	5/8	4"	5/8	
245 – 300	5/8							
330 – 402	3/4							
445 – 490	7/8		HEAVY	4000#	5/8	4"	5/8	

ANCHORAGE OF FAN BASE AND ISOLATORS TO ROOF STRUCTURE



JERRY TRAVIS MILLER- ENGINEER
FLORIDA LICENSE #89925
FLORIDA STATE CERTIFICATE
OF AUTHORITY #RY34386




NOTES:


- 1) LOREN COOK MODEL CP FANS AS REFERRED TO HEREIN REFERS TO ALL LOREN COOK MODEL VENT SETS HAVING OUTER HOUSING CONSTRUCTED OF CARBON STEEL OR STAINLESS STEEL AND INDICATED AS MODEL CPV, CPS , CPS-A, CPF (BELT AND DIRECT).
- 2) THIS APPROVAL IS FOR THE STRUCTURAL PERFORMANCE AND IMPACT RESISTANCE ONLY. INTERIOR MECHANISM AND/OR ELECTRICAL CIRCUITRY ARE OUTSIDE THE SCOPE OF THIS APPROVAL.
- 3) CLOCKWISE ROTATION IS DEPICTED IN THE ILLUSTRATIONS IN THIS DOCUMENT. CLOCKWISE AND COUNTER-CLOCKWISE ROTATIONS ARE BOTH INCLUDED IN THE SCOPE OF THIS APPROVAL.
- 4) THE TOP HORIZONTAL (THD) FAN DISCHARGE IS DEPICTED IN THE ILLUSTRATIONS OF THIS DOCUMENT. ALL NORMAL DISCHARGE LOCATIONS ARE INCLUDED IN THIS APPROVAL. (THD,BHD,BAU,UPD,TAU,TAD,DBD)
- 5) THIS PRODUCT HAS NOT BEEN TESTED FOR WATER PENETRATION. THIS UNIT IS NOT CONSIDERED A RIDGE VENT.
- 6) THIS PRODUCT IS INTENDED TO ALLOW AIRFLOW TO PASS THROUGH ITS INLET AND OUTLET. WHEN THE INLET AND OUTLET OF THE FAN REQUIRE DUCT WORK, GUARDS ARE NOT REQUIRED ON THAT OPENING. ACCESSORIES (I.E. RAIN HOODS, BIRD SCREENS AND FILTER BOXES) ARE NOT PART OF THIS APPROVAL.
- 7) ALL FASTENERS ARE TO BE HIGH QUALITY CORROSION RESISTANT STEEL OR STAINLESS STEEL.
- 8) WHEN INSTALLING ON ISOLATORS, THE ISOLATORS MUST HAVE RESTRAINT CAPACITY TO RESIST THE UPLIFT AND OVERTURNING FORCES PRODUCED AT THE DESIGN WINDLOAD. FREE-STANDING SPRINGS ARE NOT ALLOWED.
- 9) ISOLATOR ANCHORS MUST BE PROPERLY SIZED TO RESIST THE FORCES PRODUCED AT THE DESIGN WINDLOAD.
- 10) THE INSTALLER IS RESPONSIBLE FOR CHECKING THAT ALL FASTENERS ARE PROPERLY INSTALLED AND ALL ACCESS PANELS ARE IN PLACE BEFORE PUTTING THE UNIT INTO SERVICE.
- 11) ALL FASTENERS AND ACCESS PANELS MUST BE PROPERLY REPLACED AFTER MAINTENANCE OPERATIONS HAVE BEEN PERFORMED TO MAINTAIN CODE COMPLIANCE.

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06

Expiration Date 12/19/2024

By 
Miami-Dade Product Control

MAT'L		—			LOREN COOK CO.	
DRAWN		BFS	5/22/13		MANUFACTURERS OF AIR MOVING EQUIPMENT	
DESIGNER		BFS	SHEET 2 OF 14		SPRINGFIELD, MISSOURI	
DO NOT SCALE DRAWING						ASSEMBLY CPV/CPS/CPF HURRICANE RATED
TOLERANCES UNLESS OTHERWISE NOTED						
DECIMAL		FRACTIONAL				
.XX=±.063"		≤12"=±1/16"				
.XXX=±.010"		>12" THRU 96"=±1/8"				
.XXXX=±.001"		>96" THRU 144"=±1/4"				
ANGULAR		>144"=±3/8"				
±2°		(NC)=NO INSPECTION REQ'D				
SIZE					DRAWING NO.	
B					SD130522-18	
REV.					D	




180	33 1/2	20 3/4	15 1/8	18	21 3/8	10 GA.
165	31 3/8	18 3/4	15 1/8	16	20 1/8	10 GA.
150	29	18 3/4	15 1/8	16	18 3/4	12 GA.
135	26 15/16	18 3/4	15 1/8	16	17 11/16	12 GA.
120	26 3/16	18 3/4	13 1/8	16	17 11/16	12 GA.
60-100	25 3/16	18 3/4	13 1/8	16	17 11/16	12 GA.
SIZE	A	B	C	D	E	F
UNIT	DIM	DIM	DIM	DIM	DIM	DIM




JERRY TRAVIS MILLER- ENGINEER
FLORIDA LICENSE #89925
FLORIDA STATE CERTIFICATE
OF AUTHORITY #RY34386

[Signature]
JERRY TRAVIS MILLER
No 89925
STATE OF FLORIDA
PROFESSIONAL ENGINEER
11/6/23

MAT'L A569 HRS F GA.		
DRAWN	BFS	5/22/13
DESIGNER	BFS	SHEET 3 OF 14
DO NOT SCALE DRAWING		
TOLERANCES UNLESS OTHERWISE NOTED		
DECIMAL	FRACTIONAL	
.XX=±.063"	≤12"=±1/16"	
.XXX=±.010"	>12" THRU 96"=±1/8"	
.XXXX=±.001"	>96" THRU 144"=±1/4"	
ANGULAR	>144"=±3/8"	
±2°	(NC)=NO INSPECTION REQ'D	


 LOREN COOK CO. MANUFACTURERS OF AIR MOVING EQUIPMENT SPRINGFIELD, MISSOURI		
CP PEDISTAL SIDE (60-180) CPV/CPS/CPF HURRICANE RATED		
SIZE	DRAWING NO.	REV.
B	SD130522-18	D

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control





NOTES:
1. 2 REQUIRED, BEND ONE OPPOSITE

490	55 1/8	28	2	3 13/16	7 GA.	13/16	3
445	50 1/4	28	2	3 13/16	7 GA.	13/16	3
402	45 5/8	24	2	3 13/16	7 GA.	13/16	3
365	41 7/8	24	2	3 13/16	7 GA.	11/16	3
330	38	21	2	3 13/16	7 GA.	11/16	3
300	34 3/4	21	2	3 13/16	7 GA.	9/16	2
270	31 11/16	21	2	3 7/8	10 GA.	9/16	2
245/250	28 15/16	18	2	3 7/8	10 GA.	9/16	2
220/225	26 5/16	18	1 1/2	2 7/8	10 GA.	9/16	2
210	24 11/16	18	1 1/2	2 7/8	10 GA.	9/16	2
195	23	18	1 1/2	2 7/8	10 GA.	7/16	2
UNIT	A	B	C	D	E	F	G
SIZE	DIM	DIM	DIM	DIM	DIM	DIM	DIM

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By 
Miami-Dade Product Control



MAT'L	A1011 SHEET STL, E GA.		 ®	LOREN COOK CO.					
DRAWN	BFS	5/22/13		MANUFACTURERS OF AIR MOVING EQUIPMENT					
DESIGNER	BFS	SHEET 4 OF 14		SPRINGFIELD, MISSOURI					
DO NOT SCALE DRAWING			PEDESTAL SIDE PANEL CPV/CPS/CPF HURRICANE RATED						
TOLERANCES UNLESS OTHERWISE NOTED									
<u>DECIMAL</u>		<u>FRACTIONAL</u>							
.XX=±.063"		≤12"=±1/16"	SIZE			DRAWING NO.		REV.	
.XXX=±.010"		>12" THRU 96"=±1/8"							
.XXXX=±.001"		>96" THRU 144"=±1/4"	B			SD130522-18		D	
		>144"=±3/8"							
<u>ANGULAR</u> ±2°		(NC)=NO INSPECTION REQ'D							



490	44	83 5/8	7	18GA
445	40	76 1/4	7	18GA
402	36	69 5/8	7	18GA
365	32	63 5/8	7	18GA
330	30	57 3/4	6	18GA
300	27	53	6	18GA
270	25	48 1/4	6	18GA
245/250	23	44	6	18GA
220/225	21	40 3/8	6	18GA
210	20	38 1/4	6	18GA
195	18	35 1/8	5	18GA
180	18	33	5	18GA
165	16	30 7/8	5	18GA
150	16	28 1/2	5	18GA
135	16	26 3/8	5	18GA
120	16	25 5/8	5	18GA
60-100	16	24 11/16	5	18GA
UNIT	A	B	C	MATERIAL
SIZE	DIM	DIM	DIM	GAUGE

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control




MAT'L	A1011 SHEET/A36 ANGLE	
DRAWN	BFS	5/22/13
DESIGNER	BFS	SHEET 5 OF 14
DO NOT SCALE DRAWING		
TOLERANCES UNLESS OTHERWISE NOTED		
DECIMAL	FRACTIONAL	
.XX=±.063"	≤12"=±1/16"	
.XXX=±.010"	>12" THRU 96"=±1/8"	
.XXXX=±.001"	>96" THRU 144"=±1/4"	
ANGULAR	>144"=±3/8"	
±2°	(NC)=NO INSPECTION REQ'D	


**LOREN COOK CO.**
MANUFACTURERS OF AIR MOVING EQUIPMENT
SPRINGFIELD, MISSOURI

WEATHER COVER FRONT
CPV/CPS/CPF
HURRICANE RATED


SIZE	DRAWING NO.	REV.
B	SD130522-18	D




490	44 1/4	34 3/16	30 3/8	16 GA
445	40 1/4	34 3/16	27 7/8	16 GA
402	36 1/4	30 3/16	25 7/8	16 GA
365	32 1/4	30 3/16	23 5/8	16 GA
330	30 1/4	26 3/16	21 5/8	16 GA
300	27 1/4	26 3/16	20 1/8	16 GA
270	25 1/4	26 3/16	18 7/16	16 GA
245/250	23 1/8	23 3/16	16 15/16	16 GA
220/225	21 1/16	23 3/16	15 15/16	16 GA
210	20 1/16	23 3/16	15 7/16	16 GA
195	18 1/16	22 3/16	13 15/16	16 GA
180	18 1/16	19 3/16	13 7/16	16 GA
165	16 1/16	19 3/16	12 9/16	16 GA
150	16 1/16	19 3/16	11 9/16	16 GA
135	16 1/16	19 3/16	10 9/16	16 GA
120	16 1/16	17 3/16	9 13/16	16 GA
60-100	16 1/16	17 3/16	8 13/16	16 GA
UNIT	A	B	C	MATERIAL
SIZE	DIM	DIM	DIM	GAUGE

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By 
Miami-Dade Product Control



MAT'L		A-1011 CS-B		 ®	LOREN COOK CO. MANUFACTURERS OF AIR MOVING EQUIPMENT SPRINGFIELD, MISSOURI			
DRAWN		BFS	5/22/13		CP WEATHER COVER CAP CPV/CPS/CPF HURRICANE RATED			
DESIGNER		BFS	SHEET 6 OF 14					
DO NOT SCALE DRAWING								
TOLERANCES UNLESS OTHERWISE NOTED								
<u>DECIMAL</u> .XX=±.063" .XXX=±.010" .XXXX=±.001"		<u>FRACTIONAL</u> ≤12"=±1/16" >12" THRU 96"=±1/8" >96" THRU 144"=±1/4" >144"=±3/8"			SIZE	DRAWING NO.	REV.	
<u>ANGULAR</u> ±2°		(NC)=NO INSPECTION REQ'D						B




490	37 7/16	53 5/8	88 3/4	93 5/16	10 GA.	12 GA.
445	34	48 11/16	80 9/16	84 3/4	10 GA.	12 GA.
402	30 3/4	44 1/16	72 15/16	76 11/16	10 GA.	12 GA.
365	27 7/8	39 15/16	66 1/8	69 5/8	10 GA.	12 GA.
330	25 1/4	36 1/8	59 13/16	62 15/16	10 GA.	12 GA.
300	22 15/16	32 13/16	54 3/8	57	10 GA.	12 GA.
270	20 5/8	29 9/16	49 1/16	51 5/16	12 GA.	14 GA.
245/250	18 3/4	26 13/16	45 1/16	46 1/2	12 GA.	14 GA.
220/225	17 3/16	24 5/8	42	42 13/16	12 GA.	14 GA.
210	16 1/16	23	39 15/16	40 1/16	12 GA.	14 GA.
195	14 15/16	21 5/16	36 5/16	37 1/8	12 GA.	14 GA.
180	13 3/4	19 11/16	34 3/4	34 3/16	12 GA.	14 GA.
165	12 5/8	18 1/16	32 1/16	31 5/16	12 GA.	14 GA.
150	11 7/16	16 7/16	29 9/16	29 1/2	12 GA.	14 GA.
135	10 5/16	14 3/4	26 11/16	25 3/4	12 GA.	14 GA.
120	9 3/16	13 1/8	24 13/16	22 13/16	12 GA.	14 GA.
60-100	7 9/16	10 15/16	22 1/4	19	12 GA.	14 GA.
UNIT	A	B	C	D	E	F
SIZE	DIM	DIM	DIM	DIM	DIM	DIM


NOTES



1) 3/8-16 WELD NUT, C1008 STL, 8 PLACES, SIZES 60-300
1/2-13 WELD STUD, C1008 STL, 8 PLACES, SIZES 330-490
BOTH SIDES



MAT'L	HR STEEL - ASTM A1011	
DRAWN	BFS	5/22/13
DESIGNER	BFS	SHEET 7 OF 14
DO NOT SCALE DRAWING		
TOLERANCES UNLESS OTHERWISE NOTED		
DECIMAL	FRACTIONAL	
.XX=±.063"	≤12"=±1/16"	
.XXX=±.010"	>12" THRU 96"=±1/8"	
.XXX=±.001"	>96" THRU 144"=±1/4"	
ANGULAR	>144"=±3/8"	
±2'	(NC)=NO INSPECTION REQ'D	

 LOREN COOK CO. MANUFACTURERS OF AIR MOVING EQUIPMENT SPRINGFIELD, MISSOURI		
CP FAN HOUSING CPV/CPS/CPF HURRICANE RATED		
SIZE	DRAWING NO.	REV.
B	SD130522-18	D


PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By 
Miami-Dade Product Control




490	45 3/8	47 5/8	3	26	13/16	3	14 GA.
445	42 9/16	43 5/8	3	24	13/16	3	14 GA.
402	38 11/16	39 5/8	3	22	13/16	3	14 GA.
365	33 15/16	35 5/8	2	18	13/16	3	14 GA.
330	32 15/16	33 5/8	2	18	13/16	3	14 GA.
300	30 1/16	30 5/8	2	16	11/16	3	14 GA.
270	28 1/4	28 3/4	2	16	11/16	3	16 GA.
245/250	26 5/16	26 3/4	2	16	11/16	3	16 GA.
220/225	22 15/16	22 3/4	1 1/2	14	9/16	3	16 GA.
210	22	22 3/4	1 1/2	14	9/16	4	16 GA.
195	20 1/4	20 3/4	1 1/2	12	9/16	3	16 GA.
180	17 5/16	20 3/4	1 1/2	12	9/16	3	16 GA.
165	16 7/16	18 3/4	1 1/2	12	9/16	3	16 GA.
150	17 1/8	18 3/4	1 1/2	12	9/16	3	16 GA.
135	17	18 3/4	1 1/2	12	9/16	4	16 GA.
120	17	18 3/4	1 1/2	14	9/16	3	16 GA.
60-100	17	18 3/4	1 1/2	12	9/16	3	16 GA.
UNIT	A	B	C	D	E	F	MATERIAL
SIZE	DIM	DIM	DIM	DIM	DIM	DIM	GAUGE

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control




MAT'L		ASTM A1011 HR STEEL			LOREN COOK CO.	
DRAWN		BFS	5/22/13		MANUFACTURERS OF AIR MOVING EQUIPMENT	
DESIGNER		BFS	SHEET 8 OF 14		SPRINGFIELD, MISSOURI	
DO NOT SCALE DRAWING						
TOLERANCES UNLESS OTHERWISE NOTED						
<u>DECIMAL</u>		<u>FRACTIONAL</u>		CP INLET PEDISTAL SIDE CPV/CPS/CPF HURRICANE RATED		
.XX=±.063"		≤12"=±1/16"				
.XXX=±.010"		>12" THRU 96"=±1/8"				
.XXXX=±.001"		>96" THRU 144"=±1/4"		SIZE		
ANGULAR		>144"=±3/8"				DRAWING NO.
±2'		(NC)=NO INSPECTION REQ'D		REV.		
				B		
				SD130522-18		
				D		




490	41 5/8	57 7/8	2	1 3/16	9 13/16	3	13 1/16	13 7/8	2	3
445	38 3/16	52 15/16	2	1 3/16	8 15/16	3	11 13/16	12 21/32	2	3
402	34 15/16	48 5/16	2	1 3/16	8 1/8	3	10 21/32	11 1/2	2	3
365	32 1/16	44 3/16	2	1 3/16	7 7/16	3	9 5/8	10 15/32	2	3
330	29 7/16	40 5/16	2	1 3/16	6 3/4	3	8 21/32	9 1/2	2	3
300	27 3/16	37	2	1 3/16	6 3/16	3	7 27/32	8 21/32	2	2
270	24 7/8	33 3/4	2	1 3/16	11 1/4	1	7 1/32	7 27/32	2	2
245/250	23	31	2	1 3/16	10 5/16	1	6 11/32	7 5/32	2	2
220/225	20 7/16	27 13/16	1 1/2	11/16	9 9/16	1	5 25/32	6 5/8	2	2
210	19 5/16	26 3/16	1 1/2	11/16	9	1	5 3/8	6 7/32	2	1
195	18 3/16	24 1/2	1 1/2	11/16	8 7/16	1	10 3/4	-	-	1
180	16 15/16	22 7/8	1 1/2	11/16	7 13/16	1	9 15/16	-	-	1
165	15 13/16	21 1/4	1 1/2	11/16	7 1/4	1	9 1/8	-	-	1
150	14 5/8	19 5/8	1 1/2	11/16	6 5/8	1	8 5/16	-	-	1
135	13 1/2	17 15/16	1 1/2	11/16	6 1/16	1	7 15/32	-	-	1
120	12 3/8	16 5/16	1 1/2	11/16	-	-	6 21/32	-	-	1
60-100	10 3/4	14 1/16	1 1/2	11/16	-	-	5 17/32	-	-	1
UNIT	A	B	C	D	E	F	G	H	J	K
SIZE	DIM	DIM	DIM	DIM	DIM	DIM	DIM	DIM	DIM	DIM

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control




MAT'L		A36 STEEL ANGLE			LOREN COOK CO.	
DRAWN		BFS	5/22/13		MANUFACTURERS OF AIR MOVING EQUIPMENT	
DESIGNER		BFS	SHEET 9 OF 14		SPRINGFIELD, MISSOURI	
DO NOT SCALE DRAWING						
TOLERANCES UNLESS OTHERWISE NOTED						
<u>DECIMAL</u>		<u>FRACTIONAL</u>				
.XX=±.063"		≤12"=±1/16"				
.XXX=±.010"		>12" THRU 96"=±1/8"				
.XXXX=±.001"		>96" THRU 144"=±1/4"				
<u>ANGULAR</u>		>144"=±3/8"				
±2'		(NC)=NO INSPECTION REQ'D				
CP DISCHARGE FLANGE						
CPV/CPS/CPF						
HURRICANE RATED						
SIZE		DRAWING NO.			REV.	
B		SD130522-18			D	




445-490	26 1/8	19 3/8	9 11/16	3	16
300-402	21 1/4	17	8 1/2	3	16
220-270	18 1/2	13	—	2	16
180-210	15 5/8	9	—	2	16
60-165	10 1/2	8 1/2	—	2	16
UNIT	A	B	C	D	MATERIAL
SIZE	DIM	DIM	DIM	DIM	GAUGE

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control



MAT'L		ASTM A1011 HR SHEET			LOREN COOK CO.								
DRAWN		BFS	5/22/13		MANUFACTURERS OF AIR MOVING EQUIPMENT								
DESIGNER		BFS	SHEET 10 OF 14		SPRINGFIELD, MISSOURI								
DO NOT SCALE DRAWING					CP PEDESTAL SIDE COVER CPV/CPS/CPF HURRICANE RATED								
TOLERANCES UNLESS OTHERWISE NOTED													
<u>DECIMAL</u>		<u>FRACTIONAL</u>											
.XX=±.063"		≤12"=±1/16"											
.XXX=±.010"		>12" THRU 96"=±1/8"			SIZE			DRAWING NO.			REV.		
.XXXX=±.001"		>96" THRU 144"=±1/4"											
<u>ANGULAR</u>		>144"=±3/8"			B			SD130522-18			D		
±2"		(NC)=NO INSPECTION REQ'D											




490	41 5/8	57 7/8	2 X 2 X 1/8 STEEL ANGLE	1 3/16	16
445	38 3/16	52 15/16	2 X 2 X 1/8 STEEL ANGLE	1 3/16	16
402	34 15/16	48 5/16	2 X 2 X 1/8 STEEL ANGLE	1 3/16	16
365	32 1/16	44 3/16	2 X 2 X 1/8 STEEL ANGLE	1 3/16	16
330	29 7/16	40 5/16	2 X 2 X 1/8 STEEL ANGLE	1 3/16	16
300	27 3/16	37	2 X 2 X 1/8 STEEL ANGLE	1 3/16	16
270	24 7/8	33 3/4	2 X 2 X 1/8 STEEL ANGLE	1 3/16	12
245/250	23	31	2 X 2 X 1/8 STEEL ANGLE	1 3/16	12
220/225	20 7/16	27 13/16	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	12
210	19 5/16	26 3/16	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	12
195	18 3/16	24 1/2	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	8
180	16 15/16	22 7/8	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	8
165	15 13/16	21 1/4	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	8
150	14 5/8	19 5/8	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	8
135	13 1/2	17 15/16	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	8
120	12 3/8	16 5/16	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	8
60-100	10 3/4	14 1/16	1 1/2 X 1 1/2 X 1/8 STEEL ANGLE	11/16	6
UNIT	A	B	C	D	E
SIZE	DIM	DIM	DIM	DIM	DIM

NOTES:
1. OUTLET GUARD REQUIRED WHEN FAN OUTLET IS EXPOSED TO OUTDOOR CONDITIONS.

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control




MAT'L	ASTM A36	
DRAWN	BFS	5/22/13
DESIGNER	BFS	SHEET 11 OF 14
DO NOT SCALE DRAWING		
TOLERANCES UNLESS OTHERWISE NOTED		
DECIMAL	FRACTIONAL	
.XX=±.063"	≤12"=±1/16"	
.XXX=±.010"	>12" THRU 96"=±1/8"	
.XXX=±.001"	>96" THRU 144"=±1/4"	
ANGULAR	>144"=±3/8"	
±2'	(NC)=NO INSPECTION REQ'D	



LOREN COOK CO.
MANUFACTURERS OF AIR MOVING EQUIPMENT
SPRINGFIELD, MISSOURI

CP DISCHARGE GUARD
CPV/CPS/CPF
HURRICANE RATED

SIZE	DRAWING NO.	REV.
B	SD130522-18	D





490	54 1/4	50 1/4	3/4
445	48 3/4	44 3/4	3/4
402	44 1/2	40 1/2	3/4
365	40 3/4	36 3/4	3/4
330	37 1/4	33 1/4	3/4
300	34 1/4	30 1/4	5/8
270	31 1/4	27 1/4	5/8
245/250	28 3/4	25 3/4	5/8
220/225	26 3/4	23 3/4	5/8
210	25 1/4	22 1/4	5/8
195	23 1/2	20 1/2	5/8
180	21 3/4	18 3/4	5/8
165	20 1/4	17 1/4	5/8
150	18 1/2	15 1/2	5/8
135	17	14	5/8
120	15 1/2	12 1/2	5/8
60-100	13 1/2	10 1/2	5/8
UNIT	A	B	C
SIZE	DIM	DIM	DIM

NOTES:
INLET GUARD REQUIRED WHEN FAN INLET IS
EXPOSED TO OUTDOOR CONDITIONS.

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control




MAT'L		ASTM A1011			LOREN COOK CO.		
DRAWN		BFS	5/22/13		MANUFACTURERS OF AIR MOVING EQUIPMENT		
DESIGNER		BFS	SHEET 12 OF 14		SPRINGFIELD, MISSOURI		
DO NOT SCALE DRAWING					CP INLET GUARD CPV/CPS/CPF HURRICANE RATED		
TOLERANCES UNLESS OTHERWISE NOTED							
<u>DECIMAL</u>		<u>FRACTIONAL</u>					
.XX=±.063"		≤12"=±1/16"			SIZE	DRAWING NO.	REV.
.XXX=±.010"		>12" THRU 96"=±1/8"					
.XXXX=±.001"		>96" THRU 144"=±1/4"			B	SD130522-18	D
.XXXX=±.001"		>144"=±3/8"					
<u>ANGULAR</u>		(NC)=NO INSPECTION REQ'D					
±2'							




SIZE	A	B	H	K	L	M	CHANNEL
60-100	21-3/4	29-11/16	7/16	7/8	7/8	9/16	C3x4.1
120	26-1/8	31-5/16	7/16	7/8	7/8	9/16	C3x4.1
135	29-3/8	34-7/16	7/16	7/8	7/8	9/16	C3x4.1
150	32-5/8	35-9/16	7/16	7/8	7/8	9/16	C3x4.1
165	35-7/8	36-3/4	7/16	7/8	7/8	9/16	C3x4.1
180	39-1/8	37-15/16	7/16	7/8	7/8	9/16	C3x4.1
195	42-3/8	42-1/8	7/16	7/8	31/32	9/16	C4x5.4
210	45-5/8	44-1/4	9/16	7/8	31/32	9/16	C4x5.4
225	48-7/8	45-7/16	9/16	7/8	31/32	9/16	C4x5.4
245	53-1/4	47-7/16	9/16	7/8	31/32	9/16	C4x5.4
270	58-1/2	52-5/16	9/16	7/8	1	9/16	C5x6.7
300	65-1/4	55-5/16	9/16	7/8	1	9/16	C5x6.7
330	71-3/4	57-1/16	11/16	7/8	1	9/16	C5x6.7
365	79-3/8	63-5/8	11/16	7/8	1-1/8	9/16	C6x10.5
402	87-5/8	67-15/16	13/16	1-1/8	1-1/8	3/4	C6x10.5
445	97	75-3/16	13/16	1-1/8	1-1/8	3/4	C6x10.5
490	106-5/8	79	13/16	1-1/8	1-3/8	3/4	C8x11.5

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control




MAT'L		ASTM A36			LOREN COOK CO.	
DRAWN		BFS	5/22/13		MANUFACTURERS OF AIR MOVING EQUIPMENT	
DESIGNER		BFS	SHEET 13 OF 14		SPRINGFIELD, MISSOURI	
DO NOT SCALE DRAWING						
TOLERANCES UNLESS OTHERWISE NOTED						
<u>DECIMAL</u>		<u>FRACTIONAL</u>				
.XX=±.063"		≤12"=±1/16"				
.XXX=±.010"		>12" THRU 96"=±1/8"				
.XXXX=±.001"		>96" THRU 144"=±1/4"				
<u>ANGULAR</u>		>144"=±3/8"				
±2"		(NC)=NO INSPECTION REQ'D				
CP RAILS AND BASE CPV/CPS/CPF HURRICANE RATED						
SIZE		DRAWING NO.			REV.	
B		SD130522-18			D	






"F" STRUCTURAL CHANNEL

"E" STRUCTURAL CHANNEL (60-245)
"E" STRUCTURAL BEAM (270-490)





SIZE	A	B	C	D	E	F
60-100	42-3/8	36-7/8	3	11/16	(2) C3x4.1	C3x4.1
120	44	38-1/2	3	11/16	(2) C3x4.1	C3x4.1
135	47-1/8	41-5/8	3	11/16	(2) C3x4.1	C3x4.1
150	48-1/4	42-3/4	3	11/16	(2) C3x4.1	C3x4.1
165	49-1/2	44	3	11/16	(2) C3x4.1	C3x4.1
180	50-9/16	45-1/16	3	11/16	(2) C3x4.1	C3x4.1
195	54-3/4	49-1/4	3	11/16	(2) C3x4.1	C3x4.1
210	56-7/8	51-3/8	3	11/16	(2) C3x4.1	C3x4.1
225	58	52-1/2	3	11/16	(2) C3x4.1	C3x4.1
245	60-1/16	54-9/16	3	11/16	(2) C3x4.1	C3x4.1
270	65	59-1/2	4	11/16	W6x9	C4x5.4
300	67-7/16	61-15/16	4	11/16	W6x9	C4x5.4
330	69-3/4	64-1/4	4	11/16	W6x9	C4x5.4
365	76-3/8	70-7/8	4	11/16	W6x9	C4x5.4
402	80-1/4	74-3/4	4	11/16	W6x9	C4x5.4
445	87-1/2	82	4	11/16	W6x9	C4x5.4
490	90-15/16	85-7/16	4	11/16	W6x9	C4x5.4



PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0821.06
Expiration Date 12/19/2024
By *[Signature]*
Miami-Dade Product Control

JERRY TRAVIS MILLER- ENGINEER
FLORIDA LICENSE #89925
FLORIDA STATE CERTIFICATE
OF AUTHORITY #RY34386



MAT'L		ASTM A36			®	LOREN COOK CO.		MANUFACTURERS OF AIR MOVING EQUIPMENT SPRINGFIELD, MISSOURI
DRAWN		BFS	5/22/13					
DESIGNER		BFS	SHEET 14 OF 14					
DO NOT SCALE DRAWING								
TOLERANCES UNLESS OTHERWISE NOTED								
<u>DECIMAL</u>		<u>FRACTIONAL</u>						
.XX=±.063"		≤12"=±1/16"						
.XXX=±.010"		>12" THRU 96"=±1/8"						
.XXXX=±.001"		>96" THRU 144"=±1/4"						
<u>ANGULAR</u>		>144"=±3/8"						
±2'		(NC)=NO INSPECTION REQ'D						
CP ISOLATION RAILS CPV/CPS/CPF HURRICANE RATED								
SIZE		DRAWING NO.					REV.	
B		SD130522-18					D	