



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

K P Building Products Inc.
402 Boyer Street
Williston, VT 05495

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Traditional and Dutch Lap Vinyl (PVC) Siding

APPROVAL DOCUMENT: Drawing No. **KBP0003**, titled "Traditional and Dutch Lap Vinyl (PVC) Siding", sheets 1 through 8 of 8, dated 09/27/2010, with revision **F** dated 06/14/2023, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E., bearing the Miami-Dade County Product Control revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each piece shall bear a permanent label marked at not more than 4 ft. (1.2m) o.c. with the manufacturer's name or logo, Acton, Ontario, Canada or Holly Springs, MS, and following statement: "Miami-Dade County Product Control Approved" or "MDCPCA", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises NOA # 21-1208.03** and consists of this page 1 and evidence pages E-1, E-2, E-3 and E-4, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



NOA No. 23-0915.02
Expiration Date: December 7, 2025
Approval Date: November 2, 2023
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS NOA's

A. DRAWINGS “Submitted under NOA # 14-1112.08”

1. Drawing No. **KPBP0003**, titled “Traditional and Dutch Lap Vinyl (PVC) Siding”, sheets 1 through 6 of 6, dated 09/27/2010, with revision **B** dated 10/29/2014, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E.

B. TESTS “Submitted under NOA # 10-1012.06”

	Test Report No.	Standard	Date	Signature
1.	98582.01-109-18	TAS 202 and 203	06/14/10	Michael D. Stremmel, P.E.
2.	98583.01-109-18	TAS 202 and 203	06/15/10	Michael D. Stremmel, P.E.
3.	98587.01-109-18	TAS 202 and 203	05/10/10	Michael D. Stremmel, P.E.
4.	98627.01-109-18	TAS 202 and 203	05/25/10	Michael D. Stremmel, P.E.
5.	98628.01-109-18	TAS 202 and 203	06/15/10	Michael D. Stremmel, P.E.
6.	94119.02-106-18	ASTM D3679, D4226, D696, D2457, D2244, D1929, D2843 and D635	06/01/10	Joseph A. Reed, P.E.

“Submitted under NOA # 00-0912.02”

7. RAD 2132 ASTM G26 & D638 12/1998 R. F. Tucker, P.E.

C. CALCULATIONS “Submitted under NOA # 10-1012.06”

1. Anchor verification calculations, complying with FBC-2007, prepared by PTC, LLC, dated 09/24/2010, signed and sealed by Robert J. Amoruso, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS “Submitted under NOA # 14-1112.08”

1. Statement letter of code conformance with the 5th edition FBC and of no financial interest, dated 10/31/2014, signed and sealed by Robert J. Amoruso, P.E.

“Submitted under NOA # 12-0125.03”

2. Statement letter of code conformance to 2010 FBC and no financial interest, dated 01/10/2012, signed and sealed by Robert J. Amoruso, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0915.02
Expiration Date: December 7, 2025
Approval Date: November 2, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

2. EVIDENCE SUBMITTED UNDER NOA # 17-1221.34

A. DRAWINGS

1. Drawing No. **KPBP0003**, titled “Traditional and Dutch Lap Vinyl (PVC) Siding”, sheets 1 through 6 of 6, dated 09/27/2010, with revision **C** dated 12/01/2017, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of code conformance to 6th edition (2017) FBC and of no financial interest, prepared by PTC Product Design Group, LLC, dated 12/01/2017, signed and sealed by Robert J. Amoruso, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0915.02
Expiration Date: December 7, 2025
Approval Date: November 2, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

3. EVIDENCE SUBMITTED UNDER NOA # 20-1130.03

A. DRAWINGS

1. Drawing No. **KPBP0003**, titled “Traditional and Dutch Lap Vinyl (PVC) Siding”, sheets 1 through 6 of 6, dated 09/27/2010, with revision **D** dated 11/18/2020, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of code conformance to 7th edition (2020) FBC and of no financial interest, prepared by PTC Product Design Group, LLC, dated 11/18/2020, signed and sealed by Robert J. Amoruso, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0915.02
Expiration Date: December 7, 2025
Approval Date: November 2, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

4. EVIDENCE SUBMITTED UNDER NOA # 21-1208.03 AND NEW

A. DRAWINGS

1. Drawing No. **KPBP0003**, titled “Traditional and Dutch Lap Vinyl (PVC) Siding”, sheets 1 through 6 of 6, dated 09/27/2010, with revision **F** dated 06/14/2023, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E.

B. TESTS

1. Test reports on 1) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
2) Cyclic Wind Pressure Loading per FBC, TAS 203-94
along with marked-up drawings and installation diagram of Dakota PLUS D5D Vinyl Siding, by Molimo Architectural Product Testing, Report No. **2764.01-106-11**, dated 03/01/2021, signed and sealed by Michael D. Stremmel, P.E.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of code conformance to the 8th edition (2023) of the FBC and of no financial interest, issued by PTC Product Design Group, LLC, dated 06/14/2023, signed and sealed by Robert J. Amoruso, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0915.02
Expiration Date: December 7, 2025
Approval Date: November 2, 2023

KP BUILDING PRODUCTS

TRADITIONAL & DUTCH LAP VINYL (PVC) SIDING

INSTALLATION ANCHORAGE DETAILS

GENERAL NOTES:

1. THIS PRODUCT HAS BEEN TESTED AND DESIGNED TO COMPLY WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE (FBC) INCLUDING THOSE SECTIONS OF THE FBC PERTAINING TO THE HIGH VELOCITY HURRICANE ZONE (HVHZ) AT THE DESIGN PRESSURE(S) STATED HEREIN. THE PRODUCT WAS TESTED TO TAS-202 AND TAS-203. IMPACT TESTING TO TAS-201 IS NOT REQUIRED FOR SIDING INSTALLED OVER CBS CONSTRUCTION OR 5/8" PLYWOOD SUPPORTED BY 2X OR 18 GA. STUDS.
2. THE PRODUCT DETAILS CONTAINED HEREIN ARE BASED UPON SIGNED AND SEALED ARCHITECTURAL TESTING REPORT ATI #98582.01-109-18 (CEDAR CREEK D4), ATI #98583.01-109-18 (CEDAR CREEK D4D), ATI #98627.01-109-18 (CEDAR CREEK D5), ATI #98628.01-109-18 (CEDAR CREEK D5D) AND 2764.01-106-11 (DAKOTA PLUS D5D) INCLUDING ASSOCIATED LABORATORY STAMPED DRAWINGS. DESIGN PRESSURE BASED ON [2 X TEST PRESSURE]/1.5.
3. ADEQUACY OF THE EXISTING STRUCTURAL CONCRETE, MASONRY AND WOOD FRAMING COMPRISING THE ATTACHMENT SUBSTRATE FOR THE SIDING SHALL BE DETERMINED TO BE CAPABLE OF WITHSTANDING AND TRANSFERRING APPLIED PRODUCT LOADS TO THAT STRUCTURE AND IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD FOR THE PROJECT.
4. SUBSTRATES RECEIVING VINYL SIDING SHALL BE CHECKED FOR STRUCTURAL INADEQUACY. CRACKS OR DEFECTS THAT SHALL BE ELIMINATED.
5. INSTALLATION OF SIDING ACCESSORIES AND ACCESSORIES SUCH AS CORNER POSTS, STARTER STRIPS, AND TRIM AROUND OPENINGS SHALL BE DONE IN ACCORDANCE WITH THE CURRENT EDITION OF THE FLORIDA BUIDLING CODE AND THE MANUFACTURER'S INSTRUCTIONS.
6. SITE CONDITIONS THAT DEVIATE FROM THE DETAILS OF THIS DRAWING REQUIRE FURTHER ENGINEERING EVALUATION BY A LICENSED PROFESSIONAL ENGINEER OR REGISTERED ARCHITECT.
7. WALLS WHERE VINYL SIDING SHALL BE INSTALLED MUST BE DESIGNED BY A LICENSED PROFESSIONAL ENGINEER, ARCHITECT OR OTHER DESIGN PROFESSIONAL AS ALLOWED BY AND IN ACCORDANCE WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE.
8. WALLS WHERE VINYL SIDING SHALL BE INSTALLED MUST HAVE A WATER-RESISTIVE BARRIER BEHIND THE EXTERIOR WALL SIDING EQUIVALENT TO A 15 POUND FELT OR OTHER RESISTIVE BARRIER AS SPECIFIED IN THE CURRENT EDITION OF THE FLORIDA BUILDING CODE.
9. IF THE VINYL SIDING IS INSTALLED OVER FOAM PLASTIC SHEATHING, THE REQUIREMENTS RELATED TO DESIGN WIND PRESSURE RATING IN THE CURRENT EDITION OF THE FLORIDA BUILDING MUST BE FOLLOWED.

INSTALLATION NOTES:

1. ANCHORS SHALL BE THE TYPE, SIZE, EMBEDMENT AND EDGE DISTANCE SHOWN HEREIN FOR RESPECTIVE SUBSTRATE.
2. INSTALLATION ANCHORS SHALL BE AS SHOWN ON SHEETS 4, 5 AND 6.
3. MINIMUM EMBEDMENT AND EDGE DISTANCE EXCLUDE WALL FINISHES (INCLUDING BUT NOT LIMITED TO STUCCO, FOAM, BRICK VENEER AND SIDING).
4. FOR CONCRETE BLOCK, DO NOT INSTALL INSTALLATION ANCHORS INTO MORTAR JOINTS. EDGE DISTANCE IS MEASURED FROM FREE EDGE OF BLOCK OR EDGE OF MORTAR JOINT INTO FACE SHELL OF BLOCK.
5. ALL FASTENERS SHALL HAVE CORROSION RESISTANT COATINGS OR BE MADE OF CORROSION RESISTANT MATERIALS COMPATIBLE WITH THE SUBSTRATE MATERIALS.

VINYL SIDING SPECIFICATIONS:

1. KP BUILDING PRODUCTS VINYL SIDING IS MANUFACTURED FROM A FORMULATED PVC POWDER COMPOUND MEETING THE SPECIFICATIONS OF ASTM D3679.
2. WALL THICKNESS:
- 2.1. D4, D4D, D5 & D5D: MINIMUM 0.040"
- 2.2. D5D DAKOTA PLUS: NOMINAL 0.046"
- 2.3. STARTER STRIP (BASE): NOMINAL 0.046"
- 2.4. UTILITY (UNDERSILL) TRIM: NOMINAL 0.042"
3. SIDING PANEL LENGTHS:
- 3.1. D4 AND D5 ARE 12' - 0" LONG
- 3.2. D4D AND D5D ARE 12' - 6" LONG
- 3.3. D5D DAKOTA PLUS IS 12' LONG

TABLE OF CONTENTS

SHEET NO.	DESCRIPTION
1	GENERAL NOTES AND DESIGN PRESSURE CHART
2	APPROVED SIDING PROFILES – ISOMETRICS NO. 1
3	APPROVED SIDING PROFILES – ISOMETRICS NO. 2
4	APPROVED SIDING PROFILES – SECTIONS
5	TYPICAL ANCHORING DETAILS – SECTIONS
6	TYPICAL ANCHORING DETAILS – ISOMETRIC
7	BOM AND UTILITY TRIM INSTALLATION DETAIL
8	STARTER STRIP AND UTILITY TRIM

DESIGN PRESSURE (PSF) RATING

SIDING MODEL	DESIGN PRESSURE (PSF) RATING WHEN INSTALLED OVER AN IMPACTED RESISTANT SUBSTRATE. WHERE WATER INFILTRATION REQUIREMENT IS NEEDED. SEE GENERAL NOTE 9.
DOUBLE 4 TRADITIONAL LAP (D4)	–44 psf
DOUBLE 4 DUTCH LAP (D4D)	–56 psf
DOUBLE 5 TRADITIONAL LAP (D5)	–53.3 psf
DOUBLE 5 DUTCH LAP (D5D)	–58.7 psf
DOUBLE 5 DUTCH LAP (D5D) DAKOTA PLUS	–80 psf

PROJECT #422-0911

UPDATE TO 8th EDITION (2023) FLORIDA BUILDING CODE	RJA
6/14/23	RJA
UPDATE FOR NEW PROFILES AND TESTING	RJA
11/29/21	RJA
UPDATE TO 7th EDITION (2020) FLORIDA BUILDING CODE	RJA
11/18/20	RJA
DESCRIPTION	DATE
REV	BY

KP BUILDING PRODUCTS, INC.

34 BLAIR PARK RD, SUITE 104, PMB 318
WILLISTON, VT 05495

TITLE: TRADITIONAL AND DUTCH LAP VINYL (PVC) SIDING
GENERAL NOTES, B.O.M. AND D.P. CHART

DATE: 09/27/10

DRAWING NO: KPBP0003

SHEET: 1 OF 8

DRAWN BY: RJA

SCALE: N.T.S.

REV: F




PTC, LLC
P.O. Box 520775
Longwood, FL 32752-0775
Phone: 321.690.1788
Fax: 321.690.1789
Email: info@kpc-corp.com
FBPE Cert. of Auth. No. 25835

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0915.02


Expiration Date 12/07/2025

By Miami-Dade Product Control


Robert J. Amoruso, P.E.
Florida P.E. No. 49752




APPROVED SIDING 3D PROFILE DIMENSIONS




DOUBLE 4 TRADITIONAL LAP (D4)



DOUBLE 4 DUTCH LAP (D4D)


PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0915.02
Expiration Date 12/07/2025
By 
Miami-Dade Product Control

Robert J. Amoruso, P.E.
Florida P.E. No. 49752




PROJECT #422-0911			
F	UPDATE TO 8th EDITION (2023) FLORIDA BUILDING CODE	6/14/23	RJA
	UPDATE FOR NEW PROFILES AND TESTING	11/29/21	RJA
	UPDATE TO 7th EDITION (2020) FLORIDA BUILDING CODE	11/18/20	RJA
REV	DESCRIPTION	DATE	BY


APPROVED SIDING 3D PROFILE DIMENSIONS




DOUBLE 5 TRADITIONAL LAP (D5)




DOUBLE 5 DUTCH LAP (D5D)




DOUBLE 5 DUTCH LAP (D5D) DAKOTA PLUS


PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0915.02
Expiration Date 12/07/2025
By 
Miami-Dade Product Control

Robert J. Amoruso, P.E.
Florida P.E. No. 49752




KP BUILDING PRODUCTS, INC.					
34 BLAIR PARK RD, SUITE 104; PMB 318 WILLISTON, VT 05495					
TITLE:	TRADITIONAL AND DUTCH LAP VINYL (PVC) SIDING APPROVED SIDING PROFILES - ISOMETRICS NO. 1				
PREPARED BY:		DRAWN BY:	RJA	DATE:	09/27/10
		SCALE:	N.T.S.	DRAWING NO:	KBP0003
		REV:	F	SHEET:	3 OF 8
PTC, LLC P.O. Box 520775 Longwood, FL 32752-0775 Phone: 321.690.1788 Fax: 321.690.1789 Email: info@ptc-corp.com					


APPROVED SIDING SECTIONAL PROFILE DIMENSIONS




DOUBLE 4 TRADITIONAL LAP (D4)




DOUBLE 4 DUTCH LAP (D4D)



DOUBLE 5 TRADITIONAL LAP (D5)



DOUBLE 5 DUTCH LAP (D5D)



DOUBLE 5 DUTCH LAP (D5D) DAKOTA PLUS


PROJECT #422-0911

REV	DESCRIPTION	DATE	BY
F	UPDATE TO 8th EDITION (2023) FLORIDA BUILDING CODE	6/14/23	RJA
E	UPDATE FOR NEW PROFILES AND TESTING	11/29/21	RJA
D	UPDATE TO 7th EDITION (2020) FLORIDA BUILDING CODE	11/18/20	RJA

KP BUILDING PRODUCTS, INC.
34 BLAIR PARK RD, SUITE 104, PMB 318
WILLISTON, VT 05495

TITLE: TRADITIONAL AND DUTCH LAP VINYL (PVC) SIDING
APPROVED SIDING PROFILES - SECTIONS

DATE:	09/27/10
DRAWING NO:	KPBP0003
SCALE:	N.T.S.
REV:	F
SHEET:	4 OF 8





PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0915.02

Expiration Date 12/07/2025


By 
Miami-Dade Product Control

Robert J. Amoruso, P.E.
Florida P.E. No. 49752






TYPICAL ANCHORING DETAIL APPLICABLE TO ALL PROFILES



DETAIL "A" LOCK & FASTENING DETAIL



SEE SHEET 6 FOR ISOMETRIC
ILLUSTRATION OF SIDING
PANEL ANCHOR SPACING

PROJECT #422-0911

REV	DESCRIPTION	DATE	BY
F	UPDATE TO 8th EDITION (2023) FLORIDA BUILDING CODE	6/14/23	RJA
E	UPDATE FOR NEW PROFILES AND TESTING	11/29/21	RJA
D	UPDATE TO 7th EDITION (2020) FLORIDA BUILDING CODE	11/18/20	RJA

KP BUILDING PRODUCTS, INC.
34 BLAIR PARK RD, SUITE 104, PMB 318
WILLISTON, VT 05495

TITLE: TRADITIONAL AND DUTCH LAP VINYL (PVC) SIDING
TYPICAL ANCHORING DETAILS - SECTIONS


DATE:	09/27/10
DRAWN BY:	RJA
SCALE:	N.T.S.
REV:	F
DRAWING NO.:	KBP0003
SHEET:	5 OF 8

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0915.02

Expiration Date 12/07/2025


By *[Signature]*
Miami-Dade Product Control

Robert J. Amoruso, P.E.
Florida P.E. No. 49752



TYPICAL ANCHORING DETAIL
APPLICABLE TO ALL PROFILES

SEE SHEET 5 FOR SECTIONAL VIEWS
OF CONCRETE, MASONRY (CBS)
AND WOOD FRAME SUBSTRATE
INSTALLATION



* FASTENERS SPACING 8" ON
CENTER. EVERY OTHER
FASTENER (16" ON CENTER)
THROUGH SHEATHING INTO 2X
WOOD STUDS


PROJECT #422-0911

REV	DESCRIPTION	DATE	BY
F	UPDATE TO 8th EDITION (2023) FLORIDA BUILDING CODE	6/14/23	RJA
E	UPDATE FOR NEW PROFILES AND TESTING	11/29/21	RJA
D	UPDATE TO 7th EDITION (2020) FLORIDA BUILDING CODE	11/18/20	RJA

KP BUILDING PRODUCTS, INC.
34 BLAIR PARK RD, SUITE 104, PMB 318
WILLISTON, VT 05495

TITLE: TRADITIONAL AND DUTCH LAP VINYL (PVC) SIDING
TYPICAL ANCHORING DETAILS - ISOMETRIC

DATE:	09/27/10
DRAWING NO:	KPBP0003
SCALE:	N.T.S.
REV:	F
SHEET:	6 OF 8




PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0915.02

Expiration Date 12/07/2025


By 
Miami-Dade Product Control

Robert J. Amoruso, P.E.
Florida P.E. No. 49752



BILL OF MATERIALS

ITEM	DESCRIPTION	MATERIAL
1	KP BUILDING PRODUCTS VINYL (PVC) SIDING:	VINYL (PVC)
	DOUBLE 4 TRADITIONAL LAP (D4)	
	DOUBLE 4 DUTCH LAP (D4D)	
	DOUBLE 5 TRADITIONAL LAP (D5)	
	DOUBLE 5 DUTCH LAP (D5D)	
	DOUBLE 5 DUTCH LAP (D5D) DAKOTA PLUS	
2	0.12" (1/8") SHANK DIAMETER X 1-1/2" LONG RING SHANK ROOFING NAIL WITH 7/16" DIA. HEAD USED ON STUD WALL WITH 5/8" PLYWOOD.	STEEL
3	3/4" OUTSIDE DIA. X 1/4" INSIDE DIA. X 0.071" THK. NYLON WASHER	NYLON
4	0.12" (1/8") SHANK DIAMETER X 3/4" LONG SMOOTH OR RING SHANK ROOFING NAIL WITH 7/16" DIA. HEAD USED ON CONCRETE OR CBS WALL WITH FURRING STRIP.	STEEL
5	3/16" ITW ATT TAPCON OF SUFFICIENT LENGTH TO ACHIEVE A MINIMUM OF 1-1/2" EMBEDMENT & 1-1/2" EDGE DISTANCE IN CONCRETE OR 1" EMBEDMENT & 2" EDGE DISTANCE IN MASONRY (CBS) SUBSTRATE.	STEEL
6	STARTER STRIP	VINYL (PVC)
7	UTILITY TRIM	VINYL (PVC)



UTILITY TRIM INSTALLATION DETAIL PER 2023 FBC, SECTION 1405.14.2.2 AND 2023 FRC, SECTION R703.11.1.5. (ILLUSTRATION FROM 2023 FRC, SECTION R703.11.1.5)

UTILITY TRIM (ITEM NO. 7) SHALL BE ATTACHED USING 0.12" DIAMETER ROOFING NAIL (BOM ITEM NO. 2 OR 4) 8" O.C. SPACING. FASTENER SPACING SHALL BE THE SAME AS SHOWN ON SHEET 6 ISOMETRIC DETAIL FOR SIDING NAIL HEM.

FOR ADDITIONAL DETAILS, SEE KP VINYL SIDING ESTIMATING & INSTALLATION GUIDE, KP-EIG21A (101-7383) OR LATER EDITIONS.


PROJECT #422-0911		RJA	RJA	RJA	BY
UPDATE TO 8th EDITION (2023) FLORIDA BUILDING CODE		6/14/23	11/29/21	11/18/20	DATE
F		E	D	REV	
UPDATE FOR NEW PROFILES AND TESTING		UPDATE TO 7th EDITION (2020) FLORIDA BUILDING CODE		DESCRIPTION	

KP BUILDING PRODUCTS, INC. 34 BLAIR PARK RD, SUITE 104, PMB 318 WILLISTON, VT 05495		DATE: 09/27/10		DRAWING NO: KPBP0003		SHEET: 7 OF 8	
TITLE: TRADITIONAL AND DUTCH LAP VINYL (PVC) SIDING BOM AND UTILITY TRIM INSTALLATION DETAIL		DRAWN BY: RJA		SCALE: N.T.S.		REV: F	
PREPARED BY: PTC, LLC P.O. Box 520775 Longwood, FL 32752-0775 Phone: 321.690.1788 Fax: 321.690.1789 Email: info@ptc-corp.com		DATE: 09/27/10		DRAWING NO: KPBP0003		SHEET: 7 OF 8	


PRODUCT REVISED as complying with the Florida Building Code
NOA-No. 23-0915.02

Expiration Date 12/07/2025


By Robert J. Amoruso, P.E.
Miami-Dade Product Control




STARTER STRIP
VINYL




1 : 1



2 : 1



UTILITY TRIM
VINYL



PROJECT #422-0911			
UPDATE TO 8th EDITION (2023) FLORIDA BUILDING CODE	6/14/23	RJA	BY
F			
UPDATE FOR NEW PROFILES AND TESTING	11/29/21	RJA	DATE
E			
UPDATE TO 7th EDITION (2020) FLORIDA BUILDING CODE	11/18/20	RJA	DESCRIPTION
D			
REV	DATE	DESCRIPTION	
REV			

KP BUILDING PRODUCTS, INC. 34 BLAIR PARK RD, SUITE 104, PMB 318 WILLISTON, VT 05495			
TITLE: TRADITIONAL AND DUTCH LAP VINYL (PVC) SIDING STARTER STRIP AND UTILITY TRIM			
DATE: 09/27/10	DRAWN BY: RJA	SCALE: N.T.S.	SHEET: 8 OF 8
DRAWING NO: KPBP0003	REV: F		
PREPARED BY:			
PTC, LLC P.O. Box 520775 Longwood, FL 32752-0775 Phone: 321.690.1788 Fax: 321.690.1789 Email: info@ptc-corp.com			

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0915.02
Expiration Date 12/07/2025
By
Miami-Dade Product Control

Robert J. Amoruso, P.E.
Florida P.E. No. 49752

