



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Chem Link, Inc.
392 E. Lyon Street
Schoolcraft, MI 49087

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Chem Link Roofing Component Accessories

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.

03/20/25



NOA No.: 23-1011.15
Expiration Date: 03/20/30
Approval Date: 03/20/25
Page 1 of 3

ROOFING COMPONENT APPROVAL

<u>Category:</u>	Roofing
<u>Sub-Category:</u>	Roofing Membrane and Accessories
<u>Material:</u>	See components herein

SCOPE:

This approves **Chem Link Roofing Component Accessories** as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricanes Zone. Please refer to “Limitations” herein for limits of use.

PENETRATION SEAL KITS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
E-Curb Penetration Seal System <i>Manufacturing location #1, 3</i>	Various	ASTM G155	Kit for installing precast Nylon resin roof penetration
ChemCurb 1-Part Penetration Seal System <i>Manufacturing location #1, 2</i>	Various	ASTM G155	Kit for installing precast polyester resin roof penetration

ADHESIVES AND SEALANTS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
M-1 Adhesive <i>Manufacturing location #1</i>	10.1 oz. cartridge	ASTM C920	Moisture curing, multi-purpose structural adhesive/sealant
1-Part Portable Penetration Sealant <i>Manufacturing location #1</i>	10.1 oz. cartridge	ASTM C920	Moisture curing, pourable sealant designed for use in pitch pans and penetration seals
Durasil <i>Manufacturing location #1</i>	10.1 oz. cartridge	ASTM C920	Neutral cure silicone construction sealant
Durasil SL <i>Manufacturing location #1</i>	2 and 5 gallon pails	ASTM C920	Neutral cure self-levelling silicone sealant
Duralink 50 <i>Manufacturing location #1</i>	10.1 oz. cartridge	ASTM C920	Elastic moisture curing sealant designed for use in cementitious siding, metal architecture, curtain wall construction and joints subject to movement.

MANUFACTURING LOCATION:

1. Schoolcraft, MI
2. Kalamazoo, MI
3. Marcellus, MI

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
NEMO ETC LLC	4p-CHMLK-22-SSLAP-01.A	ASTM G155	2023-07-05
	4p-CHMLK-22-SSLAP-01.B	ASTM C920	2023-11-15
	4p-CHMLK-22-SSLAP-01.C	ASTM C920	2023-08-30



NOA No.: 23-1011.15
Expiration Date: 03/20/30
Approval Date: 03/20/25
Page 2 of 3

LABELING:

All membranes and accessories or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance. If a product is not listed as part of roof assemblies Notice of Acceptance, a request may be made to the local building official or the Miami Dade County Product Control Section for approval provided that appropriate documentation is provided.
3. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance
4. Products shall be applied in accordance with manufacturer's published application instructions.
5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to the Miami Dade Product Control upon request.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code
7. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below

END OF THIS ACCEPTANCE

