



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

Greenheck Fan Corporation
P.O. Box 410
Schofield, WI 54476

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Model ESD-635D Aluminum Louver with and without VCD-40 Damper

APPROVAL DOCUMENT: Drawing No. **ESD-635D**, titled "ESD-635D Louver", sheets 1 through 22 of 22, dated 08/09/2017, prepared by Greenheck Fan Corporation, signed and sealed by Wayne K. Helmila, P.E., bearing the Miami-Dade County Product Control renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, Schofield, WI or Shelby, NC, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA # 22-0816.09** and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



12/11/23

NOA No. 23-1013.08
Expiration Date: December 6, 2024
Approval Date: November 22, 2023
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS NOAs

A. DRAWINGS “Submitted under NOA # 10-0921.09”

1. Drawing No. **ESD-635D**, titled “ESD-635D Louver”, sheets 1 through 22 of 22, dated 08/25/2010, prepared by Greenheck Fan Corporation, signed and sealed by L. David Rice, P.E.

B. TESTS

“Submitted under NOA # 07-1015.06”

1. Test reports on 1) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
2) Large Missile Impact Test per FBC, TAS 201-94
3) Cyclic Wind Pressure Loading per FBC, TAS 203-94
along with marked-up drawings and installation diagram of Series/Model ESD-635D, fixed aluminum louvers, prepared by Architectural Testing, Inc., Test Report No. **74297.01-602-18**, dated 09/25/2007, signed and sealed by Joseph A. Reed, P.E.
2. Test report on Standard Test Methods for Tensile Testing of Metallic Materials, per ASTM E8-03, prepared by Architectural Testing, Inc., Test Report No. **74297.02-602-18**, dated 10/01/2007, signed and sealed by Joseph A. Reed, P.E.

C. CALCULATIONS “Submitted under NOA # 10-0921.09”

1. Structural calculations, prepared by Rice Engineering, dated 09/03/2010, signed and sealed by L. David Rice, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS “Submitted under NOA # 16-0201.02”

1. Statement letter of code conformance to the 5th edition (2014) FBC issued by Rice Engineering, dated 01/11/2016, signed and sealed by L. David Rice, P.E.
“Submitted under NOA # 12-0830.07”
2. Statement letter of code conformance to 2010 FBC issued by Rice Engineering, dated 11/06/2012, signed and sealed by L. David Rice, P.E.
“Submitted under NOA # 10-0921.09”
3. Statement letters of conformance and no financial interest issued by Rice Engineering, dated 09/03/2010, signed and sealed by L. David Rice, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-1013.08
Expiration Date: December 6, 2024
Approval Date: November 22, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

2. EVIDENCE SUBMITTED UNDER NOA # 17-0919.04, # 22-0816.09 AND NEW

A. DRAWINGS

1. Drawing No. **ESD-635D**, titled “ESD-635D Louver”, sheets 1 through 22 of 22, dated 08/09/2017, prepared by Greenheck Fan Corporation, signed and sealed by Wayne K. Helmila, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS


1. None.

F. STATEMENTS

1. Statement letter of code conformance to the 7th Edition (2020) of the FBC, issued by Rice Engineering, dated 10/14/2021, signed and sealed by Wayne K. Helmila, P.E.
2. Testing contract email issued by Eric Jehn from Quast Consulting and Testing, Inc., and dated 08/11/2022.
3. Statement letter of code conformance to the 6th Edition (2017) FBC issued by Rice Engineering, dated 08/30/2017, signed and sealed by Wayne K. Helmila, P.E.
4. Statement letters of no financial interest issued by Rice Engineering, dated 08/30/2017, signed and sealed by Wayne K. Helmila, P.E.




Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-1013.08
Expiration Date: December 6, 2024
Approval Date: November 22, 2023



HORIZONTAL SECTION CUT

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 17-0919.04
Expiration Date 12/06/2022
By *[Signature]*
Miami-Dade Product Control



VERTICAL SECTION CUT

GREENHECK P.O. BOX 410 SCHUB JELD, WISCONSIN 54476-0410 WAYNE K. HELMILA LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER AUG 30 2017 RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092	DRAWN BY MES SCALE 1:24 SHEET NO. 1 OF 22 CAD DRAWING NO. ESD-635D	DATE 8/9/2017 TITLE ESD-635D LOUVER FLANGE FRAME SLEEVE MOUNT ELEVATION
	PRODUCT RENEWED as complying with the Florida Building Code NOA-No. 22-0816.09 Expiration Date 12/06/2023 By <i>[Signature]</i> Miami-Dade Product Control	

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08
Expiration Date 12/06/2024

By *[Signature]*
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09
Expiration Date 12/06/2023

By *[Signature]*
Miami-Dade Product Control

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04
Expiration Date 12/06/2022

By *[Signature]*
Miami-Dade Product Control

HORIZONTAL SECTION CUT

13
10/22

14
10/22

16
12/22

17
13/22

5
7/22

7
7/22

6
7/22


8
7/22

10
8/22

9
8/22

VERTICAL SECTION CUT

0.125 TYP.
TO 0.375




 P.O. BOX 410 SCHUFELD, WISCONSIN 54476-0410 TITLE ESD-635D LOUVER CONTINUOUS ANGLE MOUNT ELEVATION	DRAWN BY MES	DATE 8/9/2017
	SCALE 1:24	SHEET NO. 2 OF 22
CAD DRAWING NO. ESD-635D		

WAYNE K. HELMILA
LICENSE
No. 59092
STATE OF
FLORIDA
PROFESSIONAL ENGINEER

AUG 30 2017

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 817-1042
Fax: (920) 817-1100
www.rice-inc.com

Florida Firm No: F-01000305061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092



PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **22-0816.09**

Expiration Date **12/06/2023**


By *[Signature]*
Miami-Dade Product Control

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **17-0919.04**



Expiration Date **12/06/2022**

By *[Signature]*
Miami-Dade Product Control

HORIZONTAL SECTION CUT



DRAWN BY MES	DATE 8/9/2017	SCALE 1:24	SHEET NO. 4 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410				
TITLE ESD-635D LOUVER W/VCD-40 CONTINUOUS ANGLE MOUNT		ELEVATION		
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092				



PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **22-0816.09**
Expiration Date **12/06/2023**
By *[Signature]*
Miami-Dade Product Control

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **17-0919.04**
Expiration Date **12/06/2022**
By *[Signature]*
Miami-Dade Product Control


PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **23-1013.08**
Expiration Date **12/06/2024**
By *[Signature]*
Miami-Dade Product Control

DRAWN BY MES	DATE 8/9/2017	SCALE 1/2	SHEET NO. 5 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410		TITLE ESD-635D LOUVER FLANGE FRAME SLEEVE MOUNT HEAD & SILL DETAILS, HS144"		
<div style="display: flex; align-items: center;"> <div style="border: 1px solid black; border-radius: 50%; padding: 10px; text-align: center; margin-right: 10px;"> WAYNE K. HELMILA LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER </div> <div> RICE AUG 30 2017 ENGINEERING 105 School Creek Trail Luxemburg, WI 54117 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092 </div> </div>				

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08


Expiration Date 12/06/2024

By *[Signature]*
Miami-Dade Product Control



PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04
Expiration Date 12/06/2022
By *[Signature]*
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09
Expiration Date 12/06/2023
By *[Signature]*
Miami-Dade Product Control



DRAWN BY MES	DATE 8/9/2017	SHEET NO. 1/2	6 OF 22	CAD DRAWING NO. ESD-635D
	SCALE 1/2"			
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410				
ESD-635D LOUVER FLANGE FRAME SLEEVE MOUNT HEAD & SILL DETAILS, HS96"				
WAYNE K. HELMILA LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER AUG 30 2017				
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092				

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **22-0816.09**

Expiration Date **12/06/2023**

By *[Signature]*
Miami-Dade Product Control



MULLION DIRECT MOUNT (SHOWN HERE AT HEAD) IS FOR SUBSTRATES WHERE MINIMUM FASTENER EDGE DISTANCE CAN BE ACHIEVED BY USE OF HOLES IN THE MULLION END CAP. DETAIL IS TYPICAL FOR BOTH HEAD AND SILL CONDITIONS WHEN APPLICABLE.

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **23-1013.08**

Expiration Date **12/06/2024**

By *[Signature]*
Miami-Dade Product Control

MULLION DIRECT MOUNT (SHOWN HERE AT HEAD) IS FOR SUBSTRATES WHERE MINIMUM FASTENER EDGE DISTANCE CAN BE ACHIEVED BY USE OF HOLES IN THE MULLION END CAP. DETAIL IS TYPICAL FOR BOTH HEAD AND SILL CONDITIONS WHEN APPLICABLE.




DRAWN BY MES	DATE 8/9/2017	SHEET NO. 7 OF 22	CAD DRAWING NO. ESD-635D
SCALE			
GREENHECK P.O. BOX 410 SCHUFIELD, WISCONSIN 54476-0410		TITLE ESD-635D LOUVER CONTINUOUS ANGLE MOUNT HEAD & SILL DETAILS, HS144", HEAD & SILL DETAILS, HS96"	
LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER AUG 30 2017		RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092	

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08

Expiration Date 12/06/2024


By *[Signature]*
Miami-Dade Product Control

TYPICALLY, ONLY ONE BLADE BRACKET TYPE (ITEMS 13 & 43) IS USED ON THE ASSEMBLY. BOTH STYLES ARE SHOWN HERE TO SHOW DIFFERENCES.




BRACKET IS ATTACHED TO SUPPORT ANGLE IN TYPICAL STYLE AS SHOWN IN DETAIL 9.


BLADE/BRACKET IS ATTACHED TO THE BLADE SUPPORT ANGLE




BLADE/BRACKET IS ATTACHED TO THE BLADE SUPPORT ANGLE



TYPICALLY, ONLY ONE BLADE BRACKET TYPE (ITEMS 13 & 43) IS USED ON THE ASSEMBLY. BOTH STYLES ARE SHOWN HERE TO SHOW DIFFERENCES.



BLADE/BRACKET IS ATTACHED TO THE SILL ONLY.



PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04
Expiration Date 12/06/2022

By *[Signature]*
Miami-Dade Product Control

NOTE: THE BLADE SUPPORT ANGLE (ITEM 7A) IS NOT SHOWN IN THE BOTTOM THREE DETAILS IN ORDER TO IMPROVE DETAIL CLARITY. THE BLADE SUPPORT ANGLE IS NOT ATTACHED TO THE BLADE SUPPORT BRACKET (ITEM 13 OR 43) IN THE BOTTOM THREE DETAILS AS THE BRACKET IS ATTACHED TO THE SILL INSTEAD. BLADE SUPPORT BRACKET ITEM 43 CAN REPLACE BLADE SUPPORT BRACKET 13 (SHOWN) IN ANY OF THE DRAWINGS FOR DETAIL 10.

1/16" / 3/4"

BLADE/BRACKET IS ATTACHED TO THE SILL ONLY.

BRACKET CUT SHORT

NUBS REMOVED AS NEEDED

2.500 MIN DIM. ALLOWED FOR THIS SETUP

WELDS ARE ALLOWED TO BE REPLACED BY TYPICAL BLADE SUPPORT FASTENERS WHEN ROOM ALLOWS.

10
8/22

BOTTOM BLADE SUPPORT DETAIL
LOUVER HEIGHT ≤ 144 IN.

1/16" / 3/4"

BLADE/BRACKET IS ATTACHED TO THE SILL ONLY.

BRACKET CUT SHORT

NUBS AND/OR LEG REMOVED

1.750 MIN DIM. ALLOWED FOR THIS SETUP

WELDS ARE ALLOWED TO BE REPLACED BY TYPICAL BLADE SUPPORT FASTENERS WHEN ROOM ALLOWS.

10
8/22

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09
Expiration Date 12/06/2023

By *[Signature]*
Miami-Dade Product Control

DRAWN BY MES	DATE 8/9/2017	SCALE 1/2.5	SHEET NO. 8 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410 TITLE ESD-635D LOUVER BLADE SUPPORT DETAILS				
WAYNE K. HELMILA LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092				

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08


Expiration Date 12/06/2024

By *[Signature]*
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09

Expiration Date 12/06/2023


By *[Signature]*
Miami-Dade Product Control



11
9/22 JAMB DETAIL


PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04
Expiration Date 12/06/2022

By *[Signature]*
Miami-Dade Product Control





12A
9/22

SUPPORT DETAIL
LOUVER HEIGHT ≤ 144 IN.



12B
9/22

SUPPORT DETAIL
LOUVER HEIGHT ≤ 96 IN.

GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410 	DRAWN BY MES	DATE 8/9/2017
	SCALE 1/2	SHEET NO. 9 OF 22
TITLE ESD-635D LOUVER FLANGE FRAME SLEEVE MOUNT JAMB DETAILS		
		
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092		

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **22-0816.09**

Expiration Date **12/06/2023**


By *[Signature]*
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **23-1013.08**


Expiration Date **12/06/2024**

By *[Signature]*
Miami-Dade Product Control


SUBSTRATE LIMITED TO WOOD,
STEEL, CONCRETE AND MASONRY
(CMU) (BY OTHERS).



13
10/22
JAMB DETAIL
LOUVER HEIGHT ≤ 144 IN.



14A
10/22
SUPPORT DETAIL
LOUVER HEIGHT ≤ 144 IN.




14B
10/22
SUPPORT DETAIL
LOUVER HEIGHT ≤ 96 IN.

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **17-0919.04**

Expiration Date **12/06/2022**

By *[Signature]*
Miami-Dade Product Control

DRAWN BY MES	DATE 8/9/2017	SCALE 1/2	SHEET NO. 10 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410		ESD-635D LOUVER CONTINUOUS ANGLE MOUNT JAMB DETAILS		
TITLE 				
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092				




PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **22-0816.09**
Expiration Date **12/06/2023**
By *R. J. [Signature]*
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **23-1013.08**
Expiration Date **12/06/2024**
By *R. J. [Signature]*
Miami-Dade Product Control

ACTUAL LOUVER SECTION WIDTH — ACTUAL LOUVER SECTION WIDTH
— ACTUAL OVERALL LOUVER WIDTH —

15A
11/22
MULLION DETAIL
LOUVER HEIGHT ≤ 144 IN.




PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **17-0919.04**
Expiration Date **12/06/2022**
By *R. J. [Signature]*
Miami-Dade Product Control

15B
11/22
MULLION DETAIL
LOUVER HEIGHT ≤ 96 IN.

DRAWN BY MES	DATE 8/9/2017	SCALE 1/2	SHEET NO. 11 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410		TITLE ESD-635D LOUVER FLANGE FRAME SLEEVE MOUNT MULLION DETAILS		
WAYNE K. HELMILA LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER AUG 30 2017 RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092				

MULLION DIRECT MOUNT (SHOWN HERE AT HEAD) IS FOR SUBSTRATES WHERE MINIMUM FASTENER DISTANCE CAN BE ACHIEVED BY USE OF HOLES IN THE MULLION END CAP. DETAIL IS TYPICAL FOR BOTH HEAD AND SILL CONDITIONS WHEN APPLICABLE.




16A
12/22

MULLION DETAIL
LOUVER HEIGHT ≤ 144 IN.

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **22-0816.09**
Expiration Date **12/06/2023**
By *[Signature]*
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **23-1013.08**
Expiration Date **12/06/2024**

By *[Signature]*
Miami-Dade Product Control



16B
12/22


MULLION DETAIL
LOUVER HEIGHT ≤ 144 IN.

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **17-0919.04**
Expiration Date **12/06/2022**
By *[Signature]*
Miami-Dade Product Control

GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410 ESD-635D LOUVER CONTINUOUS ANGLE MOUNT MULLION DETAILS, HS144"	DRAWN BY MES	DATE 8/9/2017
	SCALE 1/2.5	SHEET NO. 12 OF 22
	CAD DRAWING NO. ESD-635D	

LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER AUG 30 2017	RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092
---	--

MULLION DIRECT MOUNT (SHOWN HERE AT HEAD) IS FOR SUBSTRATES WHERE MINIMUM FASTENER EDGE DISTANCE CAN BE ACHIEVED BY USE OF HOLES IN THE MULLION END CAP. DETAIL IS TYPICAL FOR BOTH HEAD AND SILL CONDITIONS WHEN APPLICABLE.



PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **22-0816.09**

Expiration Date **12/06/2023**

By *[Signature]*
Miami-Dade Product Control


PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **17-0919.04**

Expiration Date **12/06/2022**

By *[Signature]*
Miami-Dade Product Control

17A
13/22

MULLION DETAIL
LOUVER HEIGHT ≤ 96 IN.



MULLION ANGLE MOUNT (SHOWN HERE AT SILL) IS FOR SUBSTRATES WHERE MINIMUM FASTENER EDGE DISTANCE CANNOT BE ACHIEVED BY USE OF HOLES IN THE MULLION END CAP. DETAIL IS TYPICAL FOR BOTH HEAD AND SILL CONDITIONS WHEN APPLICABLE.

17B
13/22

MULLION DETAIL
LOUVER HEIGHT ≤ 96 IN.


PRODUCT RENEWED
as complying with the Florida
Building Code

NOA-No. **23-1013.08**

Expiration Date **12/06/2024**

By *[Signature]*
Miami-Dade Product Control


GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410 TITLE ESD-635D LOUVER CONTINUOUS ANGLE MOUNT MULLION DETAILS, H≤96"	DRAWN BY MES	DATE 8/9/2017	13 OF 22 CAD DRAWING NO. ESD-635D
	SCALE 1/2.5	SHEET NO.	
	WAYNE K. HELMILA LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER AUG 30 2017 RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092		




PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08
Expiration Date 12/06/2024
By [Signature]
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09
Expiration Date 12/06/2023
By [Signature]
Miami-Dade Product Control

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04
Expiration Date 12/06/2022
By [Signature]
Miami-Dade Product Control



DRAWN BY MES	DATE 8/9/2017	SHEET NO. 14 OF 22	CAD DRAWING NO. ESD-635D
	SCALE		
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410		TITLE ESD-635D LOUVER W/VCD-40 FLANGE FRAME W/SLEEVE MOUNT, & CONTINUOUS ANGLE MOUNT HEAD & SILL DETAILS	
LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER		AUG 30 2017 RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092	



22
15/22
ACTUATOR DETAIL
LOUVER HEIGHT ≤ 144 IN.

MANUAL QUADRANT ACTUATOR AS SHOWN
NOTE: DAMPER MAY BE OPERATED BY
MANUAL QUADRANT, AN ELECTRIC OR
PNEUMATIC ACTUATOR.

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08

Expiration Date 12/06/2024

By *[Signature]*
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09

Expiration Date 12/06/2023

By *[Signature]*
Miami-Dade Product Control

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04
Expiration Date 12/06/2022


By *[Signature]*
Miami-Dade Product Control

DRAWN BY MES	DATE 8/9/2017	SCALE 1:2	SHEET NO. 15 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410		TITLE VCD-40 DAMPER		
		MANUAL QUAD ACTUATOR		
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092		AUG 30 2017		


PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08

Expiration Date 12/06/2024


By *[Signature]*
Miami-Dade Product Control



23
16/22
JAMB DETAIL
LOUVER HEIGHT ≤ 144 IN.



24A
16/22
MULLION DETAIL
LOUVER HEIGHT ≤ 144 IN.



24B
16/22
MULLION DETAIL
LOUVER HEIGHT ≤ 96 IN.

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04

Expiration Date 12/06/2022

By *[Signature]*
Miami-Dade Product Control

DRAWN BY MES	DATE 8/9/2017	SHEET NO. 16 OF 22	CAD DRAWING NO. ESD-635D
	SCALE		
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410 TITLE ESD-635D LOUVER W/VCD-40 FLANGE FRAME SLEEVE MOUNT JAMB AND MULLION DETAILS			
<div style="text-align: center;"> <p>WAYNE K. HELMILA LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER</p> </div>			
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092			

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09

Expiration Date 12/06/2023


By *[Signature]*
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code


NOA-No. 23-1013.08

Expiration Date 12/06/2024


By *[Signature]*
Miami-Dade Product Control



25
17/22
JAMB DETAIL
LOUVER HEIGHT ≤ 144 IN.



26A
17/22
MULLION DETAIL
LOUVER HEIGHT ≤ 144 IN.



26B
17/22
MULLION DETAIL
LOUVER HEIGHT ≤ 96 IN.

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09

Expiration Date 12/06/2023

By *[Signature]*
Miami-Dade Product Control


PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04

Expiration Date 12/06/2022

By *[Signature]*
Miami-Dade Product Control


DRAWN BY	DATE
MES	8/9/2017
SCALE	
SHEET NO.	17 OF 22
CAD DRAWING NO.	ESD-635D

GREENHECK
P.O. BOX 410 SCHOFIELD,
WISCONSIN 54476-0410



TITLE
ESD-635D LOUVER W/VCD-40
CONTINUOUS ANGLE MOUNT

JAMB AND MULLION DETAILS














RICE ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

NOTES:

1. OTHER SHAPES MAY APPLY PROVIDING THEY ARE SIMILAR TO THOSE SHOWN AND HAVE CORNER CONSTRUCTION AS DESCRIBED ON ALL SHEETS.
2. ALL SHAPED LOUVER PANELS ARE RESTRICTED TO THE SAME PANEL WIDTH AND PRESSURE AS THE RECTANGULAR LOUVER PANELS AND MAY BE STACKED VERTICALLY AND HORIZONTALLY THE SAME AS THE RECTANGULAR PANELS.
3. WHEN SECTIONS EXCEED 36" IN LENGTH BLADE SUPPORT ANGLE AND BRACKETS ARE REQUIRED.

AVAILABLE SHAPES



PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08
Expiration Date 12/06/2024
By [Signature]
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09
Expiration Date 12/06/2023
By [Signature]
Miami-Dade Product Control

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 17-0919.04
Expiration Date 12/06/2022
By [Signature]
Miami-Dade Product Control

DRAWN BY MES	DATE 8/9/2017	SCALE	SHEET NO. 18 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410				
TITLE ESD-635D LOUVER W/ AND W/O VCD-40			AVAILABLE SHAPES	
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092				

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08

Expiration Date 12/06/2024

By *[Signature]*
Miami-Dade Product Control

*EMBEDMENT DEPTH IS EQUAL TO OVERALL FASTENER LENGTH FOR CONCRETE/CMU FASTENERS. IF SHIMS ARE USED, FASTENER LENGTH MUST BE INCREASED BY THICKNESS OF SHIMS.

ITEM	DESCRIPTION	MATERIAL	NOTES
1	LOUVER HEAD	6063-T5 ALUMINUM	
2	LOUVER BLADE	6063-T5 ALUMINUM	4.0625" MAX. SPACING
3	LOUVER SILL	6063-T5 ALUMINUM	
4	LOUVER JAMB	6063-T5 ALUMINUM	
5	LOUVER/DAMPER FLANGE	6063-T5 ALUMINUM	
6	FORMED SLEEVE	5052-H32 ALUMINUM	1/8" FORMED SLEEVE - DEPTH VARIES
7A	1 1/2 X 1 1/2 X 1/4 ANGLE	6063-T5 ALUMINUM	BLADE SUPPORT ANGLE
7B	1 1/2 X 1 1/2 X 1/4 ANGLE	6063-T5 ALUMINUM	USED AT HEAD/SILL/JAMB OF SLEEVE
8	1 1/2 X 6 X 1/8 ANGLE	6063-T5 ALUMINUM	JAMB ANGLE
9	1 1/2 X 1 1/2 X 1/8 ANGLE	6063-T5 ALUMINUM	USED AT HEAD/SILL/JAMBS OF LOUVER
10	1 1/2 X 1 1/2 X 1/8 ANGLE	6063-T5 ALUMINUM	USED AT HEAD & SILL OF SLEEVE
11	3 X 6 X 5/16 STEEL TUBE	A36 STEEL	SHIP LOOSE
12	4 X 6 X 1/4 ALUM. SHIMS	5052-H32 ALUMINUM	USED AT SILL FOR SUPPORT ANGLE
13	BLADE BRACKET	6063-T5 ALUMINUM	4.5" LONG
14	DAMPER HEAD/SILL	6063-T5 ALUMINUM	
15	DAMPER JAMB	6063-T5 ALUMINUM	
16	DAMPER BLADE	6063-T5 ALUMINUM	3.75 MAX. SPACING
17	DAMPER BLADE SEAL	SILICONE/RUBBER TYPE	MATERIAL VARIES
18	DAMPER JAMB SEAL	SS	
19	DAMPER TOP/BOTTOM CLOSURE	ALUMINUM	
20A	DAMPER LINKAGE BAR	GALV. STEEL	
20B	DAMPER LINKAGE BAR	SS	
21A	DAMPER AXLE BUSHING	DEL-RIN	
21B	DAMPER AXLE BUSHING	BRONZE	
21C	DAMPER AXLE BUSHING	SS	
22A	NON-DRIVE DAMPER AXLE ASST.	ZC STEEL PIN W/ DEL-RIN BUSHING	
22B	NON-DRIVE DAMPER AXLE ASST.	ZC STEEL PIN W/ BRONZE BUSHING	
22C	NON-DRIVE DAMPER AXLE ASST.	ZC STEEL PIN W/ SS BUSHING	
22D	NON-DRIVE DAMPER AXLE ASST.	SS PIN W/ DEL-RIN BUSHING	
22E	NON-DRIVE DAMPER AXLE ASST.	SS PIN W/ BRONZE BUSHING	
22F	NON-DRIVE DAMPER AXLE ASST.	SS PIN W/ SS BUSHING	
23A	DRIVE SIDE DAMPER AXLE ASST.	ZC/GALV. STEEL	
23B	DRIVE SIDE DAMPER AXLE ASST.	SS	
24A	1/4 DIA. E-CLIP	ZP	
24B	1/4 DIA. E-CLIP	SS	
25	#8 X .75 TYP TYPE AB SMS	SS	
26	#14 X .75 TEK	ZP	
27A	1/4-20 X 1.25 HH CS	SS	
27B	1/4-20 X 1.5 HH CS	SS	
27C	1/4-20 X .75 HH CS	SS	
28A	1/4-20 NUT	ZP	
28B	1/4-20 NUT	SS	
29	REINFORCING STRAP	18-8 SS	
30	1/4-20 X .562 BALL SWIVEL	ZP	
31A	DAMPER BLADE DRIVE LEVER	SS	
31B	DAMPER BLADE DRIVE LEVER	GALV. STEEL	
32	DAMPER MANUAL QUAD ASSY.		
33	5/16 DIA. LINKAGE ROD	ZP	
34	#12-14 X 3/4" TYP SMS 18-8 SS	18-8 SS	
35	#10 X 1 1/4" SMS 316 SS	316 SS	
36	1/4" DIA. SCREW	SS	1 1/2" LONG
37	1/4" DIA. SCREW	SS	1" LONG
38A	DEAD LOAD SHIMS		NOT BY MANUFACTURER
38B	SEALANT AND BACKER ROD		NOT BY MANUFACTURER
39	5 1/4 X 2 X 1/4 ANGLE	6063-T5 ALUMINUM	USED AT JAMB OF LOUVER/SLEEVE
40	4" CHANNEL	6061-T6 ALUMINUM	USED AT JAMB OF LOUVER/SLEEVE
41	MULLION SLEEVE BRACKET	5052-H32 ALUMINUM	
42	1 1/4 X 1 1/4 X 1/8 ANGLE	6063-T5 ALUMINUM	MIN SIZE, JAMB ATTACHMENT ANGLE
43	BLADE SUPPORT, ALTERNATE	6063-T5 ALUMINUM	ALTERNATE STYLE
44	STEEL MULLION END CAP (SMD)	STEEL	FACTORY WELDED TO MULLION
45	ALUMINUM MULLION END CAP (SMD)	5052-H32 ALUMINUM	FACTORY WELDED TO MULLION
46	STEEL MULLION END CAP (LG)	STEEL	FACTORY WELDED TO MULLION
47	ALUM MULLION END CAP (LG)	5052-H32 ALUMINUM	FACTORY WELDED TO MULLION
48	MULLION MOUNTING ANG. BRACKET	STEEL 36 KSI, DR 6061-T6	MULLION MOUNTING ANGLE, HX144
49	1/4" DIA. THREAD STUD	SS OR PLATED STEEL	1/2" MIN. LONG





ITEM	CONCRETE	CMU	STEEL	WOOD	MIN.	FASTENER TYPE	ALL FASTENERS ARE STEEL OR STAINLESS
50	JAMB PERIMETER ANGLE FASTENER, HEIGHT <=144					DIAMETER # ROD. CENTERS EDGE EMBED.*	
50A	X				2KSI	"POWERS WEDGE BOLT"	3/8 VARIES 6.00 1.215 3.500
50B	X				4KSI	"POWERS WEDGE BOLT"	3/8 VARIES 6.00 1.215 3.500
50C	X				2KSI	SCOTS TAPCON / TAPCON	1/4 VARIES 4.75 1.500 1.750
50D	X				4KSI	SCOTS TAPCON / TAPCON	1/4 VARIES 6.00 1.500 1.750
50E		X			15KSI	SCOTS TAPCON / TAPCON	1/4 VARIES 3.00 1.500 1.750
50F			X		65KSI Fy	BOLT/NUT OR TAPPING SCREW	1/4 VARIES 6.00 0.500 0.125
50G				X	SG 0.42	LAG	3/8 VARIES 6.00 1.500 2.375
51	MULLION END PLATE FASTENER, HEIGHT <=144					DIAMETER # ROD. CENTERS EDGE EMBED.*	
51A	X				2KSI	"POWERS WEDGE BOLT"	3/8 8/END 1.50 1.75 3.500
51B	X				4KSI	"POWERS WEDGE BOLT"	3/8 8/END 1.50 1.75 3.500
51C	X				2KSI	SCOTS TAPCON / TAPCON	1/4 9/END 2.00 1.50 1.625
51D	X				4KSI	SCOTS TAPCON / TAPCON	1/4 8/END 2.00 1.50 1.625
51E		X			65KSI Fy	BOLT/NUT OR TAPPING SCREW	1/4 8/END 1.00 0.50 0.125
51F			X		SG 0.42	LAG	3/8 7/END 1.50 1.75 2.375
52	MULLION ANGLE MOUNT FASTENER, HEIGHT <=144					DIAMETER # ROD. CENTERS EDGE EMBED.*	
52A	X				2KSI	"POWERS WEDGE BOLT"	3/8 12/ANG. 3.375 2.250 3.500 3.766
52B	X				4KSI	"POWERS WEDGE BOLT"	3/8 9/ANG. 3.375 2.250 3.500 3.766
52C	X				2KSI	SCOTS TAPCON / TAPCON	1/4 32/ANG. 2.000 1.500 1.750 3.375
52D	X				4KSI	SCOTS TAPCON / TAPCON	1/4 27/ANG. 2.000 1.500 1.750 3.375
52E		X			15KSI	SCOTS TAPCON / TAPCON	1/4 32/ANG. 2.000 1.500 1.750 3.375
52F			X		65KSI Fy	BOLT/NUT OR TAPPING SCREW	1/4 16/ANG. 1.000 0.500 0.125 3.000
52G			X		65KSI Fy	BOLT/NUT OR TAPPING SCREW	1/4 11/ANG. 1.000 0.500 0.188 3.000
52H			X		65KSI Fy	BOLT/NUT OR TAPPING SCREW	1/4 16/ANG. 1.000 0.500 0.188 3.766
52I			X		65KSI Fy	BOLT/NUT OR TAPPING SCREW	5/16 12/ANG. 1.000 0.625 0.125 3.000
52J			X		65KSI Fy	BOLT/NUT OR TAPPING SCREW	5/16 16/ANG. 1.000 0.625 0.125 3.766
52K				X	SG 0.42	LAG	3/8 16/ANG. 1.500 1.500 2.875 3.766
52L				X	SG 0.42	LAG	3/8 11/ANG. 1.500 1.500 2.875 3.000
53	MULLION END PLATE FASTENER, HEIGHT <=96					DIAMETER # ROD. CENTERS EDGE EMBED.*	
53A	X				2KSI	"POWERS WEDGE BOLT"	3/8 5/CAP 1.50 1.6 3.500
53B	X				4KSI	"POWERS WEDGE BOLT"	3/8 5/CAP 1.50 1.6 3.500
53C	X				2KSI	"POWERS WEDGE BOLT"	3/8 5/CAP 2.00 1.75 3.500
53D	X				4KSI	"POWERS WEDGE BOLT"	3/8 5/CAP 2.00 1.75 3.500
53E	X				2KSI	SCOTS TAPCON / TAPCON	1/4 6/CAP 2.00 1.50 1.750
53F	X				4KSI	SCOTS TAPCON / TAPCON	1/4 6/CAP 2.00 1.50 1.750
53G		X			65KSI Fy	BOLT/NUT OR TAPPING SCREW	1/4 3/CAP 1.00 0.50 0.125
53H			X		SG 0.42	LAG	3/8 5/CAP 1.50 1.75 2.375
54	MULLION ANGLE MOUNT FASTENER, HX=96					DIAMETER # ROD. CENTERS EDGE EMBED.*	
54A	X				2KSI	"POWERS WEDGE BOLT"	3/8 4/ANG. 3.375 2.25 3.500 3.766
54B	X				4KSI	"POWERS WEDGE BOLT"	3/8 3/ANG. 3.375 2.25 3.500 3.766
54C	X				2KSI	SCOTS TAPCON / TAPCON	1/4 11/ANG. 2.000 1.50 1.750 3.375
54D	X				4KSI	SCOTS TAPCON / TAPCON	1/4 9/ANG. 2.000 1.50 1.750 3.375
54E		X			15KSI	SCOTS TAPCON / TAPCON	1/4 11/ANG. 2.000 1.50 1.750 3.375
54F			X		65KSI Fy	BOLT/NUT OR TAPPING SCREW	1/4 7/ANG. 1.000 0.50 0.125 3.766
54G			X		65KSI Fy	BOLT/NUT OR TAPPING SCREW	1/4 6/ANG. 1.000 0.50 0.125 3.000
54H				X	SG 0.42	LAG	3/8 5/ANG. 1.500 1.50 2.875 3.766
54I				X	SG 0.42	LAG	3/8 4/ANG. 1.500 1.50 2.875 3.000

GENERAL NOTES:











- IT SHALL BE THE RESPONSIBILITY OF THE PERMIT HOLDER TO VERIFY THE STRUCTURAL INTEGRITY OF THE EXISTING STRUCTURE TO SUPPORT THE LOADS IMPOSED BY THE LOUVER(S).
- THE LOUVER HAS BEEN DESIGNED AND TESTED IN ACCORDANCE WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) REQUIREMENTS OF THE CURRENT FLORIDA BUILDING CODE (FBC) TO TEST PROTOCOLS TAS 201-94 (IMPACT), TAS 202-94 (UNIFORM STATIC PRESSURE), AND TAS 203-94 (CYCLIC PRESSURE).
- LOUVER ASSEMBLY IS QUALIFIED FOR A MAXIMUM DESIGN LOAD OF +/- 150 PSF.
- MAXIMUM SINGLE SECTION SIZE IS 72" WIDE X 144" HIGH. MAXIMUM ASSEMBLED LOUVER SIZE IS UNLIMITED WIDE X 144" HIGH.
- SECTIONS OR ASSEMBLIES MAY BE STACKED VERTICALLY PROVIDING A SUITABLE STRUCTURAL SUPPORT IS DESIGNED AND INSTALLED BY OTHERS TO SUPPORT ALL LOADS TRANSFERRED FROM THE LOUVER.
- CMU SHALL BE ASTM C90, TYPE II, 2,000 MIN PSI GROUT-FILLED.
- THE SLEEVE MOUNT STYLE LOUVER UTILIZES AN ANCHORLESS INSTALLATION METHOD THAT DOES NOT REQUIRE THE USE OF FASTENERS INTO THE SUBSTRATE. IT MAY BE INSTALLED IN ANY SUBSTRATE THAT WILL WITHSTAND THE LOADS TRANSFERRED TO IT BY THE LOUVER. ALSO SEE NOTE #1.
- THE CONTINUOUS ANGLE MOUNT STYLE UTILIZES A CONTINUOUS JAMB ANGLE THAT IS ATTACHED TO THE SUBSTRATE BY FASTENERS. IT MAY BE INSTALLED IN CONCRETE, CMU, STEEL, OR WOOD ACCORDING TO THE FASTENER SCHEDULE. ALSO SEE NOTE #1.
- LOUVER ASSEMBLY WITH AND WITHOUT VCD-40 DAMPER SHALL ONLY BE INSTALLED IN A LOCATION WHERE THE ROOM BEHIND THE LOUVER IS DESIGNED TO DRAIN WATER PENETRATING INTO THE ROOM AND THE ROOM WILL HOUSE WATER RESISTANT/WATER PROOF EQUIPMENT, COMPONENTS, AND/OR SUPPLIES.
- INSTALLER TO PROVIDE SEPARATION OF DISSIMILAR MATERIALS AS REQUIRED. SEE OLDER 2010 FBC, BUILDING, 2003.8.4 FOR MORE INFORMATION ON SEPARATION OF DISSIMILAR MATERIALS. ALL ALUMINUM, STAINLESS STEEL (SS) AND PLATED/COATED STEEL PARTS PROVIDED BY MANUFACTURER ARE INHERENTLY CORROSION RESISTANT OR HAVE A CORROSION RESISTANT COATING.
- THE VCD-40 MAY BE OPERATED BY A MANUAL QUADRANT OR BY AN ELECTRIC OR PNEUMATIC ACTUATOR. THE DAMPER'S ACTUATOR IS NOT PART OF THIS APPROVAL.
- FRAME CONSTRUCTION. HEAD AND SILL ARE SQUARE CUT. JAMBS ARE SQUARE CUT @ HEAD AND MITERED @ SILL. CORNERS ARE SECURED WITH (2) #10x1-1/4 SMS. BLADES ARE SECURED TO JAMBS WITH (2) #10x1-1/4 SMS AND WELDED @ EACH END.
- STEEL/STAINLESS-STEEL/ALUMINUM PARTS MAY BE MADE OUT OF ALTERNATE ALLOY THAT HAS EQUAL OR GREATER YIELD STRENGTH.
- BLADE SUPPORT ANGLE AND BLADE SUPPORT BRACKETS ONLY REQUIRED WHEN ACTUAL LOUVER SECTION WIDTH IS GREATER THAN 36 INCHES.

NOTE: THE CONTINUOUS ANGLE MOUNT FASTENERS DO NOT ACCOUNT FOR INSTALLATION INTO CRACKED CONCRETE. THE SLEEVE MOUNT STYLE SETUP DOES ACCOUNT FOR INSTALLATION AROUND CRACKED CONCRETE.

DRAWN BY MES	DATE 8/9/2017	SHEET NO. 19 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410			
ESD-635D LOUVER W/ AND W/O VCD-40 SLEEVE/CONTINUOUS MOUNT NOTES/BILL OF MATERIAL			
WAYNE K. HELMILA LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER AUG 30 2017 RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092			



















PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. **22-0816.09**
Expiration Date **12/06/2023**
By *[Signature]*
Miami-Dade Product Control



PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **17-0919.04**
Expiration Date **12/06/2022**
By *[Signature]*
Miami-Dade Product Control

DRAWN BY MES	DATE 8/9/2017	SCALE 1:2	SHEET NO. 20 OF 22	CAD DRAWING NO. ESD-635D
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410				
TITLE ESD-635D LOUVER SLEEVE/CONTINUOUS MOUNT W/ AND W/O VCD-40 PART PROFILES				
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092				




PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 23-1013.08
Expiration Date 12/06/2024





By [Signature]
Miami-Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
NOA-No. 22-0816.09
Expiration Date 12/06/2023
By [Signature]
Miami-Dade Product Control

DRAWN BY MES	DATE 8/9/2017	SHEET NO. 21 OF 22	CAD DRAWING NO. ESD-635D
SCALE 1:2			
GREENHECK P.O. BOX 410 SCHOFIELD, WISCONSIN 54476-0410		TITLE ESD-635D LOUVER SLEEVE/CONTINUOUS MOUNT W/ AND W/O VCD-40 PART PROFILES	
<div style="text-align: center;"> AUG 30 2017 RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000005061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092 </div>			



DIM. DESCRIPTION
 A $\geq 0.375/0.50$ FOR $1/4$ FASTENER IN ALUMINUM/STEEL
 A $\geq 0.563/0.75$ FOR $3/8$ FASTENER IN ALUMINUM/STEEL
 B \geq FASTENER SPACING DISTANCE
 C \geq FASTENER CLEARANCE HOLE DIAMETER
 D \geq FASTENER SUBSTRATE EDGE DISTANCE
 GROUP CENTER = CENTER OF FASTENER HOLE PATTERN



PRODUCT RENEWED
 as complying with the Florida
 Building Code
 NOA-No. **22-0816.09**
 Expiration Date **12/06/2023**
 By *[Signature]*
 Miami-Dade Product Control

PRODUCT REVISED
 as complying with the Florida
 Building Code
 NOA-No. **17-0919.04**
 Expiration Date **12/06/2022**
 By *[Signature]*
 Miami-Dade Product Control

MULLION MOUNTING BRACKET TABLE, 1 OF 2						
LOUVER HEIGHT	SUBSTRATE LEG THK	LOUVER LEG THK	GUSSET THK	MIN CUT LENGTH	MAT'L TYPE	PROCESS TYPE
≤ 144	$\geq 1/2$	$\geq 1/2$	NA	16.5	6061-T6	EXTRUDED
≤ 144	$\geq 7/16$	$\geq 7/16$	NA	24	A36	ROLLED
≤ 144	$\geq 1/2$	$\geq 1/2$	NA	18.5	A36	ROLLED
≤ 144	$\geq 5/16$	$\geq 1/4$	$\geq 5/16$	20	6061-T6	WELDED
≤ 144	$\geq 5/16$	$\geq 3/16$	$\geq 5/16$	20	STEEL	WELDED

MULLION MOUNTING BRACKET TABLE, 2 OF 2						
LOUVER HEIGHT	SUBSTRATE LEG THK	LOUVER LEG THK	GUSSET THK	MIN CUT LENGTH	MAT'L TYPE	PROCESS TYPE
≤ 96	$\geq 1/2$	$\geq 1/2$	NA	6.6	6061-T6	EXTRUDED
≤ 96	$\geq 3/8$	$\geq 3/8$	NA	12.34	STEEL	ROLLED
≤ 96	$\geq 7/16$	$\geq 7/16$	NA	9	STEEL	ROLLED
≤ 96	$\geq 5/16$	$\geq 1/4$	$\geq 5/16$	9	6061-T6	WELDED
≤ 96	$\geq 5/16$	$\geq 3/16$	$\geq 5/16$	9	STEEL	WELDED

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 NOA-No. **23-1013.08**
 Expiration Date **12/06/2024**
 By *[Signature]*
 Miami-Dade Product Control

GREENHECK P.O. BOX 410 SCHOFFIELD, WISCONSIN 54476-0410	DRAWN BY MES	DATE 8/9/2017
	SCALE 1:2.2	SHEET NO. 22 OF 22
TITLE ESD-635D LOUVER SLEEVE/CONTINUOUS MOUNT W/ AND W/O VCD-40 PART PROFILES		
LICENSE No. 59092 STATE OF FLORIDA PROFESSIONAL ENGINEER AUG 30 2017		
RICE ENGINEERING 105 School Creek Trail Luxemburg, WI 54217 Phone: (920) 617-1042 Fax: (920) 617-1100 www.rice-inc.com Florida Firm No: F-01000035061 Certificate of Authorization: #9090 Wayne K. Helmila Registration No: 59092		