



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99  
[www.miamidade.gov/pera](http://www.miamidade.gov/pera)

**DuPont de Nemours, Inc.**  
**1501 Larkin Center Drive**  
**Midland, MI 48642**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Protec 120, Protec 200, Protec 160 and Protec PSU Roofing Underlayments

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 4.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 23-1018.07  
Expiration Date: 06/10/26  
Approval Date: 11/30/23  
Page 1 of 4

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Underlayment  
**Material:** Polypropylene

### SCOPE:

This approves the **Protec 120, Protec 200, Protec 160 and Protec PSU Roofing Underlayments**, as described in this Notice of Acceptance; designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Protec 120 Roofing Underlayment (Manufacturing location #1)	48" x 250' rolls & 42" x 286' rolls	ASTM D8257	polymer-based scrim-reinforced roofing underlayment, consisting of woven polyolefin base with a layer of nonwoven polyolefin sheet and a polymer coating on the back side, with a nominal unit weight of 2.25 lbs./square.
Protec 200 Roofing Underlayment (Manufacturing location #1)	48" x 250' rolls	ASTM D8257	polymer-based scrim-reinforced roofing underlayment, consisting of woven polyolefin base with a layer of nonwoven polyolefin sheet and a polymer coating on the back side, with a nominal unit weight of 3.80 lbs./square.
Protec 160 Roofing Underlayment (Manufacturing location #1)	48" x 250' rolls	ASTM D8257	polymer-based scrim-reinforced roofing underlayment, consisting of woven polyolefin base with a layer of nonwoven polyolefin sheet and a polymer coating on the back side, with a nominal unit weight of 3.40 lbs./square.
Protec PSU Underlayment (Manufacturing location #2)	36" x 67' rolls	ASTM D1970	High temp. self adhered roofing underlayment.

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
NEMO ETC, LLC	4j-ACT-22-SSUDL-01.A	ASTM D1970	07/29/22
	4a-ACT-22-LSWUS-01.A	TAS 114 (C)	02/13/23
QAI Laboratories	RJ8657P-4	ASTM D1970	11/09/22
	RJ8299P-8	ASTM D8257	02/15/22
	RJ8299P-12	ASTM D8257	03/29/22
	RJ8299P-17	ASTM D8257	02/15/22



NOA No.: 23-1018.07  
Expiration Date: 06/10/26  
Approval Date: 11/30/23  
Page 2 of 4

## MANUFACTURING LOCATION:

1. Parzai, India
2. Dubai, United Arab Emirates

## APPROVED ASSEMBLIES:

<b>Deck Type 1:</b>	Wood, Non-Insulated
<b>Deck Description:</b>	<sup>19</sup> / <sub>32</sub> " or greater plywood or wood plank
<b>System E(1):</b>	Anchor/Base Sheet mechanically fastened to deck
<b>Anchor/Base Sheet:</b>	One or more plies of Protec 120, Protec 200 or Protec 160 applied with minimum 4" side laps and minimum 6" vertical laps and mechanically fastened as noted below.
<b>Fastening:</b>	Miami-Dade approved nails & metal/tin caps spaced 6" o.c. at the 4" side laps and three staggered rows 12" o.c. equally spaced grid pattern in the field of the sheet.
<b>Membrane (Optional):</b>	One or more plies of Protec PSU, self-adhered, with a minimum 4" wide headlap and a minimum 8" wide end lap. Place the first course of Protec PSU underlayment parallel to the eave, using a heavy pressure roller under safe conditions to further secure the membrane.
<b>Surfacing:</b>	Protec PSU underlayments are approved for synthetic and/or composite shingles, asphaltic shingles, synthetic and/or composite cedar shakes, wood shakes, wood shingles, non-structural metal roofing, synthetic and/or composite slates, and quarry slates holding current NOA. Must comply with applicable Roofing Application Standards and Building Codes.

**Note: The assembly below may only be applied in the HVHZ effective with 2023 FBC 8th Edition.**

<b>Deck Type 1:</b>	Wood, Non-Insulated
<b>Deck Description:</b>	<sup>19</sup> / <sub>32</sub> " APA rated, 40/20 span rating, CDX, 4-ply or greater plywood or wood plank #10 wood screws, 6" o.c. at max. 24" spans.
<b>System F(1):</b>	Membrane self-adhered directly to deck.
<b>Membrane:</b>	One or more plies of Protec PSU, self-adhered and back-nailed using 12 ga. Ring shank nails and 1-5/8" tin caps 12" o.c.
<b>Surfacing:</b>	Protec PSU underlayments are approved for synthetic and/or composite shingles, asphaltic shingles, synthetic and/or composite cedar shakes, wood shakes, wood shingles, non-structural metal roofing, synthetic and/or composite slates, and quarry slates holding current NOA. Must comply with applicable Roofing Application Standards and Building Codes.
<b>Underlayment Uplift Design Pressure:</b>	-97.5 psf.*

**\* Underlayment Uplift Design Pressure rating above is included for additional analysis of the underlayment assembly only by the Authority Having Jurisdiction. This value does not include the roof system. Refer to roof system NOA for maximum design pressure of the final roof assembly.**



NOA No.: 23-1018.07  
Expiration Date: 06/10/26  
Approval Date: 11/30/23  
Page 3 of 4

## **BUILDING PERMIT REQUIREMENTS:**

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

## **LIMITATIONS:**

1. Fire classification is not part of this acceptance.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. Protec 120, Protec 200, Protec 160 and Protec PSU Underlayments shall be applied to a clean and dry surface.
4. Protec 120, Protec 200, Protec 160 and Protec PSU Underlayments may be used with any approved roof covering Notice of Acceptance listing Protec 120, Protec 200, Protec 160 and Protec PSU Underlayments as a component part of an assembly in the Notice of Acceptance. If Protec 120, Protec 200, Protec 160 and Protec PSU Underlayments are not listed; a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
5. Protec 120, Protec 200, Protec 160 and Protec PSU Underlayments shall not be used on slopes less than 2:12. In general, on slopes less than 4:12, a double layer is recommended. Double layer application is best achieved by using 19" side laps, making sure the side laps are 'shingled in' to shed water.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
7. Protec 120, Protec 200 and Protec 160 Underlayments shall not be left exposed as a temporary roof for longer than 90 days after application. Protec PSU shall not be left exposed as a temporary roof for longer than 180 days after application.
8. The manufacturer reserves the right to change product exposure period at any time; not to exceed the preceding maximum time limitations.
9. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

**MIAMI-DADE COUNTY**  
**APPROVED**

**END OF THIS ACCEPTANCE**

**MIAMI-DADE COUNTY**  
**APPROVED**

**NOA No.: 23-1018.07**  
**Expiration Date: 06/10/26**  
**Approval Date: 11/30/23**  
**Page 4 of 4**