

Nu-Vue Industries, Inc. 1055 East 29th Street Hialeah, Florida 33013

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series NVSNP, NV/NVTH, NVTHS, NVHC, NVSTA and NVHTA Steel Wood Connectors

APPROVAL DOCUMENT: Drawing No. **JA-2029.1-23**, titled "SERIES NVSNP, NV/NVTH, NVTHS, NVHC,NVSTA AND NVHTA STEEL WOOD CONNECTORS", sheets 1 through 5 of 5, dated 01/11/2024, prepared by Javad Ahmad PE, Inc., signed and sealed by Javad Ahmad, P.E. on 02/06/2024, bearing the Miami-Dade County Product Control revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: None

LABELING: A permanent mark with the manufacturer's name, acronym or logo is to be located on each unit. A permanent label with the manufacturer's name or logo, city, state, model/series, and the statement reading 'Miami-Dade County Product Control Approved' is to be located on each packaging carton.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises and renews NOA # 23-0210.01** and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by Sifang Zhao, P.E.

MIAMIDADECOUNTY



04/11/2024

NOA No. 24-0213.05 Expiration Date: July 30, 2030 Approval Date: April 11, 2024 Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS NOAs

A. DRAWINGS "Submitted under NOA #20-0526.05"

1. Drawing No. NU-5, titled "Skewed Nail Plate, NV358 & NV458 with Double NVTH Straps, NVTH/NVTHS Anchors & NVHC Hurricane Clips and NVSTA & NVHTA Heavy Duty Anchors with Seat", sheets 1 through 4 of 4, dated 06/25/2020, prepared by Nu-Vue Industries, Inc., signed and sealed by Vipin N. Tolat, P.E.

B. TESTS "Submitted under NOA # 04-0510.03"

Test reports on wood connectors per ASTM D1761 by Product Testing, Inc., signed and sealed by C. R. Caudel, P.E.

	<u>Report No.</u>	Wood Connector	Direction	Date
1.	PT # 03-4482	NVSNP3	Downward	09/15/03
2.	PT # 03-4625	NVHCL/R	Up& Sideways	01/21/04
3.	PT # 04-4641	NVSTA-24H	Up& Sideways	03/17/04
4 .	PT # 04-4698	NVTH24	Up& Sideways	04/15/04
5.	PT # 03-4590	NVTH26/NV458	Sideways	12/31/03
6.	PT # 04-4642	NVHTA-24H	Up& Sideways	03/22/04
7.	PT # 03-4543	NVTH20/NV358	Up& Sideways	12/19/03

C. CALCULATIONS"

- 1. Report of Design Capacities, dated 06/30/2009, sheets 1 through 12 of 12, prepared, signed and sealed by Vipin N. Tolat, P.E. "*Submitted under NOA # 09-0721.05*
- 2. Report of Design Capacities dated 04/27/2004, sheet 1 through 12, prepared, signed and sealed by Vipin N. Tolat, P.E. "*Submitted under NOA # 04-0510.03*"
- **3.** Verification calculations for compliance with the ASTM D7147-05 and ASTM D7147-11, prepared by Vipin N. Tolat, P.E. dated 05/18/2020, signed and sealed by Vipin N. Tolat, P.E. "*Submitted under NOA #20-0526.05*"

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENT

- Statement letter of code conformance to the 5th Edition (2014) and 6th Edition (2017) FBC, issued by Vipin N. Tolat, P.E., dated 07/25/2017, signed and sealed by Vipin N. Tolat, P.E.
 "Submitted under NOA #17-0802.07"
- 2. Statement letter of code conformance, no financial interest and no change of product, dated 07/08/2009, issued, signed and sealed by Vipin N. Tolat, P.E. *"Submitted under NOA # 09-0721.05"*
- 3. Statement letter of code conformance to the 6th Edition (2017) and the 7th Edition (2020) FBC and of no financial interest, issued by Vipin N. Tolat, P.E., dated 06/25/2020, signed and sealed by Vipin N. Tolat, P.E. "*Submitted under NOA #20-0526.05*"

Sifang Zhao, P.E. Product Control Examiner NOA No. 24-0213.05 Expiration Date: July 30, 2030 Approval Date: April 11, 2024

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

2. EVIDENCE SUBMITTED NOA#23-0210.01 and newer

A. DRAWINGS

- 1. Drawing No. JA-1958.1-22, titled "NOA No. 20-0526.05 Revision", sheets 1 through 5 of 5, dated 01/18/2023, prepared by Javad Ahmad PE, Inc., signed and sealed by Javad Ahmad, P.E. on 04/11/2023. "Submitted under NOA #23-0210.01"
- 2. Drawing No. JA-2029.1-23, titled "NOA No. 20-0526.05 Revision", sheets 1 through 5 of 5, dated 01/11/2024, prepared by Javad Ahmad PE, Inc., signed and sealed by Javad Ahmad, P.E. on 02/06/2024. "Submitted under NOA #24-0213.05"

B. TESTS

1. None.

C. CALCULATIONS

- 1. Allowable loads calculations, prepared by Javad Ahmad PE, Inc., dated 04/11/2023, signed and sealed by Javad Ahmad, P.E. *"Submitted under NOA #23-0210.01"*
- 2. Allowable loads calculations, prepared by Javad Ahmad PE, Inc., dated 01/23/2024, signed and sealed by Javad Ahmad, P.E. *"Submitted under NOA #24-0213.05"*

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENT

- 1. Statement letter of code conformance to the 7th Edition (2020) of the FBC and of no financial interest, issued by Javad Ahmad PE, Inc., dated 02/03/2023, signed and sealed by Javad Ahmad, P.E. *"Submitted under NOA #23-0210.01"*
- 2. Statement letter of code conformance to the 8th Edition (2023) of the FBC and of no financial interest, issued by Javad Ahmad PE, Inc., dated 01/23/2024, signed and sealed by Javad Ahmad, P.E. *"Submitted under NOA #24-0213.05"*

Sifang Zhao, P.E. Product Control Examiner NOA No. 24-0213.05 Expiration Date: July 30, 2030 Approval Date: April 11, 2024

NU-VUE INDUSTRIES, INC.

1055 EAST 29TH HIALEAH, FL 33013, TEL. 305-694-0397





GENERAL NOTES:

3

6.

7.

- ALLOWABLE LOADS AND ALL FASTENERS ARE BASED ON NATIONAL DESIGN SPECIFICATIONS (NDS) FOR WOOD CONSTRUCTION 2018.
- 2.
- 2018
- CHANGES. DESIGN LOADS DO NOT INCLUDE 33% INCREASE FOR STEEL AND CONCRETE.
- 4 5.
- TO WIND AND EARTHQUAKE LOAD PER NDS 2018.
- DESIGN CONFORMS TO 2023 EDITION OF FLORIDA BUILDING CODE AND NDS 2018.
- ACTUAL UPLIFT + ACTUAL L1 ALLOWABLE UPLIFT ALLOWABLE L1
- ALL TESTS HAVE BEEN CONDUCTED IN ACCORDANCE WITH ASTM D-1761. THE DESIGN LOADS LISTED ARE BASED ON THE LEAST VALUE OF THE FOLLOWING: 1. THE LOWEST ULTIMATE LOAD DIVIDED BY THREE. 2. THE LOWEST LOAD PRODUCING 1/8 " DEFLECTION.



MATERIAL

mAn	
1.	WOOD
	WOOD MEMBERS MUST BE S.P. NO. 1, SPECIFIC GRAVITY 0.55 OR AN APPROVED MEMBER WITH AN
	EQUIVALENT GRADE. DESIGN LOADS FOR OTHER SPECIES SHALL BE ADJUSTED PER NDS 2018. WOOD
	MEMBERS SHALL HAVE A MOISTURE CONTENT NOT EXCEEDING 19 PERCENT (16 PERCENT FOR
	STRUCTURAL ENGINEERED LUMBER). WOOD MEMBERS MUST BE USED UNDER CONTINUOUSLY DRY
0	CONDITIONS AND WHERE SUSTAINED TEMPERATURES ARE LIMITED TO 100° F.
2.	PRESERVATIVE AND FIRE RETARDANT WOOD
	CONNECTORS OR FASTENERS USED IN CONTACT WITH PRESERVATIVE-TREATED AND FIRE-RETARDANT- TREATED WOOD SHALL BE IN ACCORDANCE WITH SECTION 2304.10.5.
3.	I REATED WOOD SHALL BE IN ACCORDANCE WITH SECTION 2304.10.5. NAIL
э.	NAIL NAILS SHALL MEET THE REQUIREMENTS IN TABLE AND THE REQUIREMENTS SPECIFIED IN ASTM F 1667.
4.	GECMU MASONRY
ч.	MATERIAL AND QUALITY OF MASONRY CONSTRUCTION MUST COMPLY WITH THE APPLICABLE SECTIONS OF
	FBC 2023, MINIMUM CONCRETE OR GROUT COMPRESSIVE STRENGTH SHALL BE 1500 PSI, CONCRETE
	MASONRY SHALL COMPLY WITH ASTIN CON
5.	CONCRETE
	MINIMUM CONCRETE COMPRESSIVE STRENGTH SHALL BE 2500 PSI.
6.	STEEL
	CONNECTOR STEEL SHALL CONFORM TO ASTM A653 SS GRADE 33, MIN, YIELD 33 KSI, MIN. TENSILE
	STRENGTH 45 KSI AND MIN. GALVANIZED COATING OF G 60 PER ASTM A653.

REFE	RENCES:	
1.	AISC 360-16	
2.	AISI \$100-16	
3.	FBC 2023	
4.	ACI 318-19	

DESIGN LOADS ARE BASED ON SOUTHERN YELLOW PINE WOOD SPECIES WITH A SPECIFIC GRAVITY OF 0.55. ALLOWABLE LOADS FOR OTHER SPECIES OR CONDITIONS MUST BE ADJUSTED ACCORDING TO NDS

THIS CATALOG REFLECTS DESIGN CHANGES AND DESIGN ADJUSTMENTS TO SOME NU-VUE PRODUCTS. THE TABLES AND NOTES IN THIS CATALOG SUPERCEDE ALL PREVIOUS DOCUMENTS. NU-VUE RESERVES THE RIGHT TO CHANGE DESIGN SPECIFICATIONS WITHOUT NOTICE AND IS NOT LIABLE FOR SUCH

ALLOWABLE UPLIFT LOADS HAVE BEEN ADJUSTED FOR LOAD DURATION FACTOR CD OF 1.6. APPLICABLE

COMBINED LOAD OF UPLIFT, LI AND L2 SHALL SATISFY THE FOLLOWING EQUATION.

ACTUAL L2 <= 1.0 + ALLOWABLE L2

3. CALCULATIONS BASED ON NDS, AISI AND OTHER APPLICABLE CODES.

	with the Florida
Building Code NOA-No.	24-0213.05
Expiration Dat	te <u>07/30/2030</u>
By Do	
Miami-Dade P	roduct Control



NVSNP3



		TABLE 1 SKEWED NAIL F	PLATE					8800 NW 23rd St, Miami FL		P.N.: (303) 4.24-8001 support@ja-pe.com consulting estructural design • Fradates • Bulliding Envelope • SYSTEM DESIGN • PRODUCT APPROVALS
PRODUCT	STEEL	FASTENERS	ALLOWABL	E LOADS (Ibs.)			AHR	23rd		4.24-8 ja-pe.
CODE	GAUGE	EACH END	GRAVITY	UPLIFT			VAD	MN C	72	РП: (3U5) 4∠4-8UU1 support@ja-pe.com consurtme • structurat pesion • Facab
NVSNP3	16	(6) 8d X 1-1/2"	570	570			AL	880(33172 Db. /20	
						SERIES NV			1055 East 20th Street	Hialeah, FL. 33013
	1. 2. 3. 4.	SEE GENERAL NOTES, USE 6 NAIL HOLES IN E/ DO NOT BEND NAIL PLA SUPPORTING MEMBER	ACH FLANGE. ATE MORE THAN ONCE. SHALL BE IN THE ACUTE	ANGLE SIDE WITH OTHER FL	ANGE BEHIND THE END	3 drawn by: Bvs	check by: BS	NO	DESCRIPTION	
		OF SUPPORTED MEMBE	ER (SEE SKETCH).			JA-2029.1-23	01/11/2024	REVISION	ВҮ	
						drawing no.	date:		No. DATE	
				PRODUCT RE as complying wi Building Code NOA-No2	EVISED ith the Florida 24-0213.05 07/30/2030	D PROP	AD AHAA	MEER +	Digita Dghld Wavad #705 2024. 12:34:	MAD Ahmad 92 02.06



NV358 & NV458

TABLE 2 NV358 - 14G DOUBLE NVTH STRAPS WITH 2 PLY 18G SEAT

ASSEMBLY PRODUCT CODE	14G STRAP PRODUCT CODE	DIMENSION H (in.)	FASTENERS IN 2 STRAPS	TOTAL NO. OF FASTENERS IN SEAT	ALLOWA	BLE LOAI	DS (Ibs.)
CODE	CODE		10d X 3"	10d X 3"	UPLIFT	L1	L2
NV358-12	NVTH16	12	8	8	2245	1961	1839
NV358-14	NVTH18	14	10	8	2525	2206	2068
NV358-16	NVTH20	16	12	8	2806	2452	2298
NV358-20	NVTH24	20	14	8	3086	2697	2528
NV358-22	NVTH26	22	16	8	3367	2942	2758

NV358-24	NVTH28	24
NV358-26	NVTH30	26
NV358-32	NVTH36	32
NV358-44	NVTH48	44



<u>14G NVTH</u>





44



NOTES:

- 2.
- MINIMUM 4" EMBEDMENT INTO CONCRETE. NAILS ARE NECESSARY IN STRAPS AND SEAT TO ACHIEVE DESIGN LOADS. NAILS THROUGH CHORDS SHALL NOT FORCE THE TRUSS PLATE ON THE OPPOSITE SIDE. FOR GENERAL NOTES, SEE SHEET 1. 3.

4



TRUSS PLATE REQUIRED TO TRANSFER UPLIFT TO BOTTOM CHORD

L2

NVTH48

NV458-44

CONCRETE OR MASONRY TIE BEAM

REINFORCEMENT REQUIRED

TABLE 3 NV458 - 14G DOUBLE NVTH STRAPS WITH 3 PLY 18G SEAT

SEAT

8

8

8

8

8

10d X 3

	2" 1/2" 1	-
HOLES DIA. 3/16"		•
	2-	·1/2"
HOLES DI	I A. 3/8" —	





d. of Rs in	ALLOWA	BLE LOAD	S (Ibs.)
3"	UPLIFT	L1	L2
	2245	2783	2078
	2525	3131	2338
	2806	3479	2597
	3086	3827	2857
	3367	4175	3117



18G SEAT DETAIL

PRODUCT as complying	REVISED g with the Florida
NOA-No.	24-0213.05
Expiration Da	ate <u>07/30/2030</u>

Miami-Dade Product Control

10

By



NVHCR/L & NVTH / NVTHS

TABLE 4 HURRICANE CLIPS

	PRODUCT	RECORDETION		FASTNERS	10d X 1-1/2"	-1/2" ALLOWABLE LOADS (I		
	CODE	DESCRIPTION	GAUGE	HEADER	JOIST	UPLIFT	L1	L2
	NVHCR	HURRICANE CLIP - RIGHT	18	6	6	525	253	333
	NVHCL	HURRICANE CLIP - LEFT	18	6	6	525	253	333

TABLE 5 TRUSS ANCHORS NVTH & RIVETED TRUSS ANCHORS WITH SEAT NVTHS

	PRODU	ICT CODE	н	GAUGE		NO. OF FASTNERS IN EACH	MAXIMUM UPLIFT LOADS (lbs)			
			LENGTH(IN)	SEAT	STRAP	STRAP 10d x1-1/2"	UPLIFT	L1	L2	
	NVTH-16	NVTHS-212	12	18	14	5	1032	560	525	
	NVTH-18	NVTHS-214	14	18	14	6	1222	671	630	
	NVTH-20	NVTHS-216	16	18	14	7	1275	783	735	
	NVTH-22	NVTHS-218	18	18	14	8	1329	783	735	
	NVTH-24	NVTHS-220	20	18	14	9	1383	783	735	
	NVTH-26	NVTHS-222	22	18	14	10	1437	783	735	
	NVTH-28	NVTHS-224	24	18	14	11	1490	783	735	
)	NVTH-30	NVTHS-226	26	18	14	12	1544	783	735	
Y	NVTH-36	NVTHS-232	32	18	14	13	1598	783	735	
	NVTH-48	NVTHS-244	44	18	14					







TYPICAL NVTH/NVTHS INSTALLATION



TYPICAL NVHCR/L INSTALLATION



CROSS-SECTION

NOTES:

SEE GENERAL NOTES, SHEET 1. 2

FOR UPLIFT, USE TWO CLIPS, ONE ON EACH SIDE TO COMPLY WITH SECTION 2321.7 OF THE FBC



1-7/8"

1/2"

HOLE DIA. = 0.178"



NVTH, NVTHS FRONT VIEW

PRODUCT as complying	with the Florida
Building Čode NOA–No.	24-0213.05
Expiration Da	te <u>07/30/2030</u>
By Miami-Dade F	Product Control



NVSTA & NVHTA

NVSTA-32H

NVSTA-44H

NVTH36

NVTH48

32

44

TABLE 6 NVSTA - HEAVY DUTY ANCHORS WITH 14G NVTH STRAPS AND 1 PLY 20G SEAT

ASSEMBLY PRODUCT	14G STRAP PRODUCT CODE	DIMENSION H (in.)	FASTENERS	TOTAL NO. OF FASTENERS IN	ALLOWABLE LOADS (lbs.)				
CODE			IN STRAP 10d X 1-1/2"	20 GA. SEAT 10d X 1-1/2"	UPLIFT*	L1*	L2*		
NVSTA-12H	NVTH16	12	5	6	1308	700	1049		
NVSTA-14H	NVTH18	14	6	6	1426	760	1144		
NVSTA-16H	NVTH20	16	7	6	1545	823	1239		
NVSTA-20H	NVTH24	20	8	6	1664	887	1335		
NVSTA-22H	NVTH26	22	9 6		1783	950	1430		
NVSTA-24H	NVTH28	24	1-1/4"						
NVSTA-26H	NVTH30	26				1-1/4*			

ASSEMBLY PRODUCT CODE	14G STRAP PRODUCT CODE	DIMENSION H (in.)	TOTAL NO. OF FASTENERS IN STRAP 10d X 1-1/2"	TOTAL NO. OF FASTENERS IN 20 GA. SEAT 10d X 1-1/2"
NVHTA-12H	NVTH16	12	10	6
NVHTA-14H	NVTH18	14	12	6
NVHTA-16H	NVTH20	16	14	6
NVHTA-20H	NVTH24	20	16	6
NVHTA-22H	NVTH26	22	18	6
NVHTA-24H	NVTH28	24		1/2"
NVHTA-26H	NVTH30	26	3/ ╼┤	
NVHTA-32H	NVTH36	32	-14ª	0



-	1-1/4"	
	° °	
	e 0	
	° °	
	0.0	н
	•	
0.00	1000	
4.	The	1-12
PIN 1/4" DIA.	0	4" MIN. CONC. EMBEDMENT
		4" MIN EMBE
		1-10°

NVHTA WITH 14G DOUBLE NVTH STRAP



12

TRANSFER UPLIFT TO

TIE BEAM, MIN. 2#5 T&B

BOTTOM CHORD





NVHTA-44H NVTH48



NVHTA	- HEAVY DI	JTY ANCHOF	TABI RS WITH 14G D		STRAPS	AND 1 PL	Y 20G SE	EAT		-	י קיי	▲\\ 	• SYSTEM DESIGN • PRODUCT APPROVALS
SEMBLY	, 14G STRAP PRODUCT	STRAP DIMENSION	FASTENERS	TOTAL NO. OF FASTENERS IN 20 GA.	ALLOWABLE LOADS (lbs.)			L	РЕ, INC	ımi FL		• BUILDING ENVELOPE	
CODE	CODE	п (ш.)	IN STRAP 10d X 1-1/2"	SEAT 10d X 1-1/2"	UPLIFT*	UPLIFT**	L1*	L2*			8800 NW 23rd St, Miami FL		
/HTA-12H	NVTH16	12	10	6	1772	2078	1050	1450		АН	23rd		ГП. (303) 4∠4-0001 support@ja-pe.com consutmo •sтячстики резки •FACA
/HTA-14H	NVTH18	14	12	6	1994	2338	1181	1631			Ň		
/HTA-16H	NVTH20	16	14	6	2215	2598	1312	1812		A A	300	3172 /2	ר) . ו oddi
/HTA-20H	NVTH24	20	16	6	2437	2858	1444	1994		2	88	33.93	Sus Sus
/HTA-22H	NVTH26	22	18	6	2658	3117	1575	2175	Ļ Ļ				
/HTA-24H	NVTH28	24	-	1/2"					N N	100		ر	
/HTA-26H	NVTH30	26	3/E	3/8" 3/8"					VTH8	- N		n ∎t	
/HTA-32H	NVTH36	32	1-144	0 2		1-3/4"			L Z	ORS		Stre	3301:
/HTA-44H	NVTH48	44	1-1/4"				-112"	-		NECT			, FL.
				_ o _ · o <u>→ O O O O O O O O O O _ </u>		SIDE VIE 20 GA. SE		-	SERIES NVSNP, N	NVSIA AND NVHIA SIEEL WOOD CONNECTORS			Hialeah, FL. 33013
			NOTES:						BVS	BS		z	
			2. NAILS 3. NAILS 4. **FOR	ENERAL NOTES, SHEET 1. ARE NECESSARY IN STRA THROUGH CHORDS SHAL HIGHER UPLIFT LOADS, C D ON MINIMUM 2500 PSI C	PS AND SEAT TO L NOT FORCE TH ONCRETE SHALL	E TRUSS PLATE.	LOADS.		1-23 drawn by:	24 check by:	NOIS	DESCRIPTION	
1/2" 1-1/2" 1/2"	-	2-1/2"							JA-2029.1-23	01/11/2024	REVISION	ВΥ	
- • • 1/4*	1/4"	-112-							drawing no.			DATE	
112	• • <u></u>	1/2*							drawi	date:		ON	
HOLES DIA.	1/2" 1/2" 3/4" 2-1/2" 9"	HOLES DIA. 3/8"				as compl Building NOA-No. Expiratio	Čode 24-	ISED the Florida 0213.05 /30/2030	A State of the sta	AD AHAM		Digita DigAdel Navad	4 Abmad 92 72.06 52 •
20	GA. SEAT	I				By 💋 Miami-Da	de Produc	ct Control		5		5	OF 5