



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Twin City Fan Companies, Ltd.
5959 Trenton Lane North
Minneapolis, MN 55442

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series VC and VCU/VCUB Rooftop and Wall Mounted Aluminum Exhaust Fans

APPROVAL DOCUMENT: Drawing No. **500024054**, titled "VC/VCU/VCUB Summary" sheets 1 through 13 of 13, dated 10/18/2022, with revision F dated 03/07/2024, prepared by Twin City Fan Companies, Ltd., signed and sealed by Wayne K. Helmila, P.E. on 05/09/2024, bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, Elkton, SD, model/series and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

LIMITATION: This fan cannot be installed within the ridge area, FBC 1523.6.5.2.13.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises** NOA # **23-0918.01** consists of this page 1 and evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**




05/13/24

NOA No. 24-0314.04
Expiration Date: October 26, 2028
Approval Date: April 25, 2024
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. Evidence submitted under NOA # 23-0918.01 and new

A. DRAWINGS

1. Drawing No. **500024054**, titled “VC/VCU/VCUB Summary” sheets 1 through 13 of 13, dated 10/18/2022, with revision F dated 03/07/2024, prepared by Twin City Fan Companies, Ltd., signed and sealed by Wayne K. Helmila, P.E. on 05/09/2024.

B. TESTS “Submitted under NOA # 23-0918.01”

1. Test report on 1) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94 2) Large Missile Impact Test per FBC, TAS 201-94 along with marked-up drawings and installation diagram of three Series/Model VC-120, VCU-085 and VCUB-197 Aluminum Roof Fans, prepared by Stork UL Laboratory Canada Inc., Test Report No. **IM-00009-A**, dated 09/14/2023, signed and sealed by Alexis Spyrou, P.E.

C. CALCULATIONS “Submitted under NOA # 23-0918.01”

1. Anchor verification calculations, prepared by Rice Engineering, dated 08/07/2023, signed and sealed by Wayne K. Helmila, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS


1. 3M Acrylic and Epoxy Adhesive datasheets.

“Submitted under NOA # 23-0918.01”

2. Statement letter of code conformance to the 7th edition (2020) and 8th edition (2023) of the FBC, issued by Rice Engineering, dated 10/24/2023, signed and sealed by Wayne K. Helmila, P.E.
3. Statement letter of no financial interest issued by Rice Engineering, dated 08/24/2023, signed and sealed by Wayne K. Helmila, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 24-0314.04
Expiration Date: October 26, 2028
Approval Date: April 25, 2024



VC SIZE	A	B	C	D	E	F	G	WEIGHT.(LB)
077	19.50	17.00	12.47	14.87	1.88	4.31	9.17	44
083	19.50	17.00	12.47	14.87	1.88	4.31	9.17	40
085	19.50	17.00	12.47	14.87	1.88	4.31	9.17	40
089	22.00	17.00	15.47	17.44	2.67	5.57	9.06	46
098	22.00	17.00	15.47	17.44	2.67	5.57	9.06	46
112	22.00	17.00	15.47	17.44	2.67	5.57	9.06	48
120	22.00	17.00	15.47	17.44	2.67	5.57	9.06	48


NOTES:

1. MODEL VC HAVE BEEN SUCCESSFULLY TESTED IN ACCORDANCE WITH THE MIAMI-DADE TEST PROTOCOL TAS-201 (LARGE MISSILE IMPACT) AND TAS-202 (STATIC LOADING).
2. THIS FAN HAS NOT BEEN TESTED FOR WIND DRIVEN RAIN PER FBC, TAS 100(A).
3. THIS APPROVAL IS FOR THE STRUCTURAL PERFORMANCE AND IMPACT RESISTANCE ONLY. INTERIOR MECHANISM AND/OR ELECTRICAL CIRCUITRY ARE OUTSIDE THE SCOPE OF THIS APPROVAL.
4. ROOF STRUCTURE MUST BE DESIGNED TO WITHSTAND THE WEIGHT AND LOADING TRANSMITTED BY ROOF TOP FANS. FASTENERS SHALL BE AS SPECIFIED AND INSTALLED AS DETAILED.
5. DESIGN TESTING AND INSTALLATION CONFORMS TO THE FLORIDA BUILDING CODE 7TH EDITION (2020) AND FLORIDA BUILDING CODE 8TH EDITION (2023).
6. FAN CURBS MUST BE ANCHORED TO ROOF FRAMING MEMBERS AND NOT TO THE ROOFING SYSTEM.
7. DRIL-FLEX SELF DRILLING SCREWS AND WOOD SCREWS TO BE SEALED WITH PROSOCO LIQUID FLASHING OR EQUAL.

DRAWN BY SM		F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"		
DATE 10/18/22		REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION		
APP BY SM		<div><div><div><div></div><div></div></div><div>TCF</div><div>TWIN CITY FAN</div></div><div>5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED</div></div>							
DATE 10/18/22									
		TITLE							
		VC SUMMARY							
		MIAMI-DADE APPROVAL							
<div><div><div></div><div></div></div><div>3RD ANGLE PROJECTION</div></div>		DRAWING NO. 500024054				ROW	ITEM	SHEET	REV.
						-	-	1 OF 13	F

For Miami-Dade Product Control


Professional Engineer Seal & License




Florida Firm No & Contact Information



RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

Digital Signature Data

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By 
Miami-Dade Product Control




DESIGN LIMITS	
MAX: DESIGN LOAD:	±150 psf (7.18 kPa)
MAX: OVERALL UNIT HEIGHT:	17.30 in (0.44 m)
MAX: ENCLOSURE DIAMETER:	22.00 in (0.56 m)



For Miami-Dade Product Control

Professional Engineer Seal & License





Florida Firm No & Contact Information

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

Digital Signature Data

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By *[Signature]*
Miami-Dade Product Control

DRAWN BY SM		F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"			
DATE 10/18/22		REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION			
APP BY SM		<div></div>					<div>5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED</div>			
DATE 10/18/22										
		TITLE								
		VC SUMMARY								
		MIAMI-DADE APPROVAL								
<div> 3RD ANGLE PROJECTION</div>	DRAWING NO. 500024054					ROW	ITEM	SHEET	REV.	
						-	-	2 OF 13	F	

DRIL-FLEX SELF DRILLING SCREWS AND WOOD SCREWS TO BE SEALED WITH PROSOCO LIQUID FLASHING OR EQUAL

FASTENER TABLE				
VC SIZE	MINIMUM NUMBER OF FASTENERS PER SIDE TO ATTACH CURB TO ROOF STRUCTURE			MIN. NUMBER OF FASTENERS PER SIDE TO ATTACH UNIT TO CURB
	STEEL ANCHORING	CONCRETE DECK ANCHORING	TIMBER ANCHORING	
077	3	3	3	4
083	3	3	3	4
085	3	3	3	4
089	3	3	3	4
098	3	3	3	4
112	3	3	3	4
120	3	3	3	4

CURB NOTES:

- ROOF CURB MODEL RCSF, RCSFV, RCSA OR EQUIVALENT WELDED CONSTRUCTION. NO WOOD NAILER.
 - MATERIAL: 18 GA GALVANIZED STEEL 0.063 ALUMINUM
- UNIT TO BE ATTACHED TO CURB USING #12-14 DRIL-FLEX SELF DRILLING SCREWS OR EQUIVALENT. LOCATED 3" FROM EACH CORNER AND THROUGH SUPPORT BRACKET (LOCATED 5" FROM EACH CORNER).
- ANY GAP BETWEEN THE CURB AND FASTENER SHALL BE FILLED BY THE INSTALLING CONTRACTOR WITH A SUITABLE CORROSION RESISTANT MATERIAL THAT ALLOWS THE FASTENERS TO BE INSTALLED WITHOUT CAUSING EXCESSIVE DISTORTION ON THE UNIT FLANGES.
- CURB MUST BE ATTACHED TO A STRUCTURAL MEMBER OF THE BUILDING
- CONCRETE DECK
 - CURB ANCHORAGE SHOULD BE INTO MINIMUM 3000 PSI CRACKED CONCRETE, WITH A MINIMUM SLAB DEPTH OF 4.75".
 - USE 1/2" DIA. STAINLESS STEEL HILTI KWIK BOLT TZ EXPANSION ANCHORS OR EQUIVALENT. ANCHORS SHALL HAVE A MINIMUM 2" EMBEDMENT. FASTENERS TO BE EQUALLY SPACED. MAXIMUM ON CENTER SPACING OF 10-1/4" WITH 4-1/2" MINIMUM SPACING AND 3-1/2" MINIMUM EDGE DISTANCE.
- STEEL ROOF STRUCTURE
 - SHOULD BE INTO MINIMUM 12 GA OR 1/8" THICK STEEL MEMBER.
 - USE #12-14 DRIL-FLEX SELF DRILLING SCREWS OR EQUIVALENT. SCREWS SHALL HAVE A MINIMUM THREAD ENGAGEMENT OF .1084". FASTENERS TO BE EQUALLY SPACED. MAXIMUM ON CENTER SPACING OF 10-1/4" WITH 11/16" MINIMUM SPACING AND 3/8" MINIMUM EDGE DISTANCE.
- TIMBER ROOF STRUCTURE
 - SHOULD BE MINIMUM S.G.=0.55
 - USE #10 ZINC PLATED WOOD SCREWS OR EQUIVALENT. SCREWS SHALL HAVE A MINIMUM THREAD PENETRATION OF 1-1/2". FASTENERS TO BE EQUALLYSPACED. MAXIMUM ON CENTER SPACING OF 16-3/4" WITH 3/4" MINIMUM SPACING, 3/4" MINIMUM EDGE DISTANCE AND 1.316" MINIMUM END DISTANCE.

For Miami-Dade Product Control

Professional Engineer Seal & License













RICE ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

Florida Firm No & Contact Information

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By
Miami-Dade Product Control

Digital Signature Data

F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"
REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION
					5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED
TITLE					
VC SUMMARY					
MIAMI-DADE APPROVAL					
DRAWING NO. 500024054		ROW -	ITEM -	SHEET 3 OF 13	REV. F




For Miami-Dade Product Control

Professional Engineer Seal & License

Florida Firm No & Contact Information


Digital Signature Data




RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By
Miami-Dade Product Control


DRAWN BY SM DATE 10/18/22 APP BY SM DATE 10/18/22	F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"
	REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION
						5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED
	TITLE VC SUMMARY MIAMI-DADE APPROVAL					
	DRAWING NO. 500024054		ROW	ITEM	SHEET	REV.
			-	-	4 OF 13	F




MOTOR COVER LINER STRUCTURAL ADHESIVE INSIDE MOTOR COVER




SHROUD LINER STRUCTURAL ADHESIVE INSIDE SHROUD



MOTOR COVER MOUNTING WITH SHROUD



SHROUD SUPPORT MOUNTING WITH BIRDSCREEN, CUTOFF & SUPPORT POST




SUPPORT POST MOUNTING WITH SHROUD & DECK PLATE

For Miami-Dade Product Control


Professional Engineer Seal & License



Florida Firm No & Contact Information

Digital Signature Data



RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By 
Miami-Dade Product Control

DRAWN BY SM DATE 10/18/22 APP BY SM DATE 10/18/22	F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"
	REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION
						5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED
TITLE VC SUMMARY MIAMI-DADE APPROVAL						
 3RD ANGLE PROJECTION	DRAWING NO. 500024054		ROW	ITEM	SHEET	REV.
			-	-	5 OF 13	F



For Miami-Dade Product Control


Professional Engineer Seal & License






Florida Firm No & Contact Information

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

Digital Signature Data

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By 
Miami-Dade Product Control

DRAWN BY SM		F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"		
DATE 10/18/22		REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION		
APP BY SM		<div></div>					<div>5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED</div>		
DATE 10/18/22									
		TITLE							
		VC SUMMARY							
		MIAMI-DADE APPROVAL							
<div> 3RD ANGLE PROJECTION</div>		DRAWING NO.				ROW	ITEM	SHEET	REV.
		500024054				-	-	6 OF 13	F
		-							




MODEL	SIZE	A	B	C	D	E	F	WEIGHT (LB)
VCU	085	17.00	15.13	15.42	22.00	0.20	18.00	60
VCU	089	20.00	15.13	15.42	22.00	0.20	18.00	65
VCU	098	20.00	15.13	15.42	22.00	0.20	18.00	65
VCU	110	20.00	15.13	15.42	22.00	0.20	18.00	65
VCU	112	20.00	15.13	15.42	22.00	0.20	18.00	65
VCU/VCUB	122	24.00	22.21	23.15	30.00	1.22	25.44	95
VCU/VCUB	124	24.00	22.21	23.15	30.00	1.22	25.44	95
VCU/VCUB	135	24.00	22.21	23.15	30.00	1.22	25.44	95
VCU/VCUB	140	24.00	22.21	23.15	30.00	1.22	25.44	100
VCU/VCUB	150	24.00	22.21	23.15	30.00	1.22	25.44	100
VCU/VCUB	157	24.00	22.21	23.15	30.00	1.22	25.44	100
VCU/VCUB	165	24.00	22.21	23.15	30.00	1.22	25.44	100
VCU/VCUB	177	30.00	26.98	25.63	36.13	3.20	30.00	140
VCU/VCUB	182	30.00	26.98	25.63	36.13	3.20	30.00	140
VCU/VCUB	197	30.00	26.98	25.63	36.13	3.20	30.00	140

NOTES:

1. MODEL VCU/VCUB HAVE BEEN SUCCESSFULLY TESTED IN ACCORDANCE WITH THE MIAMI-DADE TEST PROTOCOL TAS-201 (LARGE MISSLE IMPACT) AND TAS-202 (STATIC LOADING).
2. THIS FAN HAS NOT BEEN TESTED FOR WIND DRIVEN RAIN PER FBC, TAS 100(A).
3. THIS APPROVAL IS FOR THE STRUCTURAL PERFORMANCE AND IMPACT RESISTANCE ONLY. INTERIOR MECHANISM AND/OR ELECTRICAL CIRCUITRY ARE OUTSIDE THE SCOPE OF THIS APPROVAL.
4. ROOF STRUCTURE MUST BE DESIGNED TO WITHSTAND THE WEIGHT AND LOADING TRANSMITTED BY ROOF TOP FANS. FASTENERS SHALL BE AS SPECIFIED AND INSTALLED AS DETAILED.
5. DESIGN TESTING AND INSTALLATION CONFORMS TO THE FLORIDA BUILDING CODE 7TH EDITION (2020). AND FLORIDA BUILDING CODE 8TH EDITION (2023).
6. FAN CURBS MUST BE ANCHORED TO ROOF FRAMING MEMBERS AND NOT TO THE ROOFING SYSTEM.
7. DRIL-FLEX SELF DRILLING SCREWS AND WOOD SCREWS TO BE SEALED WITH PROSOCO LIQUID FLASHING OR EQUAL.

For Miami-Dade Product Control

Professional Engineer Seal & License




Florida Firm No & Contact Information

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092


Digital Signature Data

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By
Miami-Dade Product Control

	F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"	
DRAWN BY SM	REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION	
DATE 10/18/22	<div><div><div><div><div></div><div></div></div><div><div>T</div><div>C</div><div>F</div></div><div>TWIN CITY FAN</div></div></div><div>5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED</div></div>						
APP BY SM							
DATE 10/18/22							
	TITLE						
	VCU/VCUB SUMMARY						
	MIAMI-DADE APPROVAL						
<div><div><div><div></div><div></div></div><div><div></div><div></div></div></div><div>3RD ANGLE PROJECTION</div></div>	DRAWING NO. 500024054			ROW	ITEM	SHEET	REV.
				-	-	7 OF 13	F




DESIGN LIMITS	
MAX: DESIGN LOAD:	+75 / -125 psf (+3.59 / -5.98 kPa)
MAX: OVERALL UNIT HEIGHT:	30.00 in (0.76 m)
MAX: ENCLOSURE DIAMETER:	30.00 in (0.76 m)



SHROUD

VERTICAL SUPPORT POST

CURB CAP



SECTION B-B

MOTOR HOUSING

HORIZONTAL SUPPORT POST

DRAWN BY SM DATE 10/18/22 APP BY SM DATE 10/18/22 3RD ANGLE PROJECTION	F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"
	REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION
						5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED
	TITLE VCU/VCUB SUMMARY MIAMI-DADE APPROVAL					
	DRAWING NO. 500024054		ROW -	ITEM -	SHEET 8 OF 13	REV. F

For Miami-Dade Product Control

Professional Engineer Seal & License






Florida Firm No & Contact Information

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092



Digital Signature Data

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By
Miami-Dade Product Control



DRIL-FLEX SELF DRILLING SCREWS AND WOOD SCREWS TO BE SEALED WITH PROSOCO LIQUID FLASHING OR EQUAL

FASTENER TABLE				
VCU/VCUB SIZE	MINIMUM NUMBER OF FASTENERS PER SIDE TO ATTACH CURB TO ROOF STRUCTURE			MIN. NUMBER OF FASTENERS PER SIDE TO ATTACH UNIT TO CURB
	STEEL ANCHORING	CONCRETE DECK ANCHORING	TIMBER ANCHORING	
085	3	3	3	5
089	3	3	3	5
098	3	3	3	5
110	3	3	3	5
112	3	3	3	5
122	3	3	3	5
124	3	3	3	5
135	3	3	3	5
140	3	3	3	5
150	3	3	3	5
157	3	3	3	5
165	3	3	3	5
177	3	3	5	5
182	3	3	5	5
197	3	3	5	5



- CURB NOTES:**
- ROOF CURB MODEL RCSF, RCSFV, RCSA OR EQUIVALENT WELDED CONSTRUCTION. NO WOOD NAILER.
 - MATERIAL: 18 GA GALVANIZED STEEL
 - 0.063 ALUMINUM
 - UNIT TO BE ATTACHED TO CURB USING #12-14 DRIL-FLEX SELF DRILLING SCREWS OR EQUIVALENT. LOCATED 3" FROM EACH CORNER, THROUGH SUPPORT BRACKET (LOCATED 6" FROM EACH CORNER) AND CENTER OF UNIT. ANY GAP BETWEEN THE CURB AND FASTENER SHALL BE FILLED BY THE INSTALLING CONTRACTOR WITH A SUITABLE CORROSION RESISTANT MATERIAL THAT ALLOWS THE FASTENERS TO BE INSTALLED WITHOUT CAUSING EXCESSIVE DISTORTION ON THE UNIT FLANGES.
 - CURB MUST BE ATTACHED TO A STRUCTURAL MEMBER OF THE BUILDING
 - CONCRETE DECK
 - CURB ANCHORAGE SHOULD BE INTO MINIMUM 3000 PSI CRACKED CONCRETE, WITH A MINIMUM SLAB DEPTH OF 4.75".
 - USE 1/2" DIA. STAINLESS STEEL HILTI KWIK BOLT TZ EXPANSION ANCHORS OR EQUIVALENT. ANCHORS SHALL HAVE A MINIMUM 2" EMBEDMENT. FASTENERS TO BE EQUALLY SPACED. MAXIMUM ON CENTER SPACING OF 10-1/4" WITH 4-1/2" MINIMUM SPACING AND 3-1/2" MINIMUM EDGE DISTANCE.
 - STEEL ROOF STRUCTURE
 - SHOULD BE INTO MINIMUM 12 GA OR 1/8" THICK STEEL MEMBER.
 - USE #12-14 DRIL-FLEX SELF DRILLING SCREWS OR EQUIVALENT. SCREWS SHALL HAVE A MINIMUM THREAD ENGAGEMENT OF .1084". FASTENERS TO BE EQUALLY SPACED. MAXIMUM ON CENTER SPACING OF 16-3/4" WITH 11/16" MINIMUM SPACING AND 3/8" MINIMUM EDGE DISTANCE.
 - TIMBER ROOF STRUCTURE
 - SHOULD BE MINIMUM S.G. =0.55
 - USE #10 ZINC PLATED WOOD SCREWS OR EQUIVALENT. SCREWS SHALL HAVE A MINIMUM THREAD PENETRATION OF 1-1/2". FASTENERS TO BE EQUALLY SPACED. MAXIMUM ON CENTER SPACING OF 16-3/4" WITH 3/4" MINIMUM SPACING, 3/4" MINIMUM EDGE DISTANCE AND 1.316" MINIMUM END DISTANCE.


SECURE CURB TO ROOF FRAMING MEMBERS BY DRILLING 1/4" PILOT HOLES IN THE CURB FLANGE AT LOCATIONS SHOWN IN THE DIAGRAM. SEE TABLE FOR MINIMUM QUANTITY OF ANCHORS REQUIRED PER CURB SIDE.

For Miami-Dade Product Control

Professional Engineer Seal & License

Florida Firm No & Contact Information


Digital Signature Data





RICE ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By **Miami-Dade Product Control**


DRAWN BY SM		F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"		
DATE 10/18/22		REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION		
APP BY SM		<div><div><div></div><div></div><div></div></div><div>TCF</div><div>TWIN CITY FAN</div></div>					<div>5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED</div>		
DATE 10/18/22									
		TITLE							
		VCU/VCUB SUMMARY							
		MIAMI-DADE APPROVAL							
<div><div><div></div><div></div><div></div></div><div>3RD ANGLE PROJECTION</div></div>		DRAWING NO. 500024054			ROW	ITEM	SHEET	REV.	
		-			-	-	9 OF 13	F	




	F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"	
DRAWN BY SM	REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION	
DATE 10/18/22						5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED	
APP BY SM							
DATE 10/18/22							
	TITLE						
	VCU/VCUB SUMMARY						
	MIAMI-DADE APPROVAL						
 3RD ANGLE PROJECTION	DRAWING NO.			ROW	ITEM	SHEET	REV.
	500024054			-	-	10 OF 13	F
	-						





Digital Signature Data

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092


PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By 
Miami-Dade Product Control



THICKNESS TABLE					
VCU/ VCUB	CURB CAP	SHROUD	SHROUD SUPPORT	HORIZONTAL SUPPORT POST	VERTICAL SUPPORT POST
085	0.118	0.078	0.125	14 GA	14 GA
089	0.063				
098					
110					
112	0.118	0.098	0.125	14 GA	14 GA
122	0.063				
124					
135					
140					
150					
157					
165					
177					
182			0.19	12 GA	12 GA
197					


MODEL				
	6.93 MAX	8.43 MAX	8.43 MAX	6.73 MAX
MATERIAL	MIN. MATERIAL: SEE TABLE FOR THICKNESS, ALUMINUM 5052-H32			
SIZES	085	089 - 112	122 - 165	177 - 197
PART NAME	SHROUD SUPPORT			

DRAWN BY	SM
DATE	10/18/22
APP BY	SM
DATE	10/18/22
3RD ANGLE PROJECTION	

F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"
REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION
					5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED
TITLE VCU/VCUB SUMMARY MIAMI-DADE APPROVAL					
DRAWING NO. 500024054			ROW	ITEM	SHEET 11 OF 13
			-	-	F

For Miami-Dade Product Control

Professional Engineer Seal & License




05/09/2024
COA: 9090

Florida Firm No & Contact Information

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092



Digital Signature Data

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By 
Miami-Dade Product Control




01. SIZES 085-165 = 1/4-20 x 3/4" LG, TAPTITE SCREW, FLANGED, SERRATED
02. SIZES 085-165 = 1/4-20 RIVET NUT, KNURLED BODY



DRAWN BY SM	F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"		
DATE 10/18/22	REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION		
APP BY SM						5959 Trenton Lane N Minneapolis, MN 55442 ISO-9001:REGISTERED		
DATE 10/18/22								
	TITLE							
	VCU/VCUB SUMMARY							
	MIAMI-DADE APPROVAL							
 3RD ANGLE PROJECTION	DRAWING NO. 500024054				ROW	ITEM	SHEET	REV.
					-	-	12 OF 13	F

For Miami-Dade Product Control

Professional Engineer Seal & License



Florida Firm No & Contact Information

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com

Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092





Digital Signature Data

PRODUCT REVISED
as complying with the Florida
Building Code

NOA-No. 24-0314.04

Expiration Date 10/26/2028

By 
Miami-Dade Product Control



For Miami-Dade Product Control

Professional Engineer Seal & License

Florida Firm No & Contact Information

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

Digital Signature Data

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. 24-0314.04
Expiration Date 10/26/2028
By
Miami-Dade Product Control

REV	REV BY	REV DATE	APP BY	APP DATE	DESCRIPTION
F	SK	03/07/24	DH	03/07/24	REPLACED "EPOXY" WITH "STRUCTURAL ADHESIVE"

DRAWN BY	DATE	APP BY	DATE
SM	10/18/22	SM	10/18/22

TWIN CITY FAN

**5959 Trenton Lane N
Minneapolis, MN 55442
ISO-9001:REGISTERED**

TITLE
VCU/VCUB SUMMARY
MIAMI-DADE APPROVAL

DRAWING NO.	ROW	ITEM	SHEET	REV.
500024054	-	-	13 OF 13	F