



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Johns Manville Corporation**  
717 17th Street  
Denver, CO 80202

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: JM Single Ply Roofing Membranes and Accessories

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises and renews NOA No. 19-0220.03 and consists of pages 1 through 5.  
The submitted documentation was reviewed by Jorge L. Acebo.

02/13/25



**NOA No.: 24-0610.03**  
**Expiration Date: 02/27/30**  
**Approval Date: 02/13/25**  
**Page 1 of 5**

## ROOFING COMPONENT APPROVAL

<b>Category:</b>	Roofing
<b>Sub-Category:</b>	Roofing Membranes and Accessories
<b>Material:</b>	TPO & PVC

### SCOPE:

This approves **JM Single Ply Roofing Membranes and Accessories** as roofing components, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricanes Zone. Please refer to "Limitations" herein for limits of use.

### PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
JM TPO 45 <i>Manufacturing location #1</i>	45 mils thick	ASTM D6878 TAS 131	Polyester reinforced Thermoplastic Olefin single ply membrane.
JM TPO 60 <i>Manufacturing location #1</i>	60 mils thick	ASTM D6878 TAS 131	Polyester reinforced Thermoplastic Olefin single ply membrane.
JM TPO 80 <i>Manufacturing location #1</i>	80 mils thick	ASTM D6878 TAS 131	Polyester reinforced Thermoplastic Olefin single ply membrane.
JM TPO FB 115 <i>Manufacturing location #1</i>	60 mils thick	ASTM D6878 TAS 131	Polyester reinforced, fleece backed, Thermoplastic Olefin single ply membrane.
JM TPO FB 135 <i>Manufacturing location #1</i>	80 mils thick	ASTM D6878 TAS 131	Polyester reinforced, fleece backed, Thermoplastic Olefin single ply membrane.
JM TPO FB 150 <i>Manufacturing location #1</i>	60 mils thick	ASTM D6878 TAS 131	Polyester reinforced, heavy-fleece backed, Thermoplastic Olefin single ply membrane.
JM TPO FB 175 <i>Manufacturing location #1</i>	80 mils thick	ASTM D6878 TAS 131	Polyester reinforced, heavy-fleece backed, Thermoplastic Olefin single ply membrane.
JM TPO SA – 60 MIL <i>Manufacturing location #1</i>	60 mils thick	ASTM D6878 TAS 131	Polyester reinforced Thermoplastic Olefin single ply self-adhered membrane.
JM TPO Walkpad <i>Manufacturing location #1</i>	5/32" x 30" x 50'	Proprietary	Textured walkway protection membrane.
JM TPO Detail Membrane <i>Manufacturing location #1</i>	24" x 50'	TAS 131	Non-reinforced membrane for wrapping pipe flashings and vertical stacks and for waterproofing joints of JM TPO Coated Metal.
JM TPO Curb Flashing <i>Manufacturing location #1</i>	18" x 50'	TAS 131	60 mil TPO membrane for flashing curbs and parapet walls.
JM TPO Reinforced Cover Strip <i>Manufacturing location #1</i>	8" x 50'	TAS 131	60 mil TPO membrane strip use as a heat-weldable strip in mechanically fastened systems.
JM TPO Cover Tape <i>Manufacturing location #2</i>	6" x 100'	TAS 131	30 mil membrane with a factory-applied peel and stick adhesive tape used to strip in metal flanges.
JM TPO 10" Cover Tape <i>Manufacturing location #2</i>	10" x 100'	TAS 131	30 mil membrane with a factory-applied peel and stick adhesive tape used to strip in metal flanges.



## PRODUCT DESCRIPTION: (CONTINUED)

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
JM TPO Peel & Stick 6" RTS <i>Manufacturing location #2</i>	6" x 100'	TAS 131	45 mil TPO membrane strip with a 3" tape factory laminated along one edge.
JM TPO Peel & Stick 10" RPS <i>Manufacturing location #2</i>	10" x 100'	TAS 131	45 mil TPO membrane strip with a 3" tape factory laminated along one edge.
JM TPO Universal Corners <i>Manufacturing location #3</i>	Various	TAS 131	Pre-molded for easy installation of curb flashings or corner flashings on JM TPO-Coated Metal or JM TPO Membrane.
JM TPO T-Joint Patch <i>Manufacturing location #3</i>	4"	TAS 131	Non-reinforced membrane patch for covering t-joints and/or discs and fasteners.
JM TPO Pipe Boots <i>Manufacturing location #3</i>	1" x 6"	TAS 131	Cone-shaped stepping boots designed for flashing pipe penetrations.
JM TPO Peel & Stick Pipe Boots <i>Manufacturing location #3</i>	1" x 6"	TAS 131	Cone-shaped stepping boots designed for flashing pipe penetrations.
JM TPO Split Pipe Boot <i>Manufacturing location #4</i>	Various	TAS 131	Cone shaped stepping boots designed for flashing pipe penetrations.
JM Square Pipe Boots <i>Manufacturing location #4</i>	2" x 8" & 4" x 8"	TAS 131	Square shaped stepping boots designed for flashing pipe penetrations.
JM TPO Penetration Pocket <i>Manufacturing location #5</i>	7.5" x 6"	TAS 131	Two-piece molded pocket with a rigid vertical wall and preformed flanges.
JM TPO Coated Metal <i>Manufacturing location #6</i>	4' x 10'	Proprietary	JM TPO Membrane laminated onto galvanized steel.
JM PVC <i>Manufacturing location #7</i>	50 mil x roll width x 100' 60 mil x roll width x 100' 80 mil x roll width x 75'	ASTM D4434	PVC polyester reinforced membrane with DuPont™ Elvaloy® KEE. Available in 3.25', 5', 6.5', 10', and 12' rolls.
JM PVC Fleece Backed <i>Manufacturing location #7</i>	50 mil x roll width x 90' 60 mil x roll width x 90' 80 mil x roll width x 75'	ASTM D4434	PVC polyester reinforced membrane backed with a lightweight polyester fleece. Available in 6.33' and 12' rolls.
JM PVC SD Plus <i>Manufacturing location #7</i>	50 mil x roll width" x 100' 60 mil x roll width x 100' 80 mil x roll width x 75'	ASTM D4434	PVC polyester reinforced membrane. Available in 5' and 10' rolls.
JM PVC Detail Membrane <i>Manufacturing location #7</i>	Various	ASTM D4434	Non-reinforced PVC used for pipe and corner flashing.
JM PVC Detail Strip <i>Manufacturing location #7</i>	Various	ASTM D4434	PVC used to waterproof joints



## PRODUCT DESCRIPTION: (CONTINUED)

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
JM PVC Walkpad <i>Manufacturing location #7</i>	Various	ASTM D4434	Textured PVC Walkpad.
JM PVC Heavy-Duty <i>Manufacturing location #7</i>	Various	ASTM D4434	Textured PVC Walkpad.
JM PVC Profile <i>Manufacturing location #8</i>	1-1/2" wide x 1-1/4" high x 10' long	Proprietary	Non-reinforced, extruded PVC for simulating the aesthetics of standing seam metal roofing.
JM PVC Spine <i>Manufacturing location #8</i>	3/4" wide x 13/16" high x 7' long	Proprietary	Non-reinforced, extruded PVC for simulating the aesthetics of standing seam metal roofing.
JM PVC Split Pipe Boot <i>Manufacturing location #4</i>	Various	ASTM D4434	Reinforced PVC used to flash vent stacks and other round penetrations
JM PVC Coated Metal <i>Manufacturing location #6</i>	Various	ASTM D4434	JM PVC laminated onto galvanized steel for metal flashings and edge details.

## MANUFACTURING LOCATIONS:

1. Scottsboro, AL
2. Michigan Center, MI
3. Poplar Bluff, MO
4. Santa Rosa, CA
5. Carol Stream, IL
6. Taylor, PA
7. Pawtucket, RI
8. Canton, OH

## EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies LLC	JMC-319-02-01.1	TAS 131 / ASTM D6878	08/28/18
	507T0465	TAS 131 / ASTM D6878	12/04/24
	507T0466	TAS 131 / ASTM D6878	12/04/24
	1702T0001	ASTM D 4434	02/23/21
	1702T0010	ASTM D 4434	06/13/24

## LABELING:

All membranes and accessories or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



NOA No.: 24-0610.03  
Expiration Date: 02/27/30  
Approval Date: 02/13/25  
Page 4 of 5

## LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. **JM Single Ply Roofing Membranes and Accessories** are designed for use as specified within approved roofing system NOA assemblies.
3. This acceptance establishes the required physical properties testing and traceability of roofing membrane and accessory components listed in approved roofing applications. Minimum deck requirements shall be in compliance with applicable building code. **JM Single Ply Roofing Membranes and Accessories** shall be installed in strict compliance with applicable Building Codes, Product Approvals and Manufacturers' specifications and guidelines.
4. Change in materials or manufacturing process or location of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
5. **JM Single Ply Roofing Membranes and Accessories** may be used with any approved Roof Assembly Notice of Acceptance listing **JM Single Ply Roofing Membranes and Accessories** as a component part of an assembly in the Notice of Acceptance. If **JM Single Ply Roofing Membranes and Accessories** is not listed; a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE

