



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

Sun-Tek Manufacturing, Inc.  
10303 General Drive  
Orlando, FL 32824

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER- Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: ISFGII Skylight System

**APPROVAL DOCUMENT:** Drawing No. STI-00000298A-1, titled "ISFGII", sheet 1 & 2 of 2, prepared by Sun-Tek Manufacturing, Inc., dated January 23, 2019, signed and sealed by James D. Wells, Jr., P.E., on October 27, 2023, bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and the expiration date by the Miami-Dade County Product Control Section.

### MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA #23-1127.08** and consists of this page 1, evidence submitted pages E-1 and E-2 as well as approval document mentioned above.

The submitted documentation was reviewed by **Helmy A. Makar, P.E., M.S.**



*Helmy A. Makar*  
07/11/24

NOA No. 24-0624.05  
Expiration Date: 08/29/2029  
Approval Date: 07/11/2024  
Page 1

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**1. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 19-0528.02**

**A. DRAWINGS**

1. *Drawing No. STI-00000298A-1, titled "ISFGII", sheet 1 & 2 of 2, prepared by Sun-Tek, Inc., dated 01/23/19, signed & sealed by James D. Wells, Jr., P.E., on 07/29/19.*

**B. TESTS**

1. *Test Report on Large Missile Impact Test per PA 201, Cyclic Wind Pressure Test per PA 203 and Uniform Static Air Pressure Test per PA 202 of "Insulated Glass Skylight" prepared by National Certified Testing Laboratories, Report No. 210-4142-01, dated 03/04/19, signed and sealed by Douglas J. McDougall, P.E.*

**C. CALCULATIONS**

1. *Anchor Calculations for attachment of skylight to decking, dated 04/15/19, signed and sealed by James D. Wells, Jr., P.E.*

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *None.*

**F. STATEMENTS**

1. *An FBC 2017 edition Compliance Letter, prepared by J & L Wells Consulting LLC, dated May 20, 2019, signed & sealed by James D. Wells, Jr., P.E.*

**2. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 20-1123.14**

**A. DRAWINGS**

1. *Drawing No. STI-00000298A-1, titled "ISFGII", sheet 1 & 2 of 2, prepared by Sun-Tek, Inc., dated 01/23/19, signed & sealed by James D. Wells, Jr., P.E., on 11/10/2020.*

**B. TESTS**

1. *None.*

**C. CALCULATIONS**

1. *None.*

**D. QUALITY ASSURANCE**


1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *None.*

**F. STATEMENTS**

1. *FBC 2020 edition Compliance Letter, prepared by J & L Wells Consulting LLC, dated 11/10/2020, signed & sealed by James D. Wells, Jr., P.E.*

  
\_\_\_\_\_  
Helmy A. Makar, P.E., M.S.  
Product Control Section Supervisor  
NOA No. 24-0624.05  
Expiration Date: 08/29/2029  
Approval Date: 07/11/2024

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**3. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 23-1127.08**

**A. DRAWINGS**

1. *Drawing No. STI-00000298A-1, titled "ISFGII", sheet 1 & 2 of 2, prepared by Sun-Tek Manufacturing, Inc., dated January 23, 2019, signed and sealed by James D. Wells, Jr., P.E., on October 27, 2023.*

**B. TESTS**

1. *None.*

**C. CALCULATIONS**

1. *None.*

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *None.*

**F. STATEMENTS**

1. *FBC 2023 edition Compliance Letter, prepared by J & L Wells Consulting LLC, dated 11/16/2023, signed & sealed by James D. Wells, Jr., P.E.*

**4. NEW EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. *None.*

**B. TESTS**

1. *None.*

**C. CALCULATIONS**

1. *None.*

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *None.*

**F. STATEMENTS**

1. *FBC 2023 edition Compliance Letter, prepared by J & L Wells Consulting LLC, dated 11/15/2023, signed & sealed by James D. Wells, Jr., P.E.*




Helmy A. Makar, P.E., M.S.  
Product Control Section Supervisor  
NOA No. 24-0624.05  
Expiration Date: 08/29/2029  
Approval Date: 07/11/2024










J&L Wells Consulting LLC  
1453 Arbutus Circle  
Oviedo, FL 32765  
(407) 496-5489  
Certificate of Authorization  
No. 27162

Engineer of Record  
James D. Wells, Jr., P.E.  
Professional Engineer No. 53616



**PRODUCT RENEWED**  
as complying with the Florida  
Building Code  
Acceptance No. **24-0624.05**  
Expiration Date **07/11/2029**  
By *Heidi H. Miller*  
Miami State Product Control

**PRODUCT REVISED**  
as complying with the Florida  
Building Code  
Acceptance No. **23-1127.08**  
Expiration Date **08/29/2024**  
By *Heidi H. Miller*  
Miami State Product Control

**NOTE:**  
(1) ALL ROOFING DETAILS SHALL COMPLY WITH CHAPTER 15 OF THE FLORIDA BUILDING CODE 2023 EDITION  
(2) 4" MINIMUM DISTANCE FROM ANGLE LIP TO ROOF SURFACE IS FOR SINGLE OR B.U.R. WITHOUT INSULATION. FOR INSULATION AND TILE ROOF ADD TILE HEIGHT AND INSULATION THICKNESS TO 4".  
(3) ANCHORS TO BE MADE FROM NON-CORROSIVE MATERIAL COMPATIBLE WITH ALUMINUM.  
(4) NO ONE-THIRD INCREASE IN THE DESIGN PRESSURE WAS USED  
(5) TESTED TO TAS-201, TAS-202, TAS-203, ASTM 1886 AND ASTM 1996

REVISION	REVISION	PRODUCT NAME	ISFGII
BY: DATE:	BY: DATE:	DRAWN BY: JWF	DATE: 01/23/2019
DWG. NO. STI-00000298A-1		DWG. NO. STI-00000298A-1	
SUN-TEK MANUFACTURING, INC. 10303 GENERAL DRIVE ORLANDO, FL 32824			