



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Gordon Sales, Inc.
5023 Hazel Jones Road
Bossier City, LA 71111

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Gordon WinLok™ Aluminum Exterior Solid and Perforated Ceiling System

APPROVAL DOCUMENT: Drawing No. **S202040276**, titled "Miami Dade Soffit Assembly", sheets 1 through 6 of 6, dated 11/20/2020, prepared by Gordon Sales, Inc., signed and sealed by Wayne K. Helmila, P.E., on 12/04/2024, bearing the Miami-Dade County Product Control revision stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: None

LABELING: Each piece shall be permanently marked at not more than 4' o.c. with a number or marking and the packaging shall include the manufacturer's name or logo, city, state, model number or name, Miami-Dade County NOA number, test standards and net free area per FBC 1709.10.2 and 1709.10.3.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises** **NOA # 20-0713.01** and consists of this page 1 and evidence pages E-1 and E-2 as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**




12/17/24

NOA No. 24-0906.10
Expiration Date: December 30, 2025
Approval Date: December 26, 2024
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. Evidence submitted under NOA # 20-0713.01

A. DRAWINGS

1. Drawing No. **S202040276**, titled "Miami Dade Soffit Assembly", sheets 1 through 6 of 6, dated 11/20/2020, prepared by Gordon Sales, Inc., signed and sealed by Steven Uecke, P.E.

B. TESTS

1. Test reports on 1) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
2) Cyclic Wind Pressure Loading per FBC, TAS 203-94
3) Wind Driven Rain Resistance Test per FBC, TAS 100(A)-95
4) Tensile Strength Test per ASTM E8-16a
along with marked-up drawings of Aluminum Soffit Cluster, prepared by Intertek, Test Report No. **K3856.01-801-18 R2**, dated 07/15/2020, with revision dated 11/18/2020, signed and sealed by Tyler Westerling, P.E.
2. Net free ventilation area calculations for the ventilated soffit (11.36 % open), prepared by Intertek, Test Report No. **K3856.02-801-18 R0**, dated 08/04/2020, signed and sealed by Tyler Westerling, P.E.

C. CALCULATIONS

1. Attachment to structure calculations, prepared by Rexconn Design, dated 12/03/2020, signed and sealed by Steven Uecke, P.E.
2. Hanger attachment to testing chamber, prepared by Rexconn Design, dated 09/18/2020, signed and sealed by Steven Uecke, P.E.
3. Panel system structural calculations, prepared by Rexconn Design, dated 06/04/2020, signed and sealed by Steven Uecke, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of code conformance to the 6th edition (2017) and 7th edition (2020) FBC issued by Rexconn Design, dated 12/03/2020, signed and sealed by Steven Uecke, P.E.
2. Statement letter of no financial interest issued by Rexconn Design, dated 06/25/2020, signed and sealed by Steven Uecke, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 24-0906.10

Expiration Date: December 30, 2025
Approval Date: December 26, 2024

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

2. New evidence submitted

A. DRAWINGS

1. Drawing No. **S202040276**, titled “Miami Dade Soffit Assembly”, sheets 1 through 6 of 6, dated 11/20/2020, prepared by Gordon Sales, Inc., signed and sealed by Wayne K. Helmila, P.E., on 12/04/2024.

B. TESTS

1. None.

C. CALCULATIONS

1. Attachment to structure calculations, prepared by Rice Engineering, dated 10/24/2024, signed and sealed by Wayne K. Helmila, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS


1. None.

F. STATEMENTS


1. Statement letter of code conformance to the 8th edition (2023) of the FBC, issued by Rice Engineering, dated 09/02/2024, signed and sealed by Wayne K. Helmila, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 24-0906.10
Expiration Date: December 30, 2025
Approval Date: December 26, 2024




TOP VIEW
SCALE 1:15



SIDE VIEW
SCALE 1:18

BILL OF MATERIALS

ITEM	QTY
WinLok MAIN TEE, 144" LONG (MT144)	2
WinLok MAIN TEE, 48" LONG (MT48)	2
WinLok MAIN TEE, 142.55" LONG (MT142.55)	1
WinLok MAIN TEE, 46.55" LONG (MT46.55)	1
WinLok CROSS TEE, 58.55" LONG (CT58.55)	2
WinLok CROSS TEE, 28.55" LONG (MCT28.55)	14
2WAY CONNECTOR	4
3WAY CONNECTOR	16
4WAY CONNECTOR	7
COMPRESSION BARS	15
MOUNTING BRACKET	15

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0906.10
Expiration Date 12/30/2025
By 
Miami-Dade Product Control

RICE
ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092



12/04/2024
COA: 9090


*** DESIGN PRESSURE: +80 PSF/-80PSF**

WinLok™ IS A
TRADEMARK OF GORDON SALES, INC.
Patent No.: US 10,113,317 B1




5023 Hazel Jones Rd.
Bossier City, LA 71111
800.747.8954
GORDON-INC.COM
sales@gordon-inc.com

SHEET TITLE				UNITS: INCHES			
MIAMI DADE SOFFIT ASSEMBLY				SHEET	SALES ORDER	PATH & DRAWING NUMBER	
JOB NAME				1 of 6	-	S202040276	
CUSTOMER				COMP DATE	DRAWN BY	CHKD BY	CHK DATE
-				1/30/2020	ILC	RRR	11/20/2020
				DRAWING SCALE	AS NOTED	PLOTTED SCALE	SOFTWARE USED
						2:3	INVENTOR
							REVISION
							-




SECTION D
SCALE 1 : 2

NOTE: COMPRESSION BAR NOT SHOWN FOR CLARITY




SECTION E-E
SCALE 1 / 6

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0906.10
Expiration Date 12/30/2025
By *[Signature]*
Miami-Dade Product Control



DETAIL G
SCALE 1 / 2




DETAIL F
SCALE 1 / 2

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092




12/04/2024
COA: 9090



DETAIL H
SCALE 1 / 3

STRUCTURE MATERIAL	RECOMMENDED FASTENER FASTENER TYPE	MIN. EMBEDMENT	MIN. EDGE DIST.	MIN. END DIST.	SUBSTRATE DESCRIPTION (SUBSTRATES ARE DESIGNED BY OTHERS)	INSTALLATION NOTES
CONCRETE	(2) 3/8" DIA. HILTI KWIK HUS-EZ (KH-EZ) 316 STAINLESS STEEL	3 1/4"	4"	4"	4 3/4" MIN. THICK STRUCTALLY ATTACHED 3,000PSI CONCRETE, NORMAL WEIGHT AND CRACKED	PER ESR-3027
STEEL	(2) 1/4-20 DEWALT BI-FLEX FASTENERS	5/16"	1/2"	1/2"	5/16" MIN. THICK STRUCTURALLY ATTACHED ASTM A36 STEEL FY=36KSI AND FU=58KSI MIN.	PER ESR-4374
WOOD	(2) 1/2" DIA. 300 SERIES S.S. COND. CW LAG SCREWS	4 1/4"	2"	3 1/2"	(3) 2X MEMBERS LAYED FLAT AND STACKED 4 1/2" MIN. THICK STUCTURALLY ATTACHED SPF WOOD BLOOCKING S.G.=0.42 MIN.	PER NDS GUIDELINES



5023 Hazel Jones Rd.
Bossier City, LA 71111
800.747.8954
GORDON-INC.COM
sales@gordon-inc.com

SHEET TITLE
MIAMI DADE SOFFIT ASSEMBLY

UNITS: INCHES

SHEET
2 OF 6

SALES ORDER
-

PATH & DRAWING NUMBER
S202040276

CUSTOMER
-

COMP DATE
1/30/2020

DRAWN BY
ILC

CHKD BY
RRR


CHK DATE
11/20/2020

DRAWING SCALE
AS NOTED


PLOTTED SCALE
2:3

SOFTWARE USED
INVENTOR


REVISION
-




TOP VIEW
SCALE 1:8



SECTION G-G
SCALE 1:1



SIDE VIEW
SCALE 1:8




SECTION H-H
SCALE 1:1

- GENERAL NOTES:
- STANDARD TOLERANCES: (UNO)
CNC: 0.015"
EXTRUSION CUT: +0" -0.015"
SHEET METAL CUT: +0" -0.063"
SHEET METAL BEND: ±0.031"
MAX NON-PERFORATED BORDER
DIFFERENCE OF OPPOSING SIDES: 0.094"
RADII: ±0.125"
GENERAL: ±0.031"
ANGLE: ±0.5°
 - ALL NON-SPECIFIED ANGLES: 90°
 - ABBREVIATIONS:
UNO = UNLESS NOTED OTHERWISE
TYP = TYPICAL
() = REFERENCE
 - MATERIAL: ALUM 063 3003-H14
F_y = 21,000 PSI
F_u = 22,000 PSI
 - FINISH: MILL

WinLok™ IS A
TRADEMARK OF GORDON SALES, INC.
Patent No.: US 10,113,317 B1

RICE
ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092




12/04/2024
COA: 9090

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0906.10
Expiration Date 12/30/2025
By *[Signature]*
Miami-Dade Product Control


GORDON
SALES, INCORPORATED

5023 Hazel Jones Rd.
Bossier City, LA 71111
800.747.8954
GORDON-INC.COM
sales@gordon-inc.com


SHEET TITLE				UNITS: INCHES			
PANEL NP 30X96x.063				SHEET	SALES ORDER	PATH & DRAWING NUMBER	
JOB NAME				3 of 6	-	S202040276	
CUSTOMER				COMP DATE	DRAWN BY	CHKD BY	CHK DATE
-				1/30/2020	ILC	RRR	11/20/2020
				DRAWING SCALE		PLOTTED SCALE	SOFTWARE USED
				AS NOTED		2:3	INVENTOR
				REVISION			
				-			



COMPRESSION BAR (ISO VIEW)
SCALE 1:4




MOUNTING BRACKET (ISO VIEW)
SCALE 1 : 1



COMPRESSION BAR (SECTION VIEW)
SCALE 1: 1
0.125" ALUMINUM
6061-T6
Fy = 40,000 PSI
Fu = 45,000 PSI

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0906.10
Expiration Date 12/30/2025
By *[Signature]*
Miami-Dade Product Control




MOUNTING BRACKET (SIDE VIEW)
SCALE 1 : 1
0.25" ALUMINUM
6063-T6
Fy = 31,000 PSI
Fu = 35,000 PSI

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092




12/04/2024
COA: 9090


<div><div>GORDON®</div><div>SALES, INCORPORATED</div></div>	5023 Hazel Jones Rd. Bossier City, LA 71111 800.747.8954 GORDON-INC.COM sales@gordon-inc.com	SHEET TITLE						UNITS: INCHES							
		COMPRESSION BAR AND MOUNTING BRACKET						SHEET		SALES ORDER		PATH & DRAWING NUMBER			
		JOB NAME						4 OF 6		—		S202040276			
		CUSTOMER						COMP DATE	DRAWN BY	CHKD BY	CHK DATE	DRAWING SCALE	PLOTTED SCALE	SOFTWARE USED	REVISION
		—						1/30/2020	ILC	RRR	11/20/2020	AS NOTED	2:3	INVENTOR	—




ISO VIEW
SCALE 1 : 1



TOP VIEW
SCALE 1 : 1



FRONT VIEW
SCALE 1 : 1



SIDE VIEW
SCALE 1 : 1



12/04/2024
COA: 9090

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0906.10
Expiration Date 12/30/2025
By
Miami-Dade Product Control

GENERAL NOTES:

1. MATERIAL:

CLIP BASE AND TOP:
16GA STAINLESS STEEL
TYPE 316
F_y = 42,000 PSI
F_u = 84,000 PSI

SPRING:
16GA STAINLESS STEEL AISI
(ASTM A313) TYPE 316
TENSILE STRENGTH = 200,000 PSI
MODULUS OF ELASTICITY = 28 X 10⁶ PSI
SHEAR MODULUS = 1160080 GP_a
HARDNESS: C35-45


2. FINISH: 2B

WinLok™ IS A
TRADEMARK OF GORDON SALES, INC.
Patent No.: US 10,113,317 B1


GORDON
SALES, INCORPORATED

5023 Hazel Jones Rd.
Bossier City, LA 71111
800.747.8954
GORDON-INC.COM
sales@gordon-inc.com


SHEET TITLE				UNITS: INCHES			
JOB NAME				SHEET	SALES ORDER	PATH & DRAWING NUMBER	
CUSTOMER				5 of 6	—	S202040276	
COMP DATE	DRAWN BY	CHKD BY	CHK DATE	DRAWING SCALE	PLOTTED SCALE	SOFTWARE USED	REVISION
1/30/2020	ILC	RRR	11/20/2020	AS NOTED	2:3	INVENTOR	-




HANGER TAB
SCALE 1: 1
0.125" ALUMINUM
3003-H14
Fy = 21,000 PSI
Fu = 22,000 PSI



4-WAY CONNECTOR
SCALE 1 : 2
0.125" ALUMINUM
3003-H14
Fy = 21,000 PSI
Fu = 22,000 PSI



2-WAY CONNECTOR
SCALE 1 : 2
0.125" ALUMINUM
3003-H14
Fy = 21,000 PSI
Fu = 22,000 PSI



3-WAY CONNECTOR
SCALE 1 : 2
0.125" ALUMINUM
3003-H14
Fy = 21,000 PSI
Fu = 22,000 PSI

RICE


ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com


Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

GORDON SOFFIT PANELS HARDWARE

ITEM	DESCRIPTION	REFERENCE PAGE #	MATERIAL	Fy	Fu	Fs
WL1/4-20	1/4"-20 SHOULDER BOLT SS (USED TO INSTALL WinLok SPRING CLIP BRACKET ASSEMBLY)	SEE PAGE 5 OF 6	SS 18-8	42KSI	84KSI	42KSI
BDSW	5/16 BELLEVILLE WASHER SS	SEE PAGE 5 OF 6	SS 18-8	120KSI	150KSI	75KSI
1/4"-20 X 3/4 HEX HEAD	1/4"-20 X 3/4"HEX HEAD BOLT (A193)	SEE PAGE 2 OF 6	SS 18-8	42KSI	84KSI	42KSI
#12- 24 X 3/4"	DEWALT BI-FLEX FASTENERS WITH 3/4" MIN. SPACING AND 1/2" MIN. EDGE/END DIST.	SEE PAGE 2 OF 6	PER ESR-4374			



WinLok TEE PROFILE
(MAIN/CROSS TEE)
SCALE 1: 1
ALUMINUM ALLOY
6063-T6
Fy = 31,000
Fu = 35,000



12/04/2024
COA: 9090

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 24-0906.10

Expiration Date 12/30/2025

By 
Miami-Dade Product Control

GORDON
SALES, INCORPORATED

5023 Hazel Jones Rd.
Bossier City, LA 71111
800.747.8954
GORDON-INC.COM
sales@gordon-inc.com

SHEET TITLE				UNITS: INCHES			
WinLok TEE & CONNECTORS				SHEET	SALES ORDER	PATH & DRAWING NUMBER	
JOB NAME				6 OF 6	-	S202040276	
CUSTOMER				COMP. DATE	DRAWN BY	CHKD BY	CHK. DATE
-				1/30/2020	ILC	RRR	11/20/2020
				DRAWING SCALE	AS NOTED	PLOTTED SCALE	SOFTWARE USED
						2:3	INVENTOR
				REVISION			
				-			

WinLok™ IS A
TRADEMARK OF GORDON SALES, INC.
Patent No.: US 10,113,317 B1