



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Polyglass USA, Inc.
1111 W. Newport Center Drive
Deerfield Beach, FL 33442

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Polyglass BUR, Modified Bitumen and Synthetic Roofing Membranes and Accessories

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 21-1207.19 and consists of pages 1 through 8.
The submitted documentation was reviewed by Alex Tigera.

02/06/25



NOA No.: 24-1008.04
Expiration Date: 04/16/25
Approval Date: 02/06/25
Page 1 of 8

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Roofing Membranes and Accessories
Material: BUR and Modified Bitumen Roofing

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

APP MODIFIED BITUMEN ROOFING MEMBRANES

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Polybase V <i>Manuf. Loc. #1</i>	65' 8" x 3' 3- ³ / ₈ "	ASTM D6509, Type I	APP modified bitumen, fiberglass reinforced, base or interply sheet
Polybond <i>Manuf. Loc. #1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade S, Type I	Polyester reinforced APP base, ply or cap sheet with a burn off polyethylene back face and a smooth or sanded top surface.
Polyflex <i>Manuf. Loc. #1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade S, Type I	Polyester reinforced APP base, ply or cap sheet with a burn off polyethylene back face and a smooth or sanded top surface.
Polybond G <i>Manuf. Loc. #1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Polyester reinforced APP cap sheet with a burn off polyethylene back face and a granule top surface.
Polyflex G <i>Manuf. Loc..#1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Polyester reinforced APP cap sheet with a burn off polyethylene back face and a granule top surface.
Polyflex G FR <i>Manuf. Loc..#1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Fire-rated, polyester reinforced APP cap sheet with a burn off polyethylene back face and a granule top surface and fire retardant chemistry.
Polyfresko G <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Non-woven polyester reinforced, APP cap sheet with a burn off polyethylene back face and a granule top surface
Polyfresko G FR <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Fire-rated, non-woven polyester reinforced, APP cap sheet with a burn off polyethylene back face and a granule top surface and fire retardant chemistry
Polyflex SA Base <i>Manuf. Loc. #1</i>	66' 8" x 3' 3- ³ / ₈ "	ASTM D4601, Type II	Self-adhered, fiberglass reinforced, APP modified bitumen base sheet.
Polyflex SA P <i>Manuf. Loc. #1, #4</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface
Polyflex SA P FR <i>Manuf. Loc. #4</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Self-adhered, fire-rated, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface



APP MODIFIED BITUMEN ROOFING MEMBRANES

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Polyfresko G SA <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface
Polyfresko G SA FR <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6222, Grade G, Type I	Self-adhered, fire-rated, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface

SBS MODIFIED BITUMEN MEMBRANES

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Polyglass G2 Base <i>Manuf. Loc. #6</i>	108' x 3'	ASTM D4601, Type II	Asphalt coated fiberglass reinforced base sheet
Elastoshield VP HT <i>Manuf. Loc. #1, #2</i>	65' 8" x 3' 3- ³ / ₈ "	ASTM D6162, Grade S, Type III	SBS modified asphalt coated, fiberglass/polyester reinforced base or interply sheet
Elastoshield HT G <i>Manuf. Loc. #1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6162, Grade G, Type III	SBS modified asphalt coated, fiberglass/polyester reinforced cap sheet with a polyolefin or sand back face and a granule top surface
Elastoshield HT G FR <i>Manuf. Loc. #1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6162, Grade G, Type III	Fire-rated, SBS modified asphalt coated, fiberglass/polyester reinforced cap sheet with a polyolefin or sand back face and a granule top surface
Elastobase V <i>Manuf. Loc. #1</i>	65' 8" x 3' 3- ³ / ₈ "	ASTM D6163, Grade S, Type I	SBS modified asphalt coated, fiberglass reinforced base or interply sheet, with sand or poly film top and bottom surfaces
Elastoflex V <i>Manuf. Loc. #1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6163, Grade S, Type I	SBS modified asphalt coated, fiberglass reinforced base or interply sheet, with a burn off polyethylene or sanded back face and a sanded top surface
Elastobase P <i>Manuf. Loc. #1, #4</i>	65' 8" x 3' 3- ³ / ₈ "	ASTM D6164, Grade S, Type I	SBS modified asphalt coated, polyester reinforced base or interply sheet, with sand or poly top and bottom surfaces
Elastoflex S6 <i>Manuf. Loc. #1</i>	49' 3" x 3' 3- ³ / ₈ "	ASTM D6164, Grade S, Type I	SBS modified asphalt coated polyester reinforced interply sheet, with a burn off polyethylene or sanded back face and a polyethylene or sanded top surface
Elastoflex S6 HP <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade S, Type II	SBS modified asphalt coated, polyester reinforced base or interply sheet, with sand or poly top and bottom surfaces
Elastoflex S6 G <i>Manuf. Loc. #1, #2</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	Polyester reinforced SBS cap sheet, with granule top surface, and sand or burn-off bottom surface



SBS MODIFIED BITUMEN MEMBRANES

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Elastoflex S6 G FR <i>Manuf. Loc. #1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	Fire-rated, polyester reinforced SBS cap sheet, with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry
Elastoflex V G <i>Manuf. Loc. #1, #2</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6163, Grade G, Type I	Fiberglass reinforced SBS cap sheet, with granule top surface, and sand or burn-off bottom surface
Elastoflex V G FR <i>Manuf. Loc. #1, #2</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6163, Grade G, Type I	Fire-rated, fiberglass reinforced SBS cap sheet, with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry
Elastoshield TS G <i>Manuf. Loc. #1, #4</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	Polyester reinforced SBS cap sheet, with granule top surface, and sand or burn-off bottom surface
Elastoshield TS G FR <i>Manuf. Loc. #1, #4</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	Fire-rated, polyester reinforced SBS cap sheet, with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry
PolyAnchor HV <i>Manuf. Loc. #7</i>	65' 8" x 3' 3- ³ / ₈ "	ASTM D6163, Grade S, Type I	Fiberglass reinforced SBS anchor sheet
Polyfresko G SBS <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	SBS modified asphalt coated, polyester reinforced cap sheet, with a burn off polyethylene back face and a granule top surface
Polyfresko G SBS FR <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	Fire-rated, SBS modified asphalt coated, polyester reinforced cap sheet, with a burn off polyethylene back face and a granule top surface and fire retardant chemistry
Elastoshield TS <i>Manuf. Loc. #2</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	SBS modified asphalt coated, polyester reinforced cap sheet, with a burn off polyethylene back face and a sanded top surface
Polyfresko G SBS SA FR <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	Fire-rated, Self-adhered, SBS modified asphalt coated, polyester reinforced cap sheet, with granule top surface and fire retardant chemistry
Polyfresko G SBS SA <i>Manuf. Loc. #3</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Type I, Granule	Self-adhered, SBS modified asphalt coated, polyester reinforced cap sheet, with granule top surface and fire retardant chemistry

SBS SELF-ADHERING MODIFIED BITUMEN ROOFING MEMBRANES

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Elastobase SA <i>Manuf. Loc. #2</i>	65' 8" x 3' 3- ³ / ₈ "	ASTM D6163, Grade S, Type I & ASTM D4601, Type II	Self-adhered, fiberglass reinforced, SBS modified bitumen base membrane
Elastoflex SA V <i>Manuf. Loc. #1, #2, #4</i>	65' 8" x 3' 3- ³ / ₈ "	ASTM D6163, Grade S, Type I & ASTM D4601, Type II	Self-adhered, fiberglass reinforced, SBS modified bitumen base or interply membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V FR <i>Manuf. Loc. #1, #2, #4</i>	65' 8" x 3' 3- ³ / ₈ "	ASTM D6163, Grade S, Type I & ASTM D4601, Type II	Self-adhered, fire-rated, fiberglass reinforced, SBS modified bitumen base or interply membrane with a self-adhering back face and a smooth top surface
Elastoflex SA V PLUS <i>Manuf. Loc. #1, #4</i>	66' 8" x 3' 3- ³ / ₈ "	ASTM D6163, Grade S, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen base or interply membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V PLUS FR <i>Manuf. Loc. #1, #4</i>	66' 8" x 3' 3- ³ / ₈ "	ASTM D6163, Grade S, Type I	Self-adhered, fire-rated, fiberglass reinforced, SBS modified bitumen base or interply membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V Flashing Strips <i>Manuf. Loc. #3</i>	66' x 4" 66' x 6" 66' x 9" 66' x 13" 66' x 18"	ASTM D1970	Self-adhered, fiberglass reinforced, SBS modified bitumen base or interply membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA P <i>Manuf. Loc. #1, #4</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	Self-adhered, polyester reinforced, SBS modified bitumen cap sheet, with granule top surface
Elastoflex SA P FR <i>Manuf. Loc. #1, #4</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade G, Type I	Self-adhered, fire-rated, polyester reinforced, SBS modified bitumen cap sheet, with granule top surface
Elastoflex SA Base <i>Manuf. Loc. #2, #4</i>	49' 2" x 3' 3- ³ / ₈ "	ASTM D6164, Grade S, Type I	Self-adhered, polyester reinforced, SBS modified bitumen base membrane
Polyreflect <i>Manuf. Loc. #1</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D6164, Grade S, Type I	Self-adhered, polymer, SBS modified bitumen membrane with a reflective smooth top surface
Modifleece <i>Manuf. Loc. #3, #4</i>	49' 3" x 3' 3- ³ / ₈ "	ASTM D4601	Self-adhered, SBS modified bitumen base ply, with a fleece backing

BUILT-UP ROOFING MEMBRANES

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Elastovent <i>Manuf. Loc. #2</i>	32' 10" x 3' 3- ³ / ₈ "	ASTM D4897	SBS modified asphalt coated, fiberglass reinforced, venting base sheet, with a granule back face and a sanded top surface

SYNTHETIC

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Polyanchor <i>Manuf. Loc. #5</i>	250' x 48"	ASTM D4601, Type II	A polymer woven, high performance, synthetic base sheet

MANUFACTURING LOCATIONS:

1. Winter Haven, FL
2. Hazleton, PA
3. Fernley, NV
4. Waco, TX
5. Richmond, VA
6. Tuscaloosa, AL
7. Kanjiza, Serbia



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Trinity ERD	ASTM D6164	P37590.03.13-3A	05/06/2013
	ASTM D4601	P45940.09.13	09/04/2013
	ASTM D4601	P44370.10.13	10/04/2013
	ASTM D4601	P45970.05.14	05/12/2014
	ASTM D6164	P35660.10.14	10/03/2014
	ASTM D6162	SC5170.05.15	05/08/2015
	ASTM D6163	PLYG-P45440SC.03.15-2-R1	12/29/2015
	ASTM D6162	SC5170.12.15-1	12/29/2015
	ASTM D6163	PLYG-P45440SC.03.15-1-R1	02/19/2016
	NEMO ETC, LLC	ASTM D4897	4S-PLYG-18-002.11.18-2-R1
ASTM D6164		4S-PLYG-18-002.11.18-3	11/28/2018
ASTM D6162		4S-PLYG-18-002.01.19-B	01/25/2019
ASTM D6222		4S-PLYG-18-002.05.19-C	05/20/2019
ASTM D6222		4S-PLYG-18-002.05.19-D	05/20/2019
ASTM D6164		4S-PLYG-18-002.05.19-N	05/31/2019
ASTM D6164		4S-PLYG-18-002.08.19-I	09/06/2019
ASTM D6164		4S-PLYG-18-002.09.19-J	09/06/2019
ASTM D4601		4q-PLYG-19-SSMBB-02.A	12/13/2019
ASTM D6164		4q-PLYG-19-SSMBB-04.A	01/02/2020
ASTM D6164		4q-PLYG-19-SSMBB-04.B	01/02/2020
ASTM D6222		4S-PLYG-18-002.12.19-K-R1	01/17/2020
ASTM D6164		4S-PLYG-18-004.01.20.B	01/16/2020
ASTM D6163		4q-PLYG-19-SSMBB-02.B	01/31/2020
ASTM D6509		4q-PLYG-22-SSMBB-01.A	06/14/2023
ASTM D1970		4j-PLYG-21-SSUDL-09.A	02/14/2022
ASTM D1970		4j-PLYG-22-SSUDL-03.A	09/08/2022
ASTM D6163		4j-PLYG-23-SSUDL-05.C	11/13/2023
ASTM D6222		4q-PLYG-19-SSMBB-05.A-R1	07/03/2020
ASTM D6164		4q-PLYG-20-SSMBB-04.A	10/21/2020
ASTM D6163 & ASTM D4601		4q-PLYG-20-SSMBB-05.A	10/18/2021
ASTM D6164		4q-PLYG-20-SSMBB-06.A	09/28/2021
ASTM D6222		4q-PLYG-22-SSMBB-01.B	06/14/2023
ASTM D6222		4q-PLYG-22-SSMBB-01.C	06/14/2023
ASTM D6164		4q-PLYG-22-SSMBB-01.D	07/28/2023
ASTM D6164		4q-PLYG-22-SSMBB-01.E	06/20/2024
ASTM D6164		4q-PLYG-22-SSMBB-04.A	05/05/2023
ASTM D6163		4q-PLYG-23-SSMBB-01.A	12/01/2023
ASTM D6163		4q-PLYG-23-SSMBB-01.B	03/14/2024
ASTM D4601		4q-PLYG-23-SSMBB-02.A	07/06/2023
ASTM D6163		4S-PLYG-18-002.01.19-A-R1	01/24/2019
ASTM D6163 & ASTM D4601		4q-PLYG-22-SSMBB-01.F	08/20/2024
ASTM D6163		4q-PLYG-22-SSMBB-01.G	08/20/2024



LABELING:

All membranes and accessories or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



LIMITATIONS:

1. Fire classification is not part of this acceptance. Refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Polyglass BUR, Modified Bitumen and Synthetic Roofing Membranes and Accessories are designed for use as specified within approved roofing system NOA assemblies.
3. This acceptance establishes the required physical properties testing and traceability of roofing membrane and accessory components listed in approved roofing applications. Minimum deck requirements shall be in compliance with applicable building code. Polyglass BUR, Modified Bitumen and Synthetic Roofing Membranes and Accessories shall be installed in strict compliance with applicable Building Codes, Product Approvals and Manufacturers' specifications and guidelines.
4. Change in materials or manufacturing process or location of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
5. Polyglass BUR, Modified Bitumen and Synthetic Roofing Membranes and Accessories may be used with any approved Roof Assembly Notice of Acceptance listing Polyglass BUR, Modified Bitumen and Synthetic Roofing Membranes and Accessories as a component part of an assembly in the Notice of Acceptance. If Polyglass BUR, Modified Bitumen and Synthetic Roofing Membranes and Accessories is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval, provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

