



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Tubular Skylight, Inc.
753 Cattlemen Road.
Sarasota, FL 34232

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER- Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the High Velocity Hurricane Zone of the Florida building Code.

DESCRIPTION: Polycarbonate Domed Tubular Skylight

APPROVAL DOCUMENT: Drawing No. 14009, titled "Polycarbonate Impact Resistant Skylight System", sheets 1 through 4 of 4, prepared by R & S Professional Engineering, dated January 31, 2014, signed and sealed by Luis A. Rosario, P.E., on March 12, 2015 bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and the expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large & Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein and the dome shall be properly marked by GE Plastics.

RENEWAL of this NOA shall not be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA #24-0401.09** and consists of this page 1, evidence submitted pages E-1, E-2, E-3, E-4 and E-5 as well as approval document mentioned above.

The submitted documentation was reviewed by **Helmy A. Makar, P.E., M.S.**



Helmy A. Makar
12/12/24

NOA No. 24-1023.01
Expiration Date: 12/18/2029
Approval Date: 12/12/2024

Tubular Skylight, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL NOA #03-0728.01

A. DRAWINGS

1. *Drawing No. 03-318, sheets 1 through 4 of 4, titled "No Titled", prepared by Knezevich & Associates, Inc, dated 07/22/03, with last revision on 11/19/03, signed and sealed by V. J. Knezevich, P.E.*

B. TESTS

1. *Test report on Large Missile Impact Test per TAS 201, Cyclic Load Test per TAS 203 and Uniform Static Air Pressure Test per TAS 202, on "Polycarbonate Hemispherical Dome Skylights", specimens A1, A2, B1, C1, C2, D1 & D2. They were prepared by Construction Testing Corporation, report No. 03-016 dated 07/18/03, signed and sealed by Y. G. Kuri PE.*
2. *Test report on Large Missile Impact Test per TAS 201, Cyclic Load Test per TAS 203 and Uniform Static Air Pressure Test per TAS 202, on "Polycarbonate Hemispherical Dome Skylight", specimens A1, A2, B1, C1, C2, D1 & d2. They were prepared by Construction Testing Corporation, No. 03-016, dated 07/18/03, signed and sealed by Y. G. Kuri, PE.*
3. *Test report on Uniform Static Air Pressure Test per TAS 202 on "Polycarbonate Hemispherical Dome Skylight", specimen A2, C2 & D2. It was prepared by Construction Testing Corporation report No. 03-016S, dated 10/22/03, signed and sealed by Y. G. Kuri, PE.*

C. CALCULATIONS

1. *None.*

D. QUALITY ASSURANCE


1. *By Miami-Dade County Building Code Compliance Office.*

E. MATERIAL CERTIFICATIONS

1. *Notice of Acceptance No.03-0924.01 issued to General Electric Company on 11/13/03,expiring on 07/17/08.*

F. STATEMENTS

1. *Code compliance letter issued by Knezevich & Associates, Inc on 07/24/03, and signed by V. J. Knezevich, PE.*
2. *No financial interest letter issued by Knezevich & Associates, Inc. on 07/24/03, and signed by V. J. Knezevich, PE.*



Helmy A. Makar, P.E., M.S.
Product Control Section Supervisor
NOA No. 24-1023.01
Expiration Date: 12/18/2029
Approval Date: 12/12/2024

Tubular Skylight, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

2. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 09-0212.01

A. DRAWING

1. *None.*

B. TESTS

1. *None.*

C. CALCULATIONS

1. *None.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Building Code Compliance Office.*

E. MATERIAL CERTIFICATIONS

1. *None.*

3. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 13-1205.01

A. DRAWING

1. *None.*

B. TESTS

1. *None.*

C. CALCULATIONS

1. *None.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

E. MATERIAL CERTIFICATIONS

1. *None.*

F. STATEMENTS

1. *Florida Building Code, 2010 Edition, Code compliance letter issued by R & S Professional Engineering Services, LLC, dated February 05, 2014, signed and sealed by Luis A. Rosario, P.E.*



Helmy A. Makar, P.E., M.S.

Product Control Section Supervisor

NOA No. 24-1023.01

Expiration Date: 12/18/2029

Approval Date: 12/12/2024

Tubular Skylight, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

4. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 14-1028.03

A. DRAWING

1. *Drawing No. 14009, titled " Polycarbonate Impact Resistant Skylight System ", sheets 1 through 4 of 4, prepared by R & S Professional Engineering, dated January 31, 2014, signed and sealed by Luis A. Rosario, P.E., on 03/12/2015.*

B. TESTS

1. *Test report on Large Missile Impact Test per TAS 201, Cyclic Load Test per TAS 203 and Uniform Static Air Pressure Test per TAS 202, on "Polycarbonate Hemispherical Dome Skylight", prepared by Architectural Testing, Inc., report No. E3178.01-401-18 dated 01/15/15, signed & sealed by Shawn G. Collins, P.E.*

C. CALCULATIONS

1. *None.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

E. MATERIAL CERTIFICATIONS

1. *None.*

F. STATEMENTS

1. *FBC, 2010 Edition, Code compliance letter issued by R & S Professional Eng. Services, LLC, dated 02/05/14, signed & sealed by Luis A. Rosario, P.E.*

5. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 19-1015.13

A. DRAWING

1. *None.*

B. TESTS

1. *None.*

C. CALCULATIONS

1. *None.*

D. QUALITY ASSURANCE


1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

E. MATERIAL CERTIFICATIONS

1. *None.*

F. STATEMENTS

1. *FBC, 2017 Edition, Code compliance letter issued by R & S Professional Eng. Services, LLC, dated 09/24/2019, signed and sealed by Luis A. Rosario, P.E.*




Helmy A. Makar, P.E., M.S.
Product Control Section Supervisor
NOA No. 24-1023.01
Expiration Date: 12/18/2029
Approval Date: 12/12/2024

Tubular Skylight, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

- 6. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 21-0517.03**
- A. DRAWING**
1. *None.*
- B. TESTS**
1. *None.*
- C. CALCULATIONS**
1. *None.*
- D. QUALITY ASSURANCE**
1. *By Miami-Dade County Department of Regulatory and Economic Resources.*
- E. MATERIAL CERTIFICATIONS**
1. *None.*
- F. STATEMENTS**
1. *FBC, 2020 Edition, Code compliance letter issued by R & S Professional Eng. Services, LLC, dated 05/12/2021, signed and sealed by Luis A. Rosario, P.E.*
- 7. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 24-0401.09**
- A. DRAWING**
1. *None.*
- B. TESTS**
1. *None.*
- C. CALCULATIONS**
1. *None.*
- D. QUALITY ASSURANCE**
1. *By Miami-Dade County Department of Regulatory and Economic Resources.*
- E. MATERIAL CERTIFICATIONS**
1. *None.*
- F. STATEMENTS**
1. *FBC, 2023 Edition, Code compliance letter issued by R & S Professional Eng. Services, LLC, dated 03/12/2024, signed and sealed by Luis A. Rosario, P.E.*



Helmy A. Makar, P.E., M.S.
Product Control Section Supervisor
NOA No. 24-1023.01
Expiration Date: 12/18/2029
Approval Date: 12/12/2024

Tubular Skylight, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

8. NEW EVIDENCE SUBMITTED

A. DRAWING

1. *None.*

B. TESTS

1. *None.*

C. CALCULATIONS

1. *None.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

E. MATERIAL CERTIFICATIONS

1. *None.*

F. STATEMENTS

1. *FBC, 2023 Edition, Code compliance letter issued by R & S Professional Eng. Services, LLC, dated 03/12/2024, signed and sealed by Luis A. Rosario, P.E.*



Helmy A. Makar, P.E., M.S.
Product Control Section Supervisor
NOA No. 24-1023.01
Expiration Date: 12/18/2029
Approval Date: 12/12/2024

GENERAL NOTES:

1. THESE APPROVAL DOCUMENTS REPRESENT A POLYCARBONATE IMPACT RESISTANT SKYLIGHT SYSTEM ANALYZED WITH THE PROVISION SET FOR THE ISSUANCE OF A NOTICE OF ACCEPTANCE (NOA) BY MIAMI-DADE COUNTY PRODUCT CONTROL DIVISION FOR THE HIGH VELOCITY HURRICANE ZONE (HVHZ) OF THE FLORIDA BUILDING CODE.

2. SKYLIGHT DOMES SHALL BE VACUUM FORMED FROM CLEAR POLYCARBONATE SHEETS TO A DOME MINIMUM THICKNESS OF 0.093" OR 0.118" AS NOTED ON THESE DRAWINGS.

3. ALL SKYLIGHT DOME SYSTEMS DEPICTED IN THESE APPROVAL DOCUMENTS ARE RATED FOR THE FOLLOWING DESIGN PRESSURE:

MAX. POSITIVE (+) 90 P.S.F.
MAX. NEGATIVE (-) 120 P.S.F.

4. MATERIAL SPECIFICATIONS:

A) ALL POLYCARBONATE DOMES SHALL BE FABRICATED FROM GE LEXAN POLY-CARBONATE SHEET NUMBER 9034 AS APPROVED UNDER MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE NUMBER 00-0719.02. SYNTHETIC THERMOPLASTIC POLYMER TENSILE STRENGTH $F_y = 8,908$ P.S.I., FLEXURAL STRENGTH $E_{by} = 12,900$ P.S.I., FLEXURAL MODULUS $= 329,700$ P.S.I.

B) POLYESTER OUTER SEALS SHALL BE THOROUGHLY CURED CLOSED AND OPEN CELL FOAM, 2 LBS PER CUBIC FOOT MEETING UL94-HF-1 LISTING.

5. A 33% INCREASE IN ALLOWABLE STRESS HAS NOT BEEN USED IN THE DESIGN OF THIS PRODUCT.

6. DETERMINE THE POSITIVE & NEGATIVE DESIGN LOADS TO USE, WHEN REFERENCING THESE DOCUMENTS, IN ACCORDANCE WITH THE GOVERNING CODE AND GOVERNING WIND VELOCITY.

7. THESE APPROVAL DOCUMENTS ARE GENERIC AND DO NOT INCLUDE INFORMATION FOR SITE-SPECIFIC APPLICATION OF THIS SKYLIGHT SYSTEM.

8. THESE APPROVAL DOCUMENTS SHALL COMPLY WITH CHAPTER 61G15-23 OF THE FLORIDA ADMINISTRATIVE CODE.

9. THESE APPROVAL DOCUMENTS, ARE SUITABLE TO BE APPLIED BY THE CONTRACTOR PROVIDED THE CONTRACTOR DOES NOT DEVIATE FROM THE CONDITIONS DETAILED HEREIN AND THE CONTRACTOR VERIFIES THAT THE EXISTING STRUCTURE DOES NOT DEVIATE IN EITHER FORM OR MATERIAL FROM THAT DETAILED HEREIN.

10. ANY MODIFICATIONS OR ADDITIONS TO THESE APPROVAL DOCUMENTS WILL VOID THE APPROVAL DOCUMENTS.

11. WHEN THE SITE CONDITIONS DEVIATE FROM THESE APPROVAL DOCUMENTS, THE BUILDING OFFICIAL MAY ELECT ONE OF THE FOLLOWING OPTIONS:

A) REQUIRE THAT SITE SPECIFIC DOCUMENTS BE PREPARED, SIGNED, DATED AND SEALED BY A LICENSED ENGINEER OR REGISTERED ARCHITECT, WHICH DETAIL AND JUSTIFY THE DEVIATION. SAID DOCUMENTS SHALL BE SUBMITTED TO THE PRODUCT ENGINEER FOR REVIEW AS A CONDITION TO THE BUILDING OFFICIAL GRANTING THEIR APPROVAL.

B) REQUIRE THAT A ONE-TIME SITE SPECIFIC APPROVAL BE APPLIED FOR AND SECURED FROM THE MIAMI-DADE COUNTY PRODUCT CONTROL DIVISION.

WHEN THE SITE CONDITION DEVIATIONS OCCUR WITHIN THE HIGH VELOCITY HURRICANE ZONE AREAS ONLY OPTION "B" SHALL BE ACCEPTED BY THE BUILDING OFFICIAL.

12. PRODUCT SHALL BE PERMANENTLY LABELED AS FOLLOWS:

TUBULAR SKYLIGHT, INC.
SARASOTA, FLORIDA
MIAMI-DADE COUNTY PRODUCT APPROVAL

13. ALL METAL FLASHING SHALL BE 26 GA. (0.0179" MIN. THICKNESS) STEEL IN ACCORDANCE WITH ASTM A792 CQ WITH AN AZ60 HOT DIPPED ALUMINUM ZINC ALLOY COATING (GALVALUME).

14. ALL BOLTS, SCREWS AND WASHERS SHALL BE STAINLESS STEEL WITH A MINIMUM TENSILE STRENGTH OF 60 K.S.I., U.O.N.

15. ALL INSTALLATIONS OF THIS SKYLIGHT SYSTEM SHALL FOLLOW THESE APPROVED DOCUMENTS AND THE MANUFACTURER'S INSTALLATION INSTRUCTIONS.

16. ALL ROOFING DETAILS SHALL COMPLY WITH THE PROVISION OF CHAPTER 15 OF THE FLORIDA BUILDING CODE.

17. ALL SKYLIGHT DOMES SHALL BE INSTALLED TO PROVIDE A MINIMUM CLEARANCE OF 4" ABOVE THE FINISH ROOF SURFACE OR FINISH ROOF SINGLE-PLY MEMBRANE IN COMPLIANCE WITH THE PROVISIONS OF THE MIAMI-DADE COUNTY ROOFING PROTOCOL RAS No. 111, SECTION 9.3. FOR INSULATION AND ROOF TILE, ADD TILE HEIGHT AND INSULATION THICKNESS TO 4" MINIMUM HEIGHT.

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 24-0401-09
Expiration Date 12/18/2024
By *H. G. A. M. W.*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No 24-1023.01
Expiration Date 12/18/2029
By *H. G. A. M. W.*
Miami Dade Product Control

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 21-0517.03
Expiration Date 12/18/2024
By *H. G. A. M. W.*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No 14-1028.03
Expiration Date 12/18/2019
By *H. G. A. M. W.*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No 19-1015.13
Expiration Date 12/18/24
By *H. G. A. M. W.*
Miami Dade Product Control

R&S Professional Engineering
COA# 29251
Luis A. Rosano, P.E. #61828
Milan Slovák, P.E. #67628
3007254 Street View - Sarasota, FL 34232
941-447-7557 Fax: 941-755-7337 Email: rrosano@rspe.com

DOMES SKYLIGHT APPROVAL
TUBULAR SKYLIGHT INC.
753 CATTLEMEN ROAD.
SARASOTA, FL 34232


COPYRIGHT
© 2014
THIS DOCUMENT IS THE PROPERTY OF TUBULAR SKYLIGHT INC. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF TUBULAR SKYLIGHT INC.

DATE: 03/11/11
SCALE: NOTED
DRAWN BY: A. FINE
DATE: 03/11/11


REVISIONS	
NO.	DESCRIPTION
1	12/18/2019
2	12/18/2019
3	12/18/2019
4	12/18/2019
5	12/18/2019
6	12/18/2019
7	12/18/2019
8	12/18/2019
9	12/18/2019
10	12/18/2019
11	12/18/2019
12	12/18/2019
13	12/18/2019
14	12/18/2019
15	12/18/2019
16	12/18/2019
17	12/18/2019
18	12/18/2019
19	12/18/2019
20	12/18/2019
21	12/18/2019
22	12/18/2019
23	12/18/2019
24	12/18/2019
25	12/18/2019
26	12/18/2019
27	12/18/2019
28	12/18/2019
29	12/18/2019
30	12/18/2019

SHEET
10/14


MAR 12 2015




① STANDARD FLAT ROOF MOUNT (STD-F MODEL)
SCALE: 1-1/2" = 1' - 0"




③ POLYCARBONATE DOME PROFILE
(STANDARD & FLAT ROOF MOUNTS)
SCALE: 1-1/2" = 1' - 0"




④ POLYCARBONATE DOME PLAN
(STANDARD & FLAT ROOF MOUNTS)
SCALE: 1-1/2" = 1' - 0"




⑥ FLASHING PLAN
(STANDARD & FLAT ROOF MOUNTS)
SCALE: 1-1/2" = 1' - 0"



② SKYLIGHT ASSEMBLY
SCALE: 3" = 1' - 0"



⑤ DOME CLAMP STRAP
SCALE: 1-1/2" = 1' - 0"



⑦ FLASHING PROFILE
(STANDARD & FLAT ROOF MOUNTS)
SCALE: 1-1/2" = 1' - 0"

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 24-1027.01
Expiration Date 12/18/2029
By *H. G. A. Miller*
Miami Dade Product Control

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 21-0517.03
Expiration Date 12/18/2024
By *H. G. A. Miller*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 14-1028.03
Expiration Date 12/18/2019
By *H. G. A. Miller*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 19-1015.13
Expiration Date 12/18/24
By *H. G. A. Miller*
Miami Dade Product Control

R&S Professional Engineering
COA# 29251
□ Luis A. Rosado, P.E. #61528
□ Milan Slovák, P.E. #87628
20002801 Street View - Englewood, FL 33425
Tel: 407-555-7047 Fax: 407-555-7221 Email: rps@rspe.com

DOM SKYLIGHT APPROVAL:
TUBULAR SKYLIGHT INC.
753 CATTLEMEN ROAD.
SARASOTA, FL 34232


COPYRIGHT
© 2014

REVISIONS


REVISIONS

SHEET
2 OF 4


MAR 12 2015




1 STANDARD FLAT ROOF MOUNT (STD MODEL)
SCALE: 1-1/2" = 1'-0"




3 POLYCARBONATE DOME PROFILE
(STANDARD & FLAT ROOF MOUNTS)
SCALE: 1-1/2" = 1'-0"




4 POLYCARBONATE DOME PLAN
(STANDARD & FLAT ROOF MOUNTS)
SCALE: 1-1/2" = 1'-0"




5 FLASHING PLAN
(STANDARD ROOF MOUNT)
SCALE: 1-1/2" = 1'-0"



2 SKYLIGHT ASSEMBLY
SCALE: 3\"/>



6 DOME CLAMP STRAP
SCALE: 1-1/2" = 1'-0"



7 FLASHING PROFILE
(STANDARD ROOF MOUNT)
SCALE: 1-1/2" = 1'-0"

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 14-1028.03
Expiration Date 12/18/2019
By *Heidi A. Miller*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 19-1015.13
Expiration Date 12/18/2024
By *Heidi A. Miller*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 24-1023.01
Expiration Date 12/18/2029
By *Heidi A. Miller*
Miami Dade Product Control

R&S Professional Engineering
COAF 29251
Luis A. Rosado, P.E. #61828
Milan Slovak, P.E. #61628
1000 20th Street West, Tallahassee, FL 32305
TEL: 904-755-7157 FAX: 904-755-7227 EMAIL: info@rspe.com

DOM SKYLIGHT APPROVAL:
TUBULAR SKYLIGHT INC.
753 CATTLEMEN ROAD,
SARASOTA, FL 34232


COPYRIGHT
© 2014

NO. 1420
SCALE: NOTED
DRAWN BY: A. Miller
DATE: 01/14/14


REVISIONS		
NO.	DATE	DESCRIPTION

SHEET
30/4


MAR 12, 2015




1 LOW PROFILE FLAT ROOF MOUNT (LRM-C MODEL)
SCALE: 1-1/2" = 1' - 0"




2 POLYCARBONATE DOME PROFILE (LOW PROFILE FLAT ROOF MOUNT)
SCALE: 1-1/2" = 1' - 0"



3 POLYCARBONATE DOME PLAN (LOW PROFILE FLAT ROOF MOUNT)
SCALE: 1-1/2" = 1' - 0"




4 SKYLIGHT ASSEMBLY
SCALE: 3\"/>



DOME DIAMETER / RISE SCHEDULE	
CLEAR OPENING DIAMETER	MAXIMUM DOME RISE
6.25"	4.00"
9.50"	5.00"
14.50"	7.00"
22.00"	10.50"

5 60 MIL. POLYVINYL CHLORIDE SINGLE-PLY MEMBRANE FLASHING BY SEAMAN CORP. APPROVED BY MDC N.O.A. # 00-1208.02 (LOW PROFILE FLAT ROOF MOUNT)
SCALE: 1-1/2" = 1' - 0"



6 60 MIL. MEMBRANE FLASHING DETAIL
SCALE: HALF SIZE

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 19-1028.03
Expiration Date 12/18/2019
By *Healy A. Miller*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 19-1015.13
Expiration Date 12/18/2024
By *Healy A. Miller*
Miami Dade Product Control

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 24-06/01.09
Expiration Date 12/18/2024
By *Healy A. Miller*
Miami Dade Product Control

R&S Professional Engineering
COA# 29251
Luis A. Rosario, P.E. #61828
Milan Slovak, P.E. #67628
3300 4th Street West, Bradenton, FL 34205
888-447-7577 Fax 941-755-7277 Email: info@rspe.com

DOMES SKYLIGHT APPROVAL:
TUBULAR SKYLIGHT INC.
758 CATTLEMAN ROAD,
SARASOTA, FL 34232

COPYRIGHT
© 2014

NO. 1029
SCALE: NOTED
DRAWN BY:
A. Miller
DATE: 01-31-11

REVISIONS	
NO.	DESCRIPTION
1	AS NOTED

SHEET
1 OF 4

MAR 12 2015