



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Lanco & Harris Corp.
600 Mid Florida Drive
Orlando, FL 32824

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Lanco Ultra Siliconizer, Siliconizer 1000, Urethanizer and Coolguard Liquid Applied Roof Systems over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 24-0805.02 and consists of pages 1 through 8.

The submitted documentation was reviewed by Jorge L. Acebo.

03/13/25



NOA No.: 24-1106.03
Expiration Date: 10/10/29
Approval Date: 03/13/25
Page 1 of 8

ROOFING SYSTEM APPROVAL

<u>Category:</u>	Roofing
<u>Sub-Category:</u>	Liquid Applied Roof System
<u>Deck Type:</u>	Concrete
<u>Material:</u>	Elastomeric
<u>Maximum Design Pressure:</u>	-502.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1
Test Specification

<u>Product</u>	<u>Dimensions</u>		<u>Product Description</u>
Lanco Ultra Siliconizer	1, 5, gallons	ASTM D6083	A white acrylic based elastomeric coating membrane.
Lanco Siliconizer 1000	1, 5, gallons	ASTM D6694	A solvent free, single component, high solids, moisture-cure, 100% silicone white elastomeric coating membrane.
Lanco Urethanizer	1, 5, gallons	ASTM D6083	A 100% acrylic and urethane blend of high performance components, urethane ceramic rubberized elastomeric roof coating membrane.
Lanco Coolguard	1, 5, gallons	ASTM D6083	High performance roof coating, made from an acrylic urethane hybrid that is a 100% elastomeric membrane.

APPROVED INSULATIONS:

TABLE 2
Product Description

Product Name

N/A

**Manufacturer
(With Current NOA)**

N/A

APPROVED FASTENERS:

TABLE 3
Description

**Fastener
Number**

1.

Product

N/A

Dimension

N/A

**Manufacturer
(With Current NOA)**

N/A



NOA No.: 24-1106.03
Expiration Date: 10/10/29
Approval Date: 03/13/25
Page 2 of 8

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies LLC	LHMC-020-02-01	ASTM D6083	05/07/18
	1067T0020	ASTM D6694	04/12/24
	1067T0025	ASTM E108	07/03/24
	1067T0025.1	ASTM E108	07/03/24
	1067T0024	TAS 114-D	06/18/24
	1067T0024.1	TAS 114-D	06/18/24
	LHMC-018-02-01	ASTM D6083	06/13/18
	LHMC-021-02-01	ASTM D6083	03/09/18
	1067T0027	ASTM E108	09/18/24
	1067T0031	ASTM E108	10/25/24
	1067T0026	TAS 114-D	09/18/24
	1067T0032	TAS 114-D	10/25/24



APPROVED ASSEMBLIES:

Membrane Type:	Liquid Applied Membrane
Deck Type 3:	Concrete Decks, Non-Insulated
Deck Description:	2500 psi structural concrete or concrete plank
System Type F(1):	Lanco Ultra Siliconizer system applied directly to substrate

All General and System Limitations apply.

Substrate Preparation: Substrate shall be clean, dry, smooth, and free of voids, spalled areas, laitance, honeycombs, and sharp protrusions. Refer to manufacturer specifications for additional surface preparation requirements.

Base Coat: Apply a coat of Lanco Ultra Siliconizer at a minimum rate of 1.0 gal./ 50ft² onto the deck for 32 wet mils/ 17.3 dry mils per coat.

Must be back rolled when applied by Spray. First coat must be allowed to dry for 24 hours before proceeding.

Inspect identify and backfill any pin holing that may be present in the applied coat. Inspect surface area to confirm it is dry and free of all moisture, dirt, dust and debris.

Finish Coat: Apply a coat of Lanco Ultra Siliconizer at a minimum rate of 1.0 gal./ 50ft² onto the base coat for 32 wet mils/ 17.3 dry mils per coat.

Inspect identify and backfill any pin holing that may be present in the applied coat. Inspect surface area to confirm it is dry and free of all moisture, dirt, dust and debris

The Lanco Ultra Siliconizer Multi-Layer Coating System will result in a total minimum of 4 gallons per 100ft² resulting in no less than 32 mils dry film thickness.

Maximum Design Pressure: -502.5 psf. (See General Limitation #9)



Membrane Type: Liquid Applied Membrane
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(2): Lanco Siliconizer 1000 system applied directly to substrate

All General and System Limitations apply.

Substrate Preparation: Substrate shall be clean, dry, smooth, and free of voids, spalled areas, laitance, honeycombs, and sharp protrusions. Refer to manufacturer specifications for additional surface preparation requirements.

Base Coat: (Optional) Apply a coat of Lanco Siliconizer 1000 at a minimum rate of 1.0 gal./ 64ft² onto the deck for 25 wet mils/ 22 dry mils per coat..

Must be back rolled when applied by Spray. First coat must be allowed to dry for 24 hours before proceeding.

Inspect identify and backfill any pin holing that may be present in the applied coat. Inspect surface area to confirm it is dry and free of all moisture, dirt, dust and debris.

Finish Coat: Apply a coat of Lanco Siliconizer 1000 at a minimum rate of 1.0 gal./ 64ft² onto the deck for 25 wet mils/ 22 dry mils per coat.

Inspect identify and backfill any pin holing that may be present in the applied coat. Inspect surface area to confirm it is dry and free of all moisture, dirt, dust and debris

The Lanco Siliconizer 1000 (100% silicone) System will result in a total minimum of 1.5 gallons per 100ft² resulting in no less than 22 mils dry film thickness.

Maximum Design Pressure: -502.5 psf. (See General Limitation #9)



Membrane Type: Liquid Applied Membrane
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(3): Lanco Urethanizer system applied directly to substrate

All General and System Limitations apply.

Substrate Preparation: Substrate shall be clean, dry, smooth, and free of voids, spalled areas, laitance, honeycombs, and sharp protrusions. Refer to manufacturer specifications for additional surface preparation requirements.

Base Coat: Apply a coat of Lanco Urethanizer at a minimum rate of 1.0 gal./ 50ft² onto the deck for 32 wet mils/ 17.3 dry mils per coat..

Must be back rolled when applied by Spray. First coat must be allowed to dry for 24 hours before proceeding.

Inspect identify and backfill any pin holing that may be present in the applied coat. Inspect surface area to confirm it is dry and free of all moisture, dirt, dust and debris.

Finish Coat: Apply a coat of Lanco Urethanizer at a minimum rate of 1.0 gal./ 50ft² onto the deck for 32 wet mils/ 17.3 dry mils per coat.

Inspect identify and backfill any pin holing that may be present in the applied coat. Inspect surface area to confirm it is dry and free of all moisture, dirt, dust and debris

The Lanco Urethanizer System will result in a total minimum of 4.0 gallons per 100ft² resulting in no less than 32 mils dry film thickness.

Maximum Design Pressure: -502.5 psf. (See General Limitation #9)



Membrane Type: Liquid Applied Membrane
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(4): Lanco Coolguard system applied directly to substrate

All General and System Limitations apply.

Substrate Preparation: Substrate shall be clean, dry, smooth, and free of voids, spalled areas, laitance, honeycombs, and sharp protrusions. Refer to manufacturer specifications for additional surface preparation requirements.

Base Coat: Apply a coat of Lanco Coolguard at a minimum rate of 1.0 gal./ 50ft² onto the deck for 32 wet mils/ 17.3 dry mils per coat..

Must be back rolled when applied by Spray. First coat must be allowed to dry for 24 hours before proceeding.

Inspect identify and backfill any pin holing that may be present in the applied coat. Inspect surface area to confirm it is dry and free of all moisture, dirt, dust and debris.

Finish Coat: Apply a coat of Lanco Coolguard at a minimum rate of 1.0 gal./ 50ft² onto the deck for 32 wet mils/ 17.3 dry mils per coat.

Inspect identify and backfill any pin holing that may be present in the applied coat. Inspect surface area to confirm it is dry and free of all moisture, dirt, dust and debris

The Lanco Coolguard System will result in a total minimum of 4.0 gallons per 100ft² resulting in no less than 32 mils dry film thickness.

Maximum Design Pressure: -502.5 psf. (See General Limitation #9)

CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt and/or adhesives panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)

8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).

(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)

10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE