



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Sika Corporation
201 Polito Avenue
Lyndhurst, New Jersey 07071

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Sikalastic Vehicular Traffic 2900 System

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5.

The submitted documentation was reviewed by Alex Tigera.

03/06/25



NOA No.: 24-1126.02
Expiration Date: 02/27/30
Approval Date: 02/27/25
Page 1 of 5

WATERPROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Waterproofing
Materials: Polyurethane
Deck Type: Concrete
Maximum Design Pressure: -502.50 PSF

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sikalastic® P 280FS	4.5-gal pail, 49-gal drum	Proprietary	Sikalastic® P 280FS is an MMA solvent free, two component, 100% reactive, low viscosity primer.
Sikalastic® M 290FS	4.5-gal pail	ASTM C 957	Sikalastic® P 290FS is a polyurethane-modified methyl methacrylate (PMMA) waterproofing base coat. For use in the Sikalastic® Traffic 2900 system.
Sikalastic® TC 297FS	4.5-gal pail, 53.5 gal drum	ASTM C 957	Sikalastic® TC 297 FS is an MMA, solvent-free, two-component, 100% reactive intermediate coat. For use in the Sikalastic® Traffic 2900 System.
Sikalastic® TC 299FS	4.5-gal pail, 50-gal drum	ASTM C 957	Sikalastic® TC 299 FS is an MMA solvent-free, two-component, 100% reactive topcoat, available in pigmentable and clear version.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Specification</u>	<u>Product Date</u>
PRI Construction Materials Technologies	557T0014	Physical Properties	08/08/24
	557T0015	ASTM E108	06/18/24
	557T0016	TAS 114-D	06/18/24
Nelson Testing Laboratories	22-1297	ASTM C957	02/08/24



NOA No.: 24-1126.02
Expiration Date: 02/27/30
Approval Date: 02/27/25
Page 2 of 5

APPROVED APPLICATIONS:

Deck Type 1 Concrete Decks

Deck Description: Min. 3000 psi

System Type A: Sikalastic® Vehicular Traffic 2900 System

Substrate Preparation: Surface must be clean, dry and sound with an open texture. Remove dust, laitance, grease, curing compounds, bond inhibiting impregnations, waxes, and any other contaminants. All projections, rough spots, etc. should be dressed off to achieve a level surface prior to the application.

All concrete should be cleaned and prepared to achieve a laitance and contaminant free, open textured surface by blast cleaning or equivalent mechanical means (CSP 3-4 per ICRI guidelines).

Primer: Mix the Sikalastic® P 280 FS Primer with Sikalastic® 908 FS and Sikalastic® 918 FS. Apply Sikalastic® P 280 FS Primer with a flat squeegee or roller at approximately 100ft²/gal. and work well into the substrate to ensure adequate penetration and sealing and puddles are avoided. Allow Primer to dry tack free. Base Coat must be applied within 14 – 48 hours of primer application.

Base Coat: Mix the Sikalastic® M 290 FS with Sikalastic® 918 FS. Sikalastic® M 290 FS should be applied at a rate of 20ft²/gal using a notched squeegee or trowel and backroll using a phenolic resin core roller. Extend base coat over entire area including previously detailed cracks and control joints. Allow coating to cure a minimum of 3-4 hours at 70°F and 50% RH or until tack free before top coating.

Intermediate Coat: Mix the Sikalastic® TC 297 FS with Sikalastic® 918 FS. Sikalastic® TC 297 FS should be applied at a rate of 40ft²/gal, broadcast 16-30 mesh aggregate to refusal at 20-30 lbs. per 100ft² using a flat or notched squeegee and backroll using a phenolic resin core roller. Apply aggregate* evenly distributed at the rate of 10-15 lbs/100 sf - seeded immediately into wet coating and backrolled. Allow coating to cure a minimum of 3-4 hours at 70°F and 50% RH or until tack free between coats. Excess aggregate removed after cure.

Top-Coat: Mix the Sikalastic® TC 299 FS with Sikafloor® PGM 155 and Sikalastic® 918 FS. Remove all loose aggregate. Sikalastic® TC 299 FS should be applied at a rate of 80ft²/gal using a flat or notched squeegee and backroll using a phenolic resin core roller. Allow coating to cure a minimum of 3-4 hours at 70°F and 50% RH or until tack free between coats, and a minimum of 36 hours before opening to vehicular traffic.

Integrity Test: Required, and shall be performed in accordance with ASTM D 5957 by an approved lab. Water may be maintained for a period longer than 24 hours if required.

Inspection: Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.

Maximum Design Pressure: -502.5 psf (See General Limitation #9)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. A copy of the integrity test report described herein in accordance with ASTM D5957 shall be provided to the Building Official for review at time of final inspection.
3. Contractor shall submit to the Building Official for review the system specifications and details. Submission of these documents, as well as the proper application and installation of all materials shall be the sole responsibility of the contractor.
4. Flashings shall be installed according to the manufacturers published standard details, specific details, approved by Sika Corporation and shall be submitted to the Building Official for review.
5. All work shall be performed by a Contractor licensed to do roofing/waterproofing and be an applicator trained by Sika Corporation. Sika Corporation shall supply a list of approved applicators to the authority having jurisdiction.
6. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and the wind load requirements of applicable Building Code.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. A non-skid surfacing is required for all pedestrian areas, plaza decks or balconies.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. Sikalastic shall not be installed over lightweight insulating concrete.
11. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below



END OF THIS ACCEPTANCE

