



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Johns Manville Corporation
717 17th Street
Denver, CO 80202

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Johns Manville Built-Up Roofing Systems Over Wood Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 21-0303.15 and consists of pages 1 through 8.

The submitted documentation was reviewed by Jorge L. Acebo.

07/24/25



NOA No.: 25-0212.02
Expiration Date: 07/19/26
Approval Date: 07/24/25
Page 1 of 8

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Built-up Roofing
Materials:	Fiberglass
Deck Type:	Wood
Maximum Design Pressure:	-90 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1			
<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
GlasBase Plus	36" x 108'	ASTM D4601	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
PermaPly 28	36" x 106'	ASTM D4601	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
Ventsulation Felt	36" x 36'	ASTM D4897 Type II	Heavy duty fiber glass base sheet impregnated and coated on both sides with asphalt with or without fine mineral stabilizer. Surfaced on the bottom side with coarse mineral granules embedded in asphaltic coating.
GlasPly IV	36" x 180'	ASTM D2178 Type IV	Type IV asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
GlasPly Premier	36" x 180'	ASTM D2178 Type VI	Type VI asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
GlasKap	36" x 36	ASTM D3909	Asphalt impregnated and coated felt surfaced with mineral granules used as the top ply in conventional built-up roof membranes.
GlasKap Plus	39-3/8" x 34'	ASTM D3909	SBS Modified Asphaltic cap sheet used as the top ply in conventional built-up roof membranes.
DynaBase	39-3/8" x 49'2"	ASTM D6163	A glass reinforced SBS modified bitumen base sheet.
APPeX 4S	39-3/8" x 32'10"	ASTM D6222 Type I	APP modified asphalt, polyester reinforced, smooth surfaced membrane for use as a Base and/or Ply Sheet only.
JM MBR Bonding Adhesive	4.4 gal pails	Proprietary	A two-part, solvent free, elastomeric cold-application adhesive for installing SBS modified bitumen roof membranes.

APPROVED INSULATIONS:**TABLE 2**

Product Name	Product Description	Manufacturer (With Current NOA)
N/A	N/A	N/A

APPROVED FASTENERS:**TABLE 3**

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	UltraFast Fastener	Insulation fastener for wood and steel.	#12 x 8" max. Length, #3 Phillips head	Johns Manville
2.	UltraFast Metal Plate Recessed, or UltraFast Square Metal Plate or UltraFast Plate Metal (Round)	Galvalume AZ55 steel plate	3" round & 3" square	Johns Manville

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
FM Approvals	3009499	Class 4470	04/04/01
	3012974	Class 4450	06/03/02
	3037540	Class 4450	10/20/10
Exterior Research & Design LLC Trinity Engineering	10390A.12.97-1	TAS 114	02/10/98
UL LLC	R10167	UL 790	06/25/25
Independent Roof Testing & Consultants of South Florida	IRT 99004	TAS 114	02/10/99
PRI Construction Materials Technologies, LLC	JMC-107-02-01.11	ASTM D903 ASTM D1876 ASTM D5147 TAS 117(B) TAS 117(A) TAS 114(C)	03/14/23
PRI Construction Materials Technologies, LLC	507T0079	ASTM D3909	10/01/20
	507T0117	ASTM D4601	02/17/21
	507T0120	ASTM D2178	02/17/21
	507T0121	ASTM D2178	06/14/21
	507T0122	ASTM D4601	02/17/21
	507T0123	ASTM D4897	03/08/21
	507T0310	ASTM D3909	01/09/23
	507T0412.1	TAS 114(E)	09/23/24
	507T0438	TAS 114(E)	08/13/24
	507T0491	FM 4474(D) / TAS 114(J)	10/28/24
JMC-330-02-01	507T0105	ASTM D 6163	05/11/21
	ASTM D 6222		10/17/18
	507T0316	Proprietary	01/03/23

APPROVED ASSEMBLIES

Membrane Type: BUR

Deck Type 1: Wood, Non-Insulated

Deck Description: $1\frac{5}{32}$ " or greater plywood or wood plank decks

System Type E(1): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: Two plies GlasBase Plus, PermaPly 28 or Ventsulation Felt fastened to the deck as described below:

Fastening: Base sheet shall be lapped 4" and fastened with UltraFast Fastener and UltraFast Square Metal Plate 9" o.c. in the 4" lap and two rows staggered in the center of the sheet 12" o.c.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Membrane Type: BUR

Deck Type 1: Wood, Non-insulated

Deck Description: $\frac{19}{32}$ " or greater plywood or wood plank fastened with #12-3" Olympic STD screws 6" o.c.

System Type E(2): Base sheet mechanically fastened.

All General and System limitations apply.

Anchor sheet: GlasPly Premier base sheet applied to the deck with UltraFast # 12 screws with 3" plates spaced 8" o.c. in a 3" lap staggered in three rows 8" o.c. in the field.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Membrane Type: BUR

Deck Type 1: Wood, Non-Insulated

Deck Description: 19/32 CAT PS 1-19 CDX 40/20 span rated, 4-ply plywood attached to structural supports spaced 24" o.c. with 0.113" x 2-3/8" ring shank nails spaced 6" o.c. at the intermediate supports and board edges.

System Type E(3): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: Two plies PermaPly 28 fastened to the deck as described below:

Fastening: Base sheet shall be attached with 0.120" x 1-1/4" ring shank roofing nails and 32ga. x 1-5/8" diameter tin tabs installed 8" o.c. at the 4" wide side laps and 8" o.c. in three (3) equally spaced rows in the field of the roll.

Ply Sheet: Two or more plies of DynaBase adhered with JM MBR Bonding Adhesive applied at a rate of 50-70gal/100ft² or adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. and at the 3" wide side laps.

Surfacing: (Required if no cap sheet is used) Install the following:
1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Membrane Type: BUR

Deck Type 1: Wood, Non-Insulated

Deck Description: 19/32 CAT PS 1-19 CDX 40/20 span rated, 4-ply plywood attached to structural supports spaced 24" o.c. with 0.113" x 2-3/8" ring shank nails spaced 6" o.c. at the intermediate supports and board edges.

System Type E(4): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: Two plies PermaPly 28 fastened to the deck as described below:

Fastening: Base sheet shall be attached with 0.120" x 1-1/4" ring shank roofing nails and 32ga. x 1-5/8" diameter tin tabs installed 4" o.c. at the 4" wide side laps and 4" o.c. in three (3) equally spaced rows in the field of the roll.

Ply Sheet: Two or more plies of DynaBase adhered with JM MBR Bonding Adhesive applied at a rate of 50-70gal/100ft² or adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. and at the 3" wide side laps.

Surfacing: (Required if no cap sheet is used) Install the following:
1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -90 psf. (See General Limitation #7)

WOOD DECK SYSTEM LIMITATIONS:

1. A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE