



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Manta Roofing Products, LLC**  
**1835 Wright Ave.**  
**La Verne, CA 91750**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Manta Roof Coatings

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.

06/19/25



NOA No.: 25-0402.01  
Expiration Date: 06/19/30  
Approval Date: 06/19/25  
Page 1 of 3

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Cements, Coatings and Adhesives  
**Materials** Elastomeric

### SCOPE:

This approves **Manta Roof Coatings** as manufactured by Manta Roofing Products and as described in this Notice of Acceptance. These products have been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

### EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Ace Laboratories	DX02G4A	ASTM D6083	05/12/25
	DX13E4A	ASTM D6694	05/02/25
UL LLC	R41576	UL 790	04/23/25

### MANUFACTURING LOCATION

- Fort Lauderdale, FL

### PHYSICAL PROPERTIES OF COMPONENTS

**Trade name:** MantaCryl 415 White Diamond

**Specifications:** ASTM D6083

**Description:** An acrylic liquid applied coating membrane applied at application rates as listed below:

- Spray Polyurethane Foam; Apply 2 coats of MantaCryl 415 direct to substrate at 3.0 gal/100 ft<sup>2</sup>.
- Aged PVC Membrane Roof Systems; Apply primer ManatPrime 230 Bleed Blocker at 1 gallon per 100/ft<sup>2</sup>. Apply 2 coats of MantaCryl 415 to the substrate at 3.0 gal/100 ft<sup>2</sup>.
- New Granule APP Modified Bitumen Roofing Systems; Apply primer MantaPrime 230 Bleed Blocker at 1 gallon per 400-500 ft<sup>2</sup>. Apply 2 coats of MantaCryl 415 to the primed substrate at 3.0 gal/100 ft<sup>2</sup>.
- New Concrete\*; Apply 2 coats of MantaCryl 415 direct to substrate at 3.0 gal/100 ft<sup>2</sup>.
- New Galvanized steel; Apply primer MantaPrime 235 Multipurpose Primer at 1 gallon per 100 ft<sup>2</sup>. Apply 2 coats of MantaCryl 415 to the primed substrate at 3.0 gal/100 ft<sup>2</sup>.
- New Concrete\*; Apply primer MantaPrime 235 Multipurpose Prime at 1 gallon per 100 ft<sup>2</sup>. Apply 2 coats of MantaCryl 415 to the primed substrate at 3.0 gal/100 ft<sup>2</sup>.

**\*Note: See Limitation #1.**

**Container Size:** 5 and 55 gallons. Note all cautions on container label.

**Systems Approvals:** Methods of application and quantities shall comply with specific Roof Assembly, Product Control Notice of Acceptance.



NOA No.: 25-0402.01  
Expiration Date: 06/19/30  
Approval Date: 06/19/25  
Page 2 of 3

**Trade name:** MantaSil 430 HS Premium Silicone Coating

**Specifications:** ASTM D6694

**Description:** A silicone liquid applied coating membrane applied at application rates as listed below:

- Spray Polyurethane Foam; Apply MantaSil 430 direct to substrate at 1.5 gal/100 ft<sup>2</sup>.
- Granule SBS Modified Bitumen Roofing Systems; Apply MantaSil 430 to the substrate at 1.5 gal/100 ft<sup>2</sup>.
- New Concrete\*; Apply MantaSil 430 direct to substrate at 1.5 gal/100 ft<sup>2</sup>.
- New Concrete\*; Apply primer MantaPrime 235 Multipurpose Primer at 1 gallon per 400-500 ft<sup>2</sup>. Apply MantaSil 430 to the primed substrate at 1.5 gal/100 ft<sup>2</sup>.
- Aged Silicone Coating; Apply MantaSil 430 to the substrate at 1.5 gal/100 ft<sup>2</sup>.

**\*Note: See Limitation #1.**

**Container Size:** 5 and 55 gallons. Note all cautions on container label.

**Systems Approvals:** Methods of application and quantities shall comply with specific Roof Assembly, Product Control Notice of Acceptance.

#### **LIMITATIONS:**

1. **Manta Roof Coatings are not approved as and shall not be used as a Roof or Waterproofing System as required by the Florida Building Code Chapter 15 HVHZ.**
2. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
3. All products shall be applied in strict compliance with Manufacturer's published application instructions.
4. The MantaSil 430 MantaCryl 415 products shall not be applied in inclement weather conditions.
5. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code
7. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



**END OF THIS ACCEPTANCE**



NOA No.: 25-0402.01  
Expiration Date: 06/19/30  
Approval Date: 06/19/25  
Page 3 of 3