



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Canadian General-Tower Limited
52 Middleton Street
Cambridge, Ontario
Canada N1R 5T6

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Tower Single Ply PVC Roof Systems over Recover Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 20-0303.09 and consists of pages 1 through 6.
The submitted documentation was reviewed by Jorge L. Acebo.

06/05/25

NOA No.: 25-0430.05
Expiration Date: 05/06/30
Approval Date: 06/05/25
Page 1 of 6



ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply Roofing
Material: PVC
Deck Type: Recover
Maximum Design Pressure: See Specific Assemblies

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Tower PVC		ASTM D4434	Polyester reinforced PVC membrane
Tower PVC Fleeceback		ASTM D4434	Polyester reinforced PVC membrane with a non-woven polyester fleeceback.

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ACFoam-II	Polyisocyanurate Insulation	Atlas Roofing Corp.
ACFoam-III	Polyisocyanurate Insulation	Atlas Roofing Corp.
DensDeck Roof Board	Gypsum insulation	Georgia-Pacific Gypsum LLC
ENRGY 3	Polyisocyanurate Insulation	Johns Manville Corp.
SECUROCK Gypsum-Fiber Roof Board	Gypsum insulation	USG Corporation
Insulfoam EPS	Closed-cell, Type IX (min 1.8 pcf) expanded polystyrene.	Insulfoam, a Div. of Carlisle Construction Materials LLC
Multi-Max FA-3	Polyisocyanurate foam insulation	RMax Operating, Inc.

APPROVED FASTENERS/ADHESIVES:**TABLE 3**

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Dekfast DF-#15-PH3	Insulation and membrane fastener	Various	SFS Group USA, Inc.
2.	isofast PLT-R-2-3/8-BL	Galvalume AZ55 stress plate	2-3/8" round	SFS Group USA, Inc.
3.	OMG 2-3/8" Barbed XHD Plate	Galvalume AZ55 stress plate	2-3/8" round	OMG, Inc.
4.	OMG XHD	Insulation and membrane fastener	Various	OMG, Inc.
5.	CD-10	Membrane and Insulation Fastener	Various	OMG, Inc.
6.	OMG OlyBond 500	Polyurethane foam adhesive	Various	OMG, Inc.
7.	Pliobond 7008 Adhesive	Polyurethane adhesive	Various	Bostik, Inc.
8.	Millennium One Step Foamable Insulation Adhesive	Foam insulation adhesive	Various	H.B. Fuller Company
9.	ICP Adhesives CR-20	Polyurethane foam adhesive	Various	ICP Adhesives and Sealants

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
FM Approvals	FM 4470	3005937	11/23/99
	FM 4470	3005938	11/23/99
	FM 4470	2D5A9.AM	06/22/99
	FM 4470	3009502	12/21/00
	FM 4470	3031199	12/24/08
	FM 4470	3014692	08/05/03
	FM 4470	3009502	12/21/00
	FM 4470	3012321	07/29/02
	FM 4470	3014751	08/27/03
	FM 4470	3023458	07/18/06
	FM 4470	3032172	06/12/09
	FM 4470	3026128	08/04/06
UL LLC	UL 790	R18691	11/14/18
Nemo etc.	ASTM D4434	4r-CGT-19-SSTHP-01.A	02/19/20
	ASTM D4434	4r-CGT-19-SSTHP-01.B	02/19/20

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
FM Approval Deck Limitations		D	01/01/13

APPROVED ASSEMBLIES

Membrane Type: Single Ply, PVC

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi structural concrete or Minimum 22 gauge, type B, Grade 80 steel decking secured to minimum 0.25 in. thick structural steel supports spaced a maximum of 6 ft. o.c. with ITW Buildex Traxx/5 fasteners at maximum of 6" o.c. at each structural steel support. The deck side laps are secured with ITW Buildex Traxx/1 fasteners a maximum of 30" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D: Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ACFoam-II, ACFoam-III Minimum 1.3" thick	N/A	N/A
ENRGY 3 Minimum 1.4" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the membrane sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See membrane sheet below for fasteners and density.

Vapor Retarder: Any UL or FM approved vapor retarder may be installed on the deck or over the layer of insulation.

Barrier: None.

Membrane: Tower PVC or Tower PVC Fleeceback, mechanically fastened through the insulation as specified below:

Fastening #1: Install maximum 72" wide sheets with a 5" overlap fastened 12" o.c. using CD-10 or OMG XHD fasteners and OMG 2-3/8" Barbed XHD Plates, or Dekfast DF-#15-PH3 fasteners and isofast PLT-R-2-3/8-BL plates. The roof cover outer 1-1/2" side lap is heat welded.

Maximum Design Pressure –45 psf (See General Limitation #7)

Fastening #2: Install maximum 72" wide sheets with a 5" overlap fastened 6" o.c. using CD-10 or OMG XHD fasteners and OMG 2-3/8" Barbed XHD Plates, or Dekfast DF-#15-PH3 fasteners and isofast PLT-R-2-3/8-BL plates. The roof cover outer 1-1/2" side lap is heat welded.

Maximum Design Pressure –60 psf (See General Limitation #7)

Maximum Design Pressure:

See Fastening Options Above

RECOVER SYSTEM LIMITATIONS:

1. All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.
2. All assemblies listed herein shall be installed in compliance with the applicable sections of FBC 1521. Uplift performance of assemblies bonded to existing roofing system shall be verified per 1521.10. Uplift performance of assemblies mechanically attached through existing roofing system shall be verified per 1521.11.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE