



MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING

BUILDING CODE COMPLIANCE OFFICE
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

PRODUCT CONTROL NOTICE OF ACCEPTANCE

Eemax TM Inc.
472 Pepper Street
Monroe

CT 06468

CONTRACTOR LICENSING SECTION
(305) 375-2527 FAX (305) 375-2558

CONTRACTOR ENFORCEMENT SECTION
(305) 375-2966 FAX (305) 375-2908

PRODUCT CONTROL DIVISION
(305) 375-2902 FAX (305) 372-6339

Your application for Product Approval of:

EEMAX Electric Instantaneous Water Heater

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This approval shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at anytime from a jobsite or manufacturer's plant for quality control testing.

If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

Acceptance No.: 97-0723.01 (Revises No.: 94-0706.07)

Expires: 02/18/2003

Raul Rodriguez
Chief Product Control Division

THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL CONDITIONS

BUILDING CODE & PRODUCT REVIEW COMMITTEE

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director

Miami-Dade County
Building Code Compliance Office

Approved: 02/18/2000

1 of 3



Eemax TM, Inc.

ACCEPTANCE NO: 97-0723.01

APPROVED : FEB 18 2000

EXPIRES : FEB 18 2003

NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

1.0 SCOPE:

1.1 This renews and revises the Notice of Acceptance No. 94-0706.07 that was issued on 08/29/94. It approves electric instantaneous water heaters as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code (SFBC), 1994 Edition for Miami-Dade County, for the locations where are permitted by chapter 46 of the SFBC.

2.0 PRODUCT DESCRIPTION:

2.1 The Eemax Electric Instantaneous Water Heaters and its components shall be fabricated in strict compliance with the following documents: Drawings No. EX1, titled "Electric Tankless Water Heater", sheets 1 & 2 of 2, prepared by Eemax, Inc., dated 01/14/2000. They bear the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

3.0 LIMITATIONS:

3.1 Only those models listed on the approved drawings are part of this approval and they must be listed by Underwriters Laboratories, Inc.

4.0 INSTALLATION:

4.1 The Eemax Instantaneous Water Heaters and its components shall be installed in strict compliance with the approved drawings.

5.0 LABELING:

5.1 Each water heater shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved."

6.0 BUILDING PERMIT REQUIREMENTS:

6.1 Applications for building permit shall be accompanied by copies of the following:

6.1.1 This Notice of Acceptance including duplicate copies of the approved drawings, as identified in Section 2 of this Notice of Acceptance, clearly marked to show the model selected for the proposed installation.

6.1.2 Any other documents required by the Building Official or the South Florida Building Code in order to properly evaluate the installation of this system.




Candido Font, PE, Sr., Product Control Examiner
Product Control Division

Eemax TM, Inc.

ACCEPTANCE NO : 97-0723.01
APPROVED : FEB 18 2000
EXPIRES : FEB 18 2003

NOTICE OF ACCEPTANCE: STANDARD CONDITIONS

1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
 - a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;
 - b) The product is no longer the same product (identical) as the one originally approved;
 - c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;
 - d) The engineer who originally prepared, signed and sealed the required documentation initially submitted is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
 - a) Unsatisfactory performance of this product or process.
 - b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purpose.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer need not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 1, 2 and this last page 3.




Candido Font, PE, Sr. Product Control Examiner
Product Control Division

END OF THIS ACCEPTANCE

Eemax

Eemax Electric Instantaneous Water Heaters

"Single Point"



Model No.	Volts	kW	Amps
SP3012 ✓	120	3.0	25
SP3512 ✓	120	3.5	29
SP3208 ✓	208	3.0	14.4
SP4208 ✓	208	4.1	19.7
SP35 ✓	240	3.5	14.6
SP55 ✓	240	5.5	22.9
SP3277 ✓	277	3.0	10.8
SP4277 ✓	277	4.1	14.8

"Flow Controlled"



Model No.	Volts	kW	Amps
EX35 ✓	240	3.5	14.6
EX55 ✓	240	5.5	22.9
EX65 ✓	240	6.5	27
EX75 ✓	240	7.5	32
EX95 ✓	240	9.5	40
EX60 ✓	277	6.0	22
EX80 ✓	277	8.0	29
EX100 ✓	277	10.0	36

"Thermostatic"



Model No.	Volts	kW	Amps
EX35T ✓	240	3.5	14.6
EX55T ✓	240	5.5	22.9
EX65T ✓	240	6.5	27
EX75T ✓	240	7.5	32
EX95T ✓	240	9.5	40
EX60T ✓	277	6.0	22
EX80T ✓	277	8.0	29
EX100T ✓	277	10.0	36


Models Listed By UL File E86887 (M)

<p>For Office Use APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE DATE <i>February 18, 2000</i> BY <i>[Signature]</i> PRODUCT CONTROL DIVISION BUILDING CODE COMPLIANCE OFFICE ACCEPTANCE NO. <i>97-0723.01</i></p>	<p>Eemax Inc. PO Box 200, Botsford, CT 06404 Electric tankless Water Heater</p> <p>Drawing No. EX1 Date: 1/14/2000 Sheet 1/2</p>
--	--

Eemax


Eemax Electric Instantaneous Water Heaters

“Series Two”




Model No.	Volts	kW	Amps
EX144T ✓	240	15	60(2x30)
EX144T2 ✓	240	15	60(2x30)
EX144 ✓	240	15	60(2x30)
EX190T ✓	240	19	80(2x40)
EX190T2 ✓	240	19	80(2x40)
EX190 ✓	240	19	80(2x40)
EX160T ✓	277	16	58(2x29)
EX160T2	277	16	58(2x29)
EX160 ✓	277	16	58(2x29)
EX200T ✓	277	20	72(2x36)
EX200T2 ✓	277	20	72(2x36)
EX200 ✓	277	20	72(2x36)

“Three Phase”



Model No.	Volts	kW	Amps
EX180T3 ✓	208/120	18	50A per phase
EX180 ✓	208/120	18	50A per phase
EX240T3 ✓	208/120	24	67A per phase
EX240 ✓	208/120	24	67A per phase
EX180T3 ✓	480/277	18	22A per phase
EX180 ✓	480/277	18	22A per phase
EX240T3 ✓	480/277	24	29A per phase
EX240 ✓	480/277	24	29A per phase
EX320T3 ✓	480/277	32	38.5A per phase
EX320 ✓	480/277	32	38.5A per phase

“Digital Readout”



Model No.	Volts	kW	Amps
EX95TDR	240	9.5	40

Models Listed By UL File E86887 (M)

<p>For Office Use APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE DATE <u>February 18, 2000</u> BY <u>[Signature]</u> PRODUCT CONTROL DIVISION BUILDING CODE COMPLIANCE OFFICE ACCEPTANCE NO. <u>97-0723-01</u></p>	<p>Eemax Inc. PO Box 200, Botsford, CT 06404 Electric tankless Water Heater</p> <p>Drawing No. EX1 Date: 1/14/2000 Sheet 2/2</p>
--	---