



MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING

**BUILDING CODE COMPLIANCE OFFICE**  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908

**PRODUCT CONTROL NOTICE OF ACCEPTANCE**

**Trainor Glass Company**  
**3728 Prospect Avenue**  
**Riviera Beach FL 33404**

**CONTRACTOR LICENSING SECTION**  
(305) 375-2527 FAX (305) 375-2558

**CONTRACTOR ENFORCEMENT SECTION**  
(305) 375-2966 FAX (305) 375-2908

**PRODUCT CONTROL DIVISION**  
(305) 375-2902 FAX (305) 372-6339

Your application for Product Approval of:

**Series "TCW-251C" Aluminum Curtain Wall System-Impact**

under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This approval shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at anytime from a jobsite or manufacturer's plant for quality control testing.

If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

**Acceptance No.: 98-1103.02**

**Expires: 02/11/2003**

Raul Rodriguez  
Chief Product Control Division

**THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL CONDITIONS**

**BUILDING CODE & PRODUCT REVIEW COMMITTEE**

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.  
Director

Miami-Dade County  
Building Code Compliance Office

**Approved: 02/11/2000**

1 of 3



**Trainor Glass Company**

ACCEPTANCE No.: 98-1103.02

APPROVED : FEB 11 2000

EXPIRES : FEB 11 2003

**NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS**

**1. SCOPE**

- 1.1 This approves an aluminum curtain wall system, as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code (SFBC), 1994 Edition for Miami-Dade County, for the locations where the pressure requirements, as determined by SFBC Chapter 23, do not exceed the Design Pressure Rating values indicated in the approved drawings.

**2. PRODUCT DESCRIPTION**

- 2.1 The Series "TCW-251C" Aluminum Curtain Wall System (structurally glazed)- Small/Large Missile Impact Resistant and its components shall be constructed in strict compliance with the following documents: Drawing No. 6-7302, titled "TCW-251C Product Approval Drawing" Sheets 1 through 8 of 8 dated 01/13/2000, signed and sealed by Wm. M. Meyers, P.E., bearing the Miami-Dade County Product Control approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

**3. LIMITATIONS**

- 3.1 This approval applies to multiple unit applications of an aluminum curtain wall system, limited only to the maximum frame height (span) and mullion spacing; for the Design Pressure Rating shown approved drawing.

**4. INSTALLATION**

- 4.1 The aluminum curtain wall system and its components shall be installed in strict compliance with the approved drawings.
- 4.2 Hurricane protection system (shutters): to determine whether the installation of this unit requires a hurricane protection system or not, see notes in corresponding glazing detail in approved drawing.

**5. LABELING**

- 5.1 Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved".

**6. BUILDING PERMIT REQUIREMENTS**

- 6.1 Application for building permit shall be accompanied by copies of the following:
- 6.1.1 This Notice of Acceptance
- 6.1.2 Duplicate copies of the approved drawings, as identified in Section 2 of this Notice of Acceptance, clearly marked to show the components selected for the proposed installation.
- 6.1.3 Any other documents required by the Building Official or the South Florida Building Code (SFBC) in order to properly evaluate the installation of this system.

Ishaq I. Chanda  
Ishaq I. Chanda, P.E. Product Control Examiner  
Product Control Division

**Tranor Glass Company**

**ACCEPTANCE No.:** 98-1103.02

**APPROVED** : FEB 1 1 2000


**EXPIRES** : FEB 1 1 2003

**NOTICE OF ACCEPTANCE: STANDARD CONDITIONS**


1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
  - a) There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes;
  - b) The product is no longer the same product (identical) as the one originally approved;
  - c) If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product;
  - d) The engineer who originally prepared, signed and sealed the required documentation initially submitted is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
  - a) Unsatisfactory performance of this product or process.
  - b) Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purpose.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer need not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 1, 2 and this last page 3.

Ishaq I. Chanda  
Ishaq I. Chanda, P.E. Product Control Examiner  
Product Control Division

**END OF THIS ACCEPTANCE**




TYPICAL INSTALLATION ELEVATION  
SMALL MISSILE IMPACT RESISTANT  
MAXIMUM DESIGN PRESSURE: +80.0 PSF, -108.3 PSF



GLASS TYPES 1 AND 2 MAY NOT BE INSTALLED IN AREAS BELOW ELEVATION 30'-0\"/>

**GENERAL NOTES:**  
 TCW-251C ALUMINUM FRAMING SYSTEM  
 2-1/2\"/>

TYPICAL INSTALLATION ELEVATION  
LARGE MISSILE IMPACT RESISTANT  
MAXIMUM DESIGN PRESSURE: +80.0 PSF, -108.3 PSF



- GLASS TYPES FOR SMALL MISSILE IMPACT RESISTANCE:**
- △ 1-1/4\"/>

- GLASS TYPES FOR LARGE MISSILE IMPACT RESISTANCE:**
- △ 1-1/4\"/>
  - △ 1-3/8\"/>

- △ 1-3/8\"/>

**ROBT. E. FISHER**  
**WM. M. MEYERS, P.E.**  
**Consulting Engineers**  
 9301 N.E. 6th Ave. C-300  
 Miami Shores, FL 33138  
 (305) 758-3117 557-4006 Fax 362-8282

*Wm M Meyers*  
 18755  
 Structural  
 01/19/00

APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE February 11, 2000  
 BY Isaac L. Chauda  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1103.02

**TRAINOR GLASS COMPANY**  
 3728 PROSPECT AVE.  
 MIAMI BEACH, FL 33134  
 PHONE (305) 863-7077  
 FAX (305) 863-7068



NO.	DATE	BY	REVISIONS
1			
2			
3			
4			

PROJECT NAME:	TCW-251C PRODUCT APPROVAL DRAWING
ADDRESS:	
ARCHITECT:	
CONTRACTOR:	

DATE:	01/13/2000
SCALE:	6-7502
DWG NUMBER:	
SHEET NO.:	1 OF 8
DRAWN:	
CHECKED BY:	

ENGINEER SEAL  
 MIAMI- DADE COUNTY USE

## ANCHORAGE CHART

LOCATION	SUBSTRATE	ANCHOR TYPE	MIN DIA	SPACING/ LOCATION	MIN EMBEDMENT
HEADS (BETWEEN MULLIONS)	4000 PSI CONCRETE 3145 PSI CONCRETE 3145 PSI CONCRETE A36 STEEL (1/8" MIN THICK)	ITW "REDHEAD" OR EQ WEDGE ANCHORS	3/8"	6" FROM ENDS; 16" MAX ON CENTERS	1-1/2"
		RAWL "TAPPER" OR EQ CONCRETE SCREWS	3/8"	6" FROM ENDS; 16" MAX ON CENTERS	1-1/2"
		ELCO "TAPCON" OR EQ CONCRETE SCREWS	1/4"	6" FROM ENDS; 7-1/2" MAX ON CENTERS	1-1/2"
		1/4"-20 SAE GR 5 MIN MACHINE SCREWS	1/4"	6" FROM ENDS; 16" MAX ON CENTERS	THRU STEEL
SILLS (BETWEEN MULLIONS)	4000 PSI CONCRETE 3145 PSI CONCRETE 3145 PSI CONCRETE A36 STEEL (1/8" MIN THICK)	ITW "REDHEAD" OR EQ WEDGE ANCHORS	3/8"	6" FROM ENDS; 16" MAX ON CENTERS	1-1/2"
		RAWL "TAPPER" OR EQ CONCRETE SCREWS	3/8"	6" FROM ENDS; 16" MAX ON CENTERS	1-1/2"
		ELCO "TAPCON" OR EQ CONCRETE SCREWS	1/4"	6" FROM ENDS; 7-1/2" MAX ON CENTERS	1-1/2"
		1/4"-20 SAE GR 5 MIN MACHINE SCREWS	1/4"	6" FROM ENDS; 16" MAX ON CENTERS	THRU STEEL
JAMBS	4000 PSI CONCRETE 3145 PSI CONCRETE 3145 PSI CONCRETE A36 STEEL (1/8" MIN THICK)	ITW "REDHEAD" OR EQ WEDGE ANCHORS	3/8"	5" FROM ENDS; 24" MAX ON CENTERS	1-1/2"
		RAWL "TAPPER" OR EQ CONCRETE SCREWS	3/8"	5" FROM ENDS; 24" MAX ON CENTERS	1-1/2"
		ELCO "TAPCON" OR EQ CONCRETE SCREWS	1/4"	5" FROM ENDS; 7-1/2" MAX ON CENTERS	1-1/2"
		1/4"-20 SAE GR 5 MIN MACHINE SCREWS	1/4"	5" FROM ENDS; 24" MAX ON CENTERS	THRU STEEL
JAMBS (AT 1/3 POINTS)	4000 PSI CONCRETE 3145 PSI CONCRETE A36 STEEL (1/8" MIN THICK)	ITW "REDHEAD" OR EQ WEDGE ANCHORS	5/8"	2 PER JAMB- LOCATE AT 1/3 POINTS	1-1/2"
		ITW "REDHEAD" OR EQ WEDGE ANCHORS	5/8"	2 PER JAMB- LOCATE AT 1/3 POINTS	1-1/2"
		SAE J429 GR 5 OR ASTM A325 TYPE 2 BOLT	5/8"	2 PER JAMB- LOCATE AT 1/3 POINTS	THRUBOLTED
MULLIONS (THRU ANGLE CLIPS ON EACH SIDE OF MULLION AT HEAD)	4000 PSI CONCRETE 3145 PSI CONCRETE A36 STEEL (1/8" MIN THICK)	ITW "REDHEAD" OR EQ WEDGE ANCHORS	3/8"	2 ON EACH SIDE OF MULLION (4 TOTAL)	1-1/2"
		RAWL "TAPPER" OR EQ CONCRETE SCREWS	3/8"	2 ON EACH SIDE OF MULLION (4 TOTAL)	1-1/2"
		1/4"-20 SAE GR 5 MIN MACHINE SCREWS	1/4"	2 ON EACH SIDE OF MULLION (4 TOTAL)	THRU STEEL
MULLIONS (THRU ANGLE CLIPS ON EACH SIDE OF MULLION AT SILL)	4000 PSI CONCRETE 3145 PSI CONCRETE A36 STEEL (1/8" MIN THICK)	ITW "REDHEAD" OR EQ WEDGE ANCHORS	3/8"	2 ON EACH SIDE OF MULLION (4 TOTAL)	1-1/2"
		RAWL "TAPPER" OR EQ CONCRETE SCREWS	3/8"	2 ON EACH SIDE OF MULLION (4 TOTAL)	1-1/2"
		1/4"-20 SAE GR 5 MIN MACHINE SCREWS	1/4"	2 ON EACH SIDE OF MULLION (4 TOTAL)	THRU STEEL
MULLIONS (INTERMEDIATE OR "WINDLOAD" ANCHOR)	6" X 6" X 1/2" A36 STEEL ANGLES- ONE ON EACH SIDE OF MULLION (2 TOTAL)	SAE J429 GR 5 OR ASTM A325 TYPE 2 BOLT	5/8"	ONE BOLT THRU BOTH ANGLES	THRUBOLTED






**TRAINOR GLASS COMPANY**  
 3728 PROSPECT AVE.  
 RIVERA BEACH, FL 33404  
 TEL: (561) 863-7078  
 FAX: (561) 863-7088



NO.	DATE	BY	REVISIONS

<p style="text-align: center;">ENGINEER SEAL</p> <p style="text-align: center;"><b>ROBT. E. FISHER</b>  <b>WM. M. MEYERS, P.E.</b>                  Consulting Engineers                  9301 N.E. 6th Ave. C-300                  Miami Shores, FL 33138                  (305) 758-3117 557-4006 Fax 362-6000</p> <p style="text-align: center;"><i>Wm M Meyers</i>                  18755                  Structural                  01/17/00</p>	<p style="text-align: center;">MIAMI- DADE COUNTY USE</p> <p style="text-align: center;">APPROVED AS COMPLYING WITH THE                  SOUTH FLORIDA BUILDING CODE                  DATE <u>February 11, 2000</u>                  BY <u>Shaq I. Chanda</u></p> <p style="text-align: center;">PRODUCT CONTROL DIVISION                  BUILDING CODE COMPLIANCE OFFICE                  ACCEPTANCE NO. <u>98-1103.02</u></p>
---	--

PROJECT NAME	TCM-251C PRODUCT APPROVAL DRAWING
ADDRESS	
ARCHITECT	
CONTRACTOR	
DATE	01/13/2000
SCALE	NO SCALE
DRAWN	
CHECKED BY	
DWG NUMBER	6-7302
SHEET NO.	2 OF 8



REFER TO PAGE 2 OF 8 FOR ANCHORAGE REQUIREMENTS

- MATERIAL LEGEND:**
- (A) KAWNEER #175-310 PLASTIC RETAINER CLIPS AT 12" O.C.
  - (B) TREMCO TR1733 CLOSED CELL NEOPRENE SPONGE GASKET
  - (C) TREMCO TR5399 70 DUROMETER SILICONE COMPATIBLE RUBBER GASKET
  - (D) DOW 983 STRUCTURAL SILICONE- 1/4" X 3/4" (UON)
  - (E) NORTON V2100 1/4" X 1/4" STRUCTURAL TAPE
  - (F) TGF-39 ALUMINUM RETAINER CLIPS- 4" LONG PIECES AT 12" O.C.

ENGINEER SEAL

MIAMI- DADE COUNTY USE

**ROBT. E. FISHER  
WM. M. MEYERS, P.E.  
Consulting Engineers**  
9301 N.E. 8th Ave. C-300  
Miami Shores, FL 33138  
(305) 758-3117 557-4006 Fax 362-6282

*Wm M Meyers*  
18755  
Structural  
01/17/00

APPROVED AS COMPLYING WITH THE  
SOUTH FLORIDA BUILDING CODE  
DATE February 11, 2000  
BY Ishaq I. Ulanda  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 98-1103-02

TRAINOR GLASS COMPANY


3728 PROSPECT AVE.  
RIVIERA BEACH, FL 33404  
PH. (561) 863-7078  
FAX (561) 863-7088




NO.	DATE	BY	REVISIONS

PROJECT NAME:	TCW-251C PRODUCT APPROVAL DRAWING
ADDRESS:	
ARCHITECT:	
CONTRACTOR:	


DATE:	01/13/2000	NO.	3 OF 8
SCALE:	N.T.S.	SHEET	
DRAWN:		D.T.	
CHECKED BY:			




6 HEAD




7 HORIZONTAL



8 SILL



9 HORIZONTAL



10 HORIZONTAL

REFER TO PAGE 2 OF 8 FOR ANCHORAGE REQUIREMENTS

- MATERIAL LEGEND:**
- (A) KAWNEER #175-310 PLASTIC RETAINER CLIPS AT 12" O.C.
  - (B) TREMCO TR1733 CLOSED CELL NEOPRENE SPONGE GASKET
  - (C) TREMCO TR5399 70 DUROMETER SILICONE COMPATIBLE RUBBER GASKET
  - (D) DOW 983 STRUCTURAL SILICONE- 1/4" X 3/4" (UON)
  - (E) NORTON V2100 1/4" X 1/4" STRUCTURAL TAPE
  - (F) TGF-39 ALUMINUM RETAINER CLIPS- 4" LONG PIECES AT 12" O.C.

ENGINEER SEAL

MIAMI- DADE COUNTY USE

**ROBT. E. FISHER**  
**WM. M. MEYERS, P.E.**  
 Consulting Engineers  
 9301 N.E. 6th Ave. C-300  
 Miami Shores, FL 33138  
 (305) 758-3117 557-4006 Fax 362-6282

*Wm M Meyers*  
 12763  
 Structural  
 0117100

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE

DATE *February 11, 2000*

BY *Ishaq I. Danda*





PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. *98-1103.02*

PROJECT NAME: TCM-251C PRODUCT APPROVAL DRAWING		NO.	DATE	BY	REVISIONS
ADDRESS:		NO.	DATE	BY	REVISIONS
ARCHITECT:		NO.	DATE	BY	REVISIONS
CONTRACTOR:		NO.	DATE	BY	REVISIONS
DATE: 01/13/2000	SCALE: AS SHOWN	DWG NUMBER: 6-7302	SHEET NO: 4	OF 8	
ENG. SEAL	DRAWN BY:	CHECKED BY:			

**TRAINER GLASS COMPANY**

3728 PROSPECT AVE.  
 MIAMI BEACH, FL 33404  
 PH: (305) 863-7078  
 FAX: (305) 863-7088





- MATERIAL LEGEND:**
- (A) KAWNEER #175-310 PLASTIC RETAINER CLIPS AT 12" O.C.
  - (B) TREMCO TR1733 CLOSED CELL NEOPRENE SPONGE GASKET
  - (C) TREMCO TR5399 70 DUROMETER SILICONE COMPATIBLE RUBBER GASKET
  - (D) DOW 983 STRUCTURAL SILICONE- 1/4" X 3/4" (UON)
  - (E) NORTON V2100 1/4" X 1/4" STRUCTURAL TAPE
  - (F) TGF-39 ALUMINUM RETAINER CLIPS- 4" LONG PIECES AT 12" O.C.

REFER TO PAGE 2 OF 8 FOR ANCHORAGE REQUIREMENTS

ENGINEER SEAL  
**ROBT. E. FISHER**  
**WM. M. MEYERS, P.E.**  
 Consulting Engineers  
 9301 N.E. 6th Ave. C-300  
 Miami Shores, FL 33138  
 (305) 758-3117 557-4006 Fax 362-6282

*Wm M Meyers*  
 1975  
 Structural  
 01/17/00


MIAMI- DADE COUNTY USE

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE  
 DATE February 11, 2000  
 BY Isaac L. Llaude  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. 98-1103.02

PROJECT NAME: TCW-251C PRODUCT APPROVAL DRAWING		NO. DATE BY		T.C. PROJ. MGR.	
ADDRESS:		NO. DATE BY		T.C. PROJ. MGR.	
ARCHITECT:		NO. DATE BY		T.C. PROJ. MGR.	
CONTRACTOR:		NO. DATE BY		T.C. PROJ. MGR.	
DATE: 01/13/2000	SCALE: NTS	CHK NUMBER: 6-7902	SHEET NO.: 5	OF 8	
DATE: 01/13/2000	SCALE: NTS	CHK NUMBER: 6-7902	SHEET NO.: 5	OF 8	
DATE: 01/13/2000	SCALE: NTS	CHK NUMBER: 6-7902	SHEET NO.: 5	OF 8	


**TRINOR GLASS COMPANY**  
 3728 PROSPECT AVE.  
 RIVIERA BEACH, FL 33404  
 (561) 883-7068  
 FAX: (561) 883-7068





- MATERIAL LEGEND:**
- (A) KAWNEER #175-310 PLASTIC RETAINER CLIPS AT 12" O.C.
  - (B) TREMCO TR1733 CLOSED CELL NEOPRENE SPONGE GASKET
  - (C) TREMCO TR5399 70 DUROMETER SILICONE COMPATIBLE RUBBER GASKET
  - (D) DOW 983 STRUCTURAL SILICONE— 1/4" X 3/4" (UDN)
  - (E) NORTON V2100 1/4" X 1/4" STRUCTURAL TAPE
  - (F) TGF-39 ALUMINUM RETAINER CLIPS— 4" LONG PIECES AT 12" O.C.

REFER TO PAGE 2 OF 8 FOR ANCHORAGE REQUIREMENTS



ENGINEER SEAL

MIAMI-DADE COUNTY USE

**ROBT. E. FISHER**  
**WM. M. MEYERS, P.E.**  
Consulting Engineers  
9301 N.E. 6th Ave. C-300  
Miami Shores, FL 33138  
(305) 758-3117 557-4006 Fax 362-6282

*Wm M Meyers*  
18782  
Structural  
01/17/00

APPROVED AS COMPLYING WITH THE  
SOUTH FLORIDA BUILDING CODE  
DATE February 11, 2000  
BY Ishaq I. Chanda  
PRODUCT CONTROL DIVISION  
BUILDING CODE COMPLIANCE OFFICE  
ACCEPTANCE NO. 98-1103.02

**TRINOR GLASS COMPANY**  
3728 PROSPECT AVE.  
RIVIERA BEACH, FL 33404  
TEL: (561) 863-7028  
FAX: (561) 863-7088



NO.	DATE	BY	REVISIONS
1			
2			
3			
4			
5			
6			
7			
8			

PROJECT NAME: TCW-251C PRODUCT APPROVAL DRAWING


ADDRESS: \_\_\_\_\_ ARCHITECT: \_\_\_\_\_ CONTRACTOR: \_\_\_\_\_

DATE: 01/13/2000 DWG NUMBER: 6-7502 SHEET NO.: 6 OF 8

SCALE: NTS DRAWN: \_\_\_\_\_ D.T.: \_\_\_\_\_ CHECKED BY: \_\_\_\_\_

ENG. SEAL: \_\_\_\_\_





REFER TO PAGE 2 OF 8 FOR ANCHORAGE REQUIREMENTS

23

SEE DETAILS 4 OR 9 FOR FRAMING INFORMATION

ENGINEER SEAL

MIAMI- DADE COUNTY USE

**ROBT. E. FISHER**  
**WM. M. MEYERS, P.E.**  
 Consulting Engineers  
 9301 N.E. 6th Ave. C-300  
 Miami Shores, FL 33138  
 (305) 758-3117 557-4006 Fax 362-6282

*Robt E Fisher*  
 1/27/00  
 S. Meyers  
 01/27/00

APPROVED AS COMPLYING WITH THE  
 SOUTH FLORIDA BUILDING CODE  
 DATE *February 11, 2000*  
 BY *Ishaq I. Mauda*  
 PRODUCT CONTROL DIVISION  
 BUILDING CODE COMPLIANCE OFFICE  
 ACCEPTANCE NO. *98-1103-02*

TRAINOR GLASS COMPANY



3728 PROSPECT AVE.  
 RIVIERA BEACH, FL 33404  
 PH: (561) 863-7078  
 FAX: (561) 863-7088

NO.		DATE		BY		REVISIONS	
PROJECT NAME:		TCW-251C PRODUCT APPROVAL DRAWING					
ADDRESS:							
ARCHITECT:							
CONTRACTOR:							
DATE:	01/17/2000	DWG NUMBER:	6-7302	SHEET NO.:	8	OF 8	
SCALE:	NTS	DRAWN:		CHECKED BY:			
ENG. SEAL:							