



MIAMI-DADE COUNTY
BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING

140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

www.miamidade.gov

NOTICE OF ACCEPTANCE (NOA)

James Hardie Building Product, Inc.
10901 Elm Avenue
Fontana, CA 92337

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Artisan Lap Siding

APPROVAL DOCUMENT: Drawing No. 2008-8-7.vsd, titled " Artisan Lap Siding ", sheets 1 through 4 of 4, prepared by Ronald I. Ogawa, P.E., dated August 07, 2008, last revision #1 dated August 27, 2008, signed and sealed by Ronald I. Ogawa, P.E., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and the approval date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1, evidence submitted page E-1 as well as approval document mentioned above. The submitted documentation was reviewed by **Helmy A. Makar, P.E., M.S.**



Helmy A. Makar
 10/02/2008

NOA No. 08-0514.11
 Expiration Date: 10/02/2013
 Approval Date: 10/02/2008
 Page 1

James Hardie Building Product, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. *Drawing No. 2008-8-7.vsd, titled " Artisan Lap Siding ", sheets 1 through 4 of 4, prepared by Ronald I. Ogawa, P.E., dated August 07, 2008, last revision #1 dated August 27, 2008, signed and sealed by Ronald I. Ogawa, P.E.*

B. TESTS

1. *Test Report #MID3137643-01, by Intertek ETL Semko, dated January 30, 2008, per TAS 202 and TAS 203, signed and sealed by Rick Curkeet, P.E.*
2. *Test Report #MID3137643-03, by Intertek ETL Semko, dated April 16, 2008, per TAS 202 and TAS 203, signed and sealed by Rick Curkeet, P.E.*
3. *Test Report #3097158-009B, by Intertek ETL Semko, dated May 04, 2007, per Acceptance Criteria for Fiber Cement Siding used as Exterior Wall Siding, signed and sealed by Kal Kooner, EIT.*

C. CALCULATIONS


1. *None.*

D. QUALITY ASSURANCE


1. *By Miami-Dade County Building Code Compliance Office.*

E. MATERIAL CERTIFICATIONS

1. *Test Report #3099611SAT-001, by Intertek ETL Semko, dated June 28, 2006, per ASTM E84-05, Surface Burning Characteristics of Building Materials, signed by C. Anthony Penaloza, Flammability Testing Team Leader.*



Henry A. Makar, P.E., M.S.
Product Control Examiner
NOA No. 08-0514.11
Expiration Date: 10/02/2013
Approval Date: 10/02/2008



PRODUCT DESCRIPTION

Artisan® Lap Siding material is a nonasbestos fiber-cement product tested in accordance with ASTM C1186 Grade II, Type A and meeting the requirements of the Florida Building Code.

PLANK DIMENSIONS

Width 5 8-1/4"
Length 12'
Thickness 5/8"

DESIGN PRESSURE RATING

Installation Design Pressure
Wood Studs -92 psf

Impact Resistant -

Planks installed over 5/8" thick / 5 ply APA rated plywood sheathing

SECTION B-B



ARTISAN® LAP SIDING INSTALLATION DETAILS


- All installation shall be done in conformance with this Notice of Acceptance, the manufacturer's installation recommendations, and the applicable sections of the Florida Building Code.
- Metal studs where Artisan® Lap Siding will be installed shall be designed by an Engineer or Architect per the Florida Building Code and the requirements of this N.O.A.
- Planks shall be applied horizontally commencing from the bottom course of the wall with 1-1/4" wide laps at the top of the plank.
- The tongue and groove vertical joints must occur 4" off stud, do not nail within 2 inches of tongue and groove.
- The planks shall be installed over 5/8" thick / 5 ply APA rated plywood sheathing supported by a minimum of 18ga, Nominal 2" X 6" Metal C-studs spaced a maximum of 16" O.C.
- The siding shall be fastened over the studs with a combination of both concealed and exposed fasteners.
- The concealed fastener shall be a minimum No. 8-18, 0.375" head diameter X 1-3/4" long* bugle head screw over metal studs. (*or screw shall have at least 3 full threads penetrating metal framing)
- The exposed fastener shall be a minimum 0.075" shank X 2" long corrosion resistant metal stud finish nail (pin) over metal studs.
- The concealed fastener shall be fastened through the top edge of a single plank; the concealed fastener shall be positioned 1" down from the plank's top edge in such a way that the fastener is fully concealed by the next course of plank.
- The exposed fastener shall be placed in the overlapping area approximately 3/4" from the bottom edge of the overlapping plank.
- Both concealed and exposed fasteners shall be 5/8" thick / 5 ply APA rated plywood sheathing.
- A fastener edge distance of 3/4" shall always be observed.
- 5/8" thick / 5 ply APA rated plywood sheathing shall be attached to the studs in accordance with the Florida Building Code, with minimum #8 X 1" long ribbed bugle head screws spaced a maximum of 6 inches on center along the perimeter and a maximum of 12 inches on center along the intermediate supports.
- The exposed fastener shall be a minimum No. 8-18, 0.375" head diameter X 1-3/4" long* bugle head screw over metal studs.
- The concealed fastener shall be fastened through the top edge of a single plank; the concealed fastener shall be positioned 1" down from the plank's top edge in such a way that the fastener is fully concealed by the next course of plank.
- *or screw shall have at least 3 full threads penetrating metal framing

DETAIL A

5/8" thick / 5 ply APA rated plywood sheathing shall be attached to the studs in accordance with the Florida Building Code, with Minimum #8 X 1" long ribbed bugle head screws, spaced a maximum of 6 inches on center along the perimeter and a maximum of 12 inches on center along the intermediate supports.

- The exposed fastener shall be a minimum 0.075" shank X 2" long corrosion resistant metal stud finish nail (pin) over metal studs.
- The exposed fastener shall be placed in the overlapping area approximately 3/4" from the bottom edge of the overlapping plank.
- The concealed fastener shall be a minimum No. 8-18, 0.375" head diameter X 1-3/4" long* bugle head screw over metal studs.
- The concealed fastener shall be fastened through the top edge of a single plank; the concealed fastener shall be positioned 1" down from the plank's top edge in such a way that the fastener is fully concealed by the next course of plank.
- *or screw shall have at least 3 full threads penetrating metal framing

Approved & completed by
Date 10/02/2008
NOA# 08-0514.11
Miami Date Product Control
Division
By Helmy A. M. K.




James Hardie

James Hardie Building Products, Inc.
10901 Elm Avenue
Fontana, CA 92337
Phone: 906-355-6300, Fax: 906-427-9634

Creator: C. Diercks

Artisan® Lap Siding (Metal Studs)	
SIZE A	FSCM NO
SCALE 1/2" = 1'-0"	Date: 8/7/2008
REV 1	DWG NO Miami Date NOA - Artisan Lap Siding- 2008-8-7.vsd
SHEET 1 OF 4	

This drawing and the copyright therein are the property of the named company and accordingly the drawing must not be copied or reproduced in any material form whatsoever and must be returned with quotation and on completion of job



FOR METAL AND WOOD STUDS, PROVISIONS FOR DIAPHRAGM ACTION AND GRAVITY LOAD ARE NOT PART OF THIS APPROVAL (MUST PROVIDE ALTERNATE PROVISIONS FOR THESE LOADS)

Approved as complying with the Florida Building Code
 Date 10/02/2008
 NOA# 08-0514-11
 Division Miami Dade Product Control
 By *Anthony A. Miller*


- FRAMING**
 - NOMINAL 18 GAUGE 2" X 6" STEEL STUDS 16" O.C. FASTENED WITH NO. 8 X 1" LONG BUGLE HEAD SCREWS (2 PER TOP AND BOTTOM CONNECTION)
- SHEATHING**
 - NOMINAL 5/8" THICK 1/5 PLY APA RATED PLYWOOD SHEATHING FASTENED WITH #8 X 1" LONG RIBBED BUGLE HEAD SCREWS, AT 6" O.C. AROUND THE PERIMETER AND 12" O.C. WITHIN THE FIELD
- CLADDING**
 - PLANKS OVERLAP 1-1/4"
 - THE EXPOSURE IS 7"
 - THE PLANKS ARE BLIND SCREWED WITH NO. 8-18, 0.375" HEAD DIAMETER X 1-1/2" LONG CORROSION RESISTANT BUGLE HEAD SCREWS (SCREW SHALL HAVE AT LEAST 3 FULL THREADS PENETRATING THE METAL FRAMING), PLACE SCREWS 1" DOWN FROM THE TOP EDGE OF THE PLANK AT EACH STUD LOCATION
 - THE PLANKS ARE FACE NAILED WITH 0.075" SHANK DIAMETER X 2" LONG CORROSION RESISTANT METAL STUD FINISH NAILS, PLACE FINISH NAILS 3/4" UP FROM THE BOTTOM EDGE OF THE PLANK AT EACH STUD LOCATION

James Hardie
 James Hardie Building Products, Inc.
 10801 Elm Avenue
 Fontana, CA 92337
 Phone: 951-355-6300, Fax: 951-427-0534


Creator: C. Diercks

Artisan® Lap Siding (Metal Studs)	
SIZE A	FSCM NO
SCALE 1" = 1'-0"	DWG NO Miami Dade NOA - Artisan Lap Siding-2008-8-7.vsd
DATE 8/7/2008	SHEET 2 OF 4
REV 1	DATE 8/7/2008

This drawing and the copyright therein are the property of the named company and accordingly the drawing must not be copied or reproduced in any material form whatsoever and must be returned with quotation and on completion of job



SEE
DETAIL A



PRODUCT DESCRIPTION
 Artisan® Lap Siding material is a nonasbestos fiber-cement product tested in accordance with ASTM C1186 Grade II, Type A and meeting the requirements of the Florida Building Code.

PLANK DIMENSIONS
 Width ≤ 8-1/4"
 Length 12'
 Thickness 5/8"

DESIGN PRESSURE RATING
 Installation Design Pressure
 Wood Studs -92 psf

Impact Resistant –
 Planks installed over 5/8" thick / 5 ply APA rated plywood sheathing

ARTISAN® LAP SIDING INSTALLATION DETAILS


- All installation shall be done in conformance with this Notice of Acceptance, the manufacturer's installation recommendations, and the applicable sections of the Florida Building Code.
- Wood studs where Artisan® Lap Siding will be installed shall be designed by an Engineer or Architect per the Florida Building Code and the requirements of this N.O.A.
- Planks shall be applied horizontally commencing from the bottom course of the wall with 1-1/4" wide laps at the top of the plank.
- The tongue and groove vertical joints must occur 4" off stud, do not nail within 2 inches of tongue and groove.
- The planks shall be installed over 5/8" thick / 5 ply APA rated plywood sheathing supported by a minimum of 2"x4" S-P-F wood studs spaced a maximum of 16" O.C.
- The siding shall be fastened over the studs with a combination of both concealed and exposed fasteners.
- The concealed fastener shall be an 8d, 2-3/8" long corrosion resistant ring shank box nail over wood studs.
- The exposed fastener shall be an 8d, 2-1/2" long corrosion resistant finish nail over wood studs.
- The concealed fastener shall be positioned 1" down from the plank's top edge in such a way that the fastener is fully concealed by the next course of plank.
- The exposed fastener shall be placed in the overlapping area approximately 3/4" from the bottom edge of the overlapping plank.
- Both concealed and exposed fasteners shall be ≤ 7" O.C. vertically and 16" O.C. horizontally into wood studs through 5/8" thick / 5 ply APA rated plywood sheathing.
- A fastener edge distance of 3/4" shall always be observed.
- 5/8" thick / 5 ply APA rated plywood sheathing shall be attached to the studs in accordance with the Florida Building Code, with minimum 8d 2-3/8" long box nails spaced a maximum of 6 inches on center along the perimeter and a maximum of 12 inches on center along the intermediate supports.

5/8" thick / 5 ply APA rated plywood sheathing shall be attached to the studs in accordance with the Florida Building Code, with minimum 8d 2-3/8" long box nails spaced a maximum of 6 inches on center along the perimeter and a maximum of 12 inches on center along the intermediate supports.

The exposed fastener shall be an 8d, 2-1/2" long corrosion resistant finish nail over wood studs.
 The exposed fastener shall be placed in the overlapping area approximately 3/4" from the bottom edge of the overlapping plank.

The concealed fastener shall be an 8d, 2-3/8" long corrosion resistant ring shank box nail over wood studs.
 The concealed fastener shall be fastened through the top edge of a single plank; the concealed fastener shall be positioned 1" down from the plank's top edge in such a way that the fastener is fully concealed by the next course of plank.

DETAIL A



- Weatherproofing per 2121.6.2 of Florida Building Code
- 5/8" thick / 5 ply APA rated plywood sheathing fastened according to the Florida Building Code
- 2" X 4" S-P-F Wood Studs
- Artisan® Lap Siding



James Hardie
 James Hardie Building Products, Inc.
 10001 Elm Avenue
 Fontaine, CA 92337
 Phone: 909-556-5300, Fax: 909-527-0634

Creator: C. Diercks

Approved as complying with the Florida Building Code
 Date: 10/02/2008
 NOA 08-0514.11
 Miami Dade Product Control
 By: *Henry A. Miller*

Artisan® Lap Siding (Wood Studs)	
SIZE A	REV 1
FSCM NO	DWG NO
1/2" = 1'-0"	Miami Dade NOA - Artisan Lap Siding-2008-5-7.vsd
SCALE	DATE: 8/7/2008
	SHEET 3 OF 4

This drawing and the copyright therein are the property of the named company and accordingly the drawing must not be copied or reproduced in any material form whatsoever and must be returned with quotation and on completion of job



Approved as complying with the
 Florida Building Code
 Date 10/02/2008
 NOA# 08-0514-II
 Miami Dade Product Control
 Division
 By: *Heather A. Dehn*

FOR METAL AND WOOD STUDS, PROVISIONS FOR
 DIAPHRAGM ACTION AND GRAVITY LOAD ARE NOT
 PART OF THIS APPROVAL (MUST PROVIDE ALTERNATE
 PROVISIONS FOR THESE LOADS)

- FRAMING**
- NOMINAL 2" X 4" S-P-F WOOD STUDS 16" O.C. FASTENED WITH 16d COMMON NAILS (2 PER TOP AND BOTTOM CONNECTION)
- SHEATHING**
- NOMINAL 5/8" THICK / 5 PLY APA RATED PLYWOOD SHEATHING FASTENED WITH 2-3/8 INCH 8d COMMON NAILS, AT 6" O.C. AROUND THE PERIMETER AND 12" O.C. WITHIN THE FIELD
- CLADDING**
- PLANKS OVERLAP 1-1/4"
 - THE EXPOSURE IS 7"
 - THE PLANKS ARE BLIND NAILED WITH A 2-3/8" CORROSION RESISTANT COMMON RING SHANK NAILS, 1" DOWN FROM THE TOP EDGE OF THE PLANK AT EACH STUD LOCATION
 - THE PLANKS ARE FACE NAILED WITH 2-1/2" CORROSION RESISTANT FINISH NAILS, 3/4" UP FROM THE BOTTOM EDGE OF THE PLANK AT EACH STUD LOCATION

James Hardie
 James Hardie Building Products, Inc.
 10901 Elm Avenue
 Fontana, CA 92337
 Phone: 909-356-6300 Fax: 909-427-0634

Creator: C. Diercks

Artisan® Lap Siding (Wood Studs)	
SIZE A	FSCM NO
SCALE 1" = 1'-0"	DWG NO Miami Dade NOA - Artisan Lap Siding- 2008-8-7.vsd
DATE 8/7/2008	REVISION 1
SHEET 4 OF 4	

This drawing and the copyright therein are the property of the named company and accordingly the drawing must not be copied or reproduced in any material form whatsoever and must be returned with quotation and on completion of job