

Walters, Vivian (RER)

From: Walters, Vivian (RER)
Sent: Friday, September 06, 2013 2:40 PM
To: 'jdiaz@acengineering.com'; 'aparets@aaronind.com'; 'oparets@aaronind.com'; 'rlostal@safetysourceusa.com'; 'SALE@TRIANGLEFIRE.COM'
Cc: Johnson, Laurie (RER); McGriff, Sherri (RER)
Subject: Verification of Availability - RQID1300194
Attachments: Verification of Availability - RQID1300194.pdf

Good Afternoon!

Please see attached and respond accordingly (ensuring all questions are answered).

***FYI – you are not required to provide any pricing at this point (info is included as a FYI)

- ***Are you interested?***

YES _____ NO _____

- ***Are capable of meeting the scope and ALL requirements?***

YES _____ NO _____

- ***Do you have prior experience consistent with these scopes services?***

YES _____ NO _____

- ***Are you an authorized vendor in the cases of the Groups with “NO” substitutes?***

YES _____ NO _____

- ***Can you meet the “Standards” consistent with these scopes? (Section 3.2)***

YES _____ NO _____

Please Check the **“GROUP”** in which you are interested (and capable of covering the **“Scopes of Services”**)

- **Group A – Fire Extinguisher - Regular Dry Chemical-Stored Pressure “BC” Chemical**

- **Group B– Chemical “ABC” Amerex Only – No Substitute**

- **Group C– Dry Chemical - Purple K Dry Chemical**

- **Group D – Halon 1211**

- **Group E – Water Pressure Type**

- **Group F – Brand: Amerex “No Substitute”**

- **Group G – Ansul ABC “No Substitute”**

- **Group H – Cold Fire Class A, B, D and K “No Substitute”**

Please respond (via email) by **12:00pm Tuesday September 10, 2013.**

Regards,

Vivian O. Walters, Jr.

Contract Development Specialist II
Regulatory and Economic Resources Department
Small Business Development Division
111 NW 1st Street #19 Floor
Miami, FL 33128
walterv@miamidade.gov

☎ Office (305) 375-3138 | 📠 Fax (305) 375-3160

"Delivering Excellence Every Day"

"For the New Project Review & Analysis Process"



click on our new website

<http://www.miamidade.gov/sba/about-project-review-and-analysis.asp>

Miami-Dade County is a public entity subject to Chapter 119 of the Florida Statutes concerning public records. E-mail messages are covered under such laws and thus subject to disclosure.



SECTION 3
TECHNICAL SPECIFICATIONS

FIRE EXTINGUISHERS

3.1 SCOPE OF WORK

The purpose of this solicitation is to establish a contract for the purchase of fire extinguishers for various Miami-Dade Departments on as needed when needed basis.

3.2 STANDARDS

All fire extinguishers shall conform to the latest National Fire Protection Association (NFPA) Standard (NFPA-10) as adopted in Florida Administrative Code #483 and OSHA.

All portable fire extinguishers must have the nationally recognized laboratory testing label to verify compliance with applicable standards [29 CFR 1910.157(c)(2)]

All fire extinguishers bidders shall comply with the State Fire Marshall uniform Fire Safety Rules and Standards – Florida Statutes- Chapter 633.061.

All portable fire extinguishers shall be tagged and dated, certified by the bidder, and ready for use when delivered to the County.

In addition, each extinguisher shall meet the following requirements:

- a. Shell: The exterior shell/container of the fire extinguisher must be equal in design and performance to the model identified by the County on the Bid Submittal Form and which is marked "No Substitute".
- b. Finish: The exterior shell/container must be corrosion and impact resistant.
- c. Head and bracket (when applicable): Made of metal with a metal pull pin and seal. (plastic allowed: siphon tube only). This would help prevent accidental discharge and discourage tampering.
- d. Resistance: A ring or similar device.
- e. Gauge: Threaded and screw-in type gauge showing a visual demarcation in industry-standard red and green, indicating the state of charge of the extinguisher.
- f. All fire extinguishers weighing less than 20 lbs. must have a minimum rating of 40BC.
- g. All fire extinguishers must be tagged and certified ready to install.
- h. The body of the fire extinguisher should be deep drawn, welded hydro tested to 35 KG/cm², hot phosphate and powder coated both external and internal.

The following is a list of fire extinguishers that may be purchased under this contract. If bidding on an equal, please provide manufacturer's name and model number in Section 4, Bid Submittal pages 8 through 12.

SECTION 3
TECHNICAL SPECIFICATIONS

FIRE EXTINGUISHERS

3.3 EXTINGUISHERS GROUPS:

GROUP A Fire Extinguishers- Regular Dry Chemical-Stored Pressure "BC" Chemical

1.	2-1/2 lbs. 10B:C. Amerex Model No. B403T, or approved equal
2.	5 lbs. 10B:C. Amerex Model No. B409T, or approved equal
3.	All-purpose bracket for the above listed extinguishers, or approved equal
4.	All-purpose bracket No. 809, or approved equal, or approved equal

GROUP B Chemical "ABC" Amerex Only – "No Substitute"

1.	2-1/2 lbs. Amerex 4 X 9 Model No. B417
2.	5 lbs. Amerex Model No. B500
3.	10 lbs. Amerex Model No. B456
4.	10 lbs. Amerex Model No. B441
5.	20 lbs. Amerex Model No. 423

GROUP C – Dry Chemical Purple K Dry Chemical

1.	2-1/2 lbs. Amerex Model No. B410T, or approved equal
2.	20 lbs. Amerex Model No. A413, or approved equal
3.	Bracket, Amerex Model No. 810, or approved equal
4.	Bracket, Amerex Model No. 812, or approved equal

GROUP D - HALON 1211

1.	17 lbs. Halon 1211, Amerex Model No. 361, or approved equal
2.	9 lbs. Halon 1211, Amerex Model No. B369, or approved equal
3.	15-1/2 lbs. Halotron, Amerex Model No. 398, or approved equal

GROUP E –WATER PRESSURE TYPE

1.	2-1/2 gal. Amerex Model No. 240, or approved equal
2.	2-1/2 gal. Water Mist unit, Amerex Model No. B272NM (Non magnetic), or approved equal

GROUP F – Brand: Amerex, "No Substitute"

1.	50 lbs. Dry Chemical, "BC" charge, Amerex Model No. 512
2.	125 lbs. Wheeled unit, Amerex Model No. 490
3.	20 lbs. CO ² , Amerex Model No. 332
4.	15 lbs. CO ² , Amerex Model No. 331
5.	30 lbs. Class D, Amerex Model No. B570
6.	30 lbs. Class D, Amerex Model No. B571

GROUP G- Ansul ABC "No Substitute"

1.	10 lbs. RED LINE Cartridge-Operated Hand, Ansul Model No. A10E (part No.14344)
----	--

SECTION 3
TECHNICAL SPECIFICATIONS

FIRE EXTINGUISHERS

GROUP H- Cold Fire Class A,B,D, and K "No Substitute"

1.	Cold Fire Model No. CF015 -1.5 gallon, stainless steel extinguishers filled, to include universal mounting and aspirating nozzle
----	--