

MIAMI DADE COUNTY PERMITTING AND INSPECTION CENTER



FIRE DEPARTMENT "APPROVED AS NOTED CRITERIA

1. Door ratings.
2. Minor changes of elevation at exits on new construction.
3. Note additional exit sign, emergency lights symbol or modify location.
4. The citing of required door closers or panic hardware.
5. Adding site related stripping, bollards.
6. Minor modification of handrail extensions on ramps or stairs.