


Miami-Dade County

Typical Flat Wall Sign Mounting Detail

Zoning Improvement Permit Category 0020



Wall Type	Fastener Type	Maximum S Spacing in Inches
Masonry Block	Masonry Anchor Screw ¼"Ø with 1" embedment	12" o.c.
Concrete (2000PSI)	Concrete Anchor Screw ¼" Ø with 1-½" embedment	24" o.c.
	Wedge Anchor ½"Ø with 3-¼" embedment	24" o.c.
Wood Studs *	Wood Screws #10 with 2" embedment	16" o.c.
	Lag Bolts ¼"Ø with 2-½" embedment	24" o.c.
Steel Studs * 20 ga. min	#10 Self Drilling Screws	16" o.c.

* Connection to stud **OR** adequate backing must be provided

Note:

- 1) Maximum Building Height 30'
- 2) Maximum Parapet Height 4'
- 3) Wind Speed 180 MPH Ultimate (3 second gust)
- 4) Exposure D
- 5) Maximum sign size 40 sq. ft.