



**NOTES:**

- 1.- CAST TOP SLAB TO FIT WALL USED.
- 2.- USE 4,000 psi CONCRETE. (MINIMUM), MAXIMUM W/C=0.53, GRADE 60 STEEL FOR REBAR AND GRADE 65 FOR WWF.
- 3.- PIPES MAY EXTEND INTO CATCH BASIN A MAXIMUM OF 4".
- 4.- APPLY A SMOOTH LINE OF MORTAR 1/2" THICK INSIDE AND OUTSIDE.
- 5.- WEEP HOLES ARE TO BE USED WHEN THE YEARLY LOWEST WATER ELEVATION IS ABOVE THE TOP OF THE BOTTOM SLAB OF THE STRUCTURE.

<p>MIAMI-DADE COUNTY</p> <p>DEPARTMENT OF TRANSPORTATION AND PUBLIC WORKS</p>	<p>APPROVED</p> <p>5/8/2018</p>	<p>REVISED</p> <p>5/8/2018</p> <p>9/16/2013</p> <p>9/26/2012</p> <p>2/8/2011</p> <p>3/7/1981</p>	<p>STANDARD STORM DRAINAGE DETAIL</p> <p>PRECAST CATCH BASIN (D-3)</p>	<p>SD</p> <p>2.2</p> <p>SHEET 1 OF 2</p>
---	---------------------------------	--	--	--