



**NOTES:**

1. SEE SPECIFICATION SECTION 15130 FOR APPROVED ARV'S.
2. METALLIC THREADS TO BE COATED WITH BITUMASTIC COATING.
3. ON ARV'S FOR SEWERAGE INSTALL 1" BLOW-OFF VALVE AND 1/2" QUICK-DISCONNECT BACKFLUSHING CONNECTION WITH SHUT-OFF VALVE.
4. INSTALL TAPPING SADDLE FOR THICKNESS CLASS D.I. MAINS 4" & SMALLER, PRESSURE CLASS D.I. MAINS 8" & SMALLER, OR WHEN MAIN IS PVC, HDPE, OR AC PIPE.
5. FOR MANHOLE/VALVE BOX IN GRASS AREAS, SEE SS 21.0 SHEET 1 OF 1.

TYPE "A" MANHOLE	SS 4.0	
ITEM	CROSS REF.	SPEC. REF.



ISSUE DATE	APPROVED BY
9/26/2014	J.B.F.

STANDARD DETAIL

**AUTOMATIC AIR RELEASE VALVE  
ASSEMBLY IN PAVED AREAS**

**SS  
11.0  
SHEET 2 OF 2**