	REDUCED PRESSURE ZONE ASSEMBLY (RPZA)		DOUBLE CHECK VALVE ASSEMBLY (DCVA)		DOUBLE CHECK DETECTOR ASSEMBLY (DCDA)	
MANUFACTURER	¾" – 2"	2 ½" – 10"	¾" – 2"	2 ½" – 10"	2"	2 ½" – 10"
AMES 1485 TANFORAN AVENUE WOODLAND, CA. 95695 (530)666–2493 WWW.AMESFIREWATER.COM	400B–Z*	Colt 400Z* Maxim 400Z*	2000B	Colt 200a Maxim 200a	3000B	Colt 300 Maxim 300
APOLLO / CONBRACO P.O. BOX 247 MATTEWS, NC. 281065 (704)847–9191 WWW.APOLLOVALVES.COM	4020(x)T2Z*	N/A	N/A	(X) DC 4SG–100	N/A	(X)DCDA
FEBCO P.O. BOX 8070 FRESNO, CA. 93747 (208)252–0791 WWW.FEBCOONLINE.COM	N/A	760z* 880V*	850	750 857 870V*	858	876V*
WATTS REGULATOR CO. 815 CHESTNUT STREET N. ANDOVER, MA. 01845 (978)688–1811 WWW.WATTS.COM	909QT 919QT* U009AQT*	957z*	007 QT 719 QT 775 QT	757a 767a	007–DCDA	709 DCDA
WILKINS 1747 COMMERCE WAY PASO ROBLES, CA. 93446 (800)817–8177 WWW.ZURN.COM	975XLV*	475V*	350 950XL	350 450*	950XLTDA	350DA 450DA*

NOTE: * UNIT IS APPROVED IN THE VERTICLE UP / VERTICLE UP (VUVU) "Z–PATTERN" ORIENTATION



MIAMI-DADE COUNTY
Delivering Excellence Every Day

ISSUE DATE	APPROVED BY
7/6/2012	F.A.

STANDARD DETAIL
APPROVED BACKFLOW PREVENTION ASSEMBLIES FOR VERTICAL INSTALLATION
– NOTES –

ITEM

CROSS REF.

SPEC. REF.

WS 4.18

SHEET 5 OF 5