

**MIAMI-DADE WATER AND SEWER DEPARTMENT
APPROVED BACKFLOW PREVENTION ASSEMBLIES
FOR VERTICAL INSTALLATION**

MANUFACTURER	REDUCE PRESSURE ZONE (RPZA)		DOUBLE CHECK VALVE (DCVA)		DOUBLE CHECK DETECTOR (DCDA)	
	3/4" - 2"	2 1/2" - 10"	3/4" - 2"	2 1/2" - 10"	2"	2 1/2" - 10"
AMES 1485 TANFORAN AVENUE WOODLAND, CA 95695 (530) 666-2493 www.amesfirewater.com	400B-Z*	Colt 400Z * Maxim 400Z *	2000B	Colt 200a Maxim 200a	3000B	COLT 300 MAXIM 300
APOLLO / CONBRACO P.O. BOX 247 MATTEWS, NC 281065 (704) 847-9191 www.apollovalves.com	4020(x)T2Z *	N/A	N/A	(X) DC 4SG-100	N/A	(X)DCDA
FEBCO P.O. BOX 8070 FRESNO, CA 93747 (208) 252-0791 www.febcoonline.com	N/A	760z* 880V*	850	750 857 870V*	858	876V *
WATTS REGULATOR CO. 815 CHESTNUT STREET N.ANDOVER, MA 01845 (978) 688-1811 www.watts.com	909QT 919ZQT* U009AQT*	957z *	007 QT 719QT 775 QT	757a 767a	007-DCDA	709 DCDA
WILKINS 1747 COMMERCE WAY PASO ROBLES, CA 93446 (800) 817-8177 www.zurn.com	975XLV *	475V*	350 950XL	350 450 *	950XLTDA	350 DA 450DA *

Note: * Unit is approved in the Verticle Up / Verticle Up (VUVU) "Z-pattern" orientation

