



Product Specifications

Poly Vinylchloride (PVC) Pipe- C900

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477
Email: WASD-STANDARDS@miamidade.gov

Note: PVC DR 18 (4 to 16-inches color blue) will be allowed for water mains due to current supply chain disruptions. WASD will accept water main projects with PVC DR 18 for one year to 9/30/2023. Plans approved after 9-30-2023 will require DIP to be used for potable water mains.



Minimum Standards

- AWWA C900
• ASTM D1784, D3139, F477
• MDWASD Specifications: Sections 33 31 11 (UC-250), 33 14 00 (15060), 33 05 31.16 (15067)

Other Requirements

- For C900 – DR 14, 18, 25
• For Pressure applications – DR 18
• For wellfields and gravity sewer deeper than 13 feet
• Color Green for sanitary sewer application
• Color Blue for potable water application
• Saddles are required for all corporation stops and service connections.
• All PVC installed shall have the ability to be located aboveground. Tracer Wire, Magnetic Balls and Location Safety Tape are all required per WASD Standards.
• No deflections are allowed at the joints. Longitudinal deflection along the pipe barrel shall be limited to the Table provided in Specification 33 05 31.16.
• Pipe shall have a gasket locking system at the bell end (MJ Joints).

Applications

- Sewer – For gravity and pressure applications approved by the Department.
• Potable Water – Acceptable for use 4 to 16-inches in diameter due to supply chain disruptions. The Department will return to the original standard of only for use in saltwater intrusion areas on 9-30-2023.

PRE-APPROVED MANUFACTURER

- 1) CertainTeed/North American Specialty Products
2) Diamond Plastics Corp
3) IPEX Inc.
4) JM Eagle
5) National Pipe & Plastics, Inc.
6) North American Pipe Corp
7) Sanderson Pipe Corp.

Issue Date:

4-4-2016

Revised Date:

9-22-22

APPROVED PRODUCTS / MODELS			
PIPE SIZE	MANUFACTURER	MODEL	SUBMITTED
PRESSURE PIPE			
4" - 16"	CertainTeed/North American Specialty Products	Certa-Lock C900/RJ	<input type="checkbox"/>
4" - 12"	Diamond Plastics Corp	C900 PVC Pressure Pipe	<input type="checkbox"/>
14" - 30"	Diamond Plastics Corp	Trans-21	<input type="checkbox"/>
4" - 30"	IPEX Inc.	Ipex Centurion	<input type="checkbox"/>
4" - 12"	IPEX Inc.	Blue Brute Pipe	<input type="checkbox"/>
14" - 24"	JM Eagle	C900 Big Blue	<input type="checkbox"/>
4" - 12"	JM Eagle	Blue Brute C900	<input type="checkbox"/>
4" - 12"	National Pipe & Plastics, Inc.	Dura-Blue C900	<input type="checkbox"/>
14" - 24"	National Pipe & Plastics, Inc.	Dura-Blue C900	<input type="checkbox"/>
4" - 30"	North American Pipe Corp	Gasketed Integral Bell PVC Pipe C900	<input type="checkbox"/>
4" - 12"	Sanderson Pipe Corp.	C900 (Blue)	<input type="checkbox"/>
<i>Note: Other sizes require MDWASD Approval</i>			
SIZES FURNISHED:			
<input type="checkbox"/> 4"	<input type="checkbox"/> 12"	<input type="checkbox"/> 20"	
<input type="checkbox"/> 6"	<input type="checkbox"/> 14"	<input type="checkbox"/> 24"	
<input type="checkbox"/> 8"	<input type="checkbox"/> 16"	<input type="checkbox"/> 30"	
<input type="checkbox"/> 10"	<input type="checkbox"/> 18"	<input type="checkbox"/> Other	
REMARKS - PROVIDE SDR RATING: _____			
APPLICATION _____			
PIPE COLOR			
<input type="checkbox"/> Green (Sewer) <input type="checkbox"/> Blue (Potable Water))			
COMMENTS: _____			

Approved by: MDWASD Departmental Standards, Specifications and Products Committee			
Revision History:			
9-22-2022: Removed All References to C905; Allowed the use of PVC DR 18 (4-inch to 16-inch) countywide for potable water due to supply chain disruptions until 9-30-2023.			