

QUALITY. VALUE. ECONOMIC GROWTH.

WWW.MIAMIDADE.GOV/WATER



MIAMI-DADE
COUNTY

Sheet Number: 1.2.2

Product Specifications

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477

Poly Vinylchloride (PVC) Pipe-
SDR 26



Minimum Standards

- ASTM D1784, D3034, F477
- MDWASD Specifications: Sections UC-250, 15060

Other Requirements

- SDR 26 Heavy Walled Gravity Sewer Pipe
- Color Green for Sanitary Sewer Application

Applications

- Sewer – for gravity sewer application
- Not to be used in wellfield protection areas
- Not to be used at depths greater than 13 feet
- Gravity sewer laterals

PRE-APPROVED MANUFACTURER

- 1) CertainTeed/North American Specialty Products
- 2) Diamond Plastics Corporations
- 3) JM Eagle
- 4) National Pipe & Plastics, Inc.
- 5) Next Polymers
- 6) North American Pipe, Corp
- 7) Sanderson Pipe Corp.

Issue Date:

4-4-2016

Revised Date:

9-1-2017

APPROVED PRODUCTS / MODELS

PIPE SIZE	MANUFACTURER	MODEL	SUBMITTED
GRAVITY SEWER PIPE			
4" - 12"	CertainTeed	CertaFlo Greenline	<input type="checkbox"/>
4" - 30"	Diamond Plastics Corporations	Diamond Gravity Sewer pipe	<input type="checkbox"/>
4" - 30"	JM Eagle	Gravity Sewer	<input type="checkbox"/>
4" - 18"	National Pipe & Plastics, Inc.	EVER-GREEN for sewer and storm drainage	<input type="checkbox"/>
4" - 30"	Next Polymers	Duroloc PVC Sewer Pipe	<input type="checkbox"/>
4" - 15" & 18" - 30"	North American Pipe, Corp	Gravity Sewer	<input type="checkbox"/>
4" - 15"	Sanderson Pipe Corp.	Gravity Sewer Pipe Gasket Bell	<input type="checkbox"/>
<i>Note: Other sizes require MDWASD Approval</i>			<input type="checkbox"/>

SIZES FURNISHED:

- | | | |
|------------------------------|------------------------------|--------------------------------|
| <input type="checkbox"/> 4" | <input type="checkbox"/> 12" | <input type="checkbox"/> 30" |
| <input type="checkbox"/> 6" | <input type="checkbox"/> 15" | <input type="checkbox"/> Other |
| <input type="checkbox"/> 8" | <input type="checkbox"/> 18" | |
| <input type="checkbox"/> 10" | <input type="checkbox"/> 24" | |

COMMENTS: _____

Approved by: David Vazquez, PE

Title: Manager, Specifications