QUALITY. VALUE. ECONOMIC GROWTH.
WWW.MIAMIDADE.GOV/WATER

MIAMI-DADE COUNTY

Sheet Number: 4.1

Product Specifications

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477

Butterfly Valve

Minimum Standards

- AWWA C504, C550, C111, A21.11
- ASTM B16.1, Class 125, A48 Class 40, A126 Class B, A536, A216 Grade WCB, A436 Type 1 or 2, A439 Type D2, A123, A153
- MDWASD Specifications: Sections 15100, 15110

Other Requirements

- NSF61/ANSI for potable water applications

Applications

- Water

Pre-Approved Manufacturer

1) Clow
2) DEZURIK
3) Kennedy
4) Mueller
5) PRATT

Issue Date: 4/4/2016

Revised Date: 11/4/2016

Approved Products / Models

Size	Manufacturer	Model	Submitted
30” - 54”	Clow	Style #1450, MJ and Flanged	☐
16” - 54”	DEZURIK	BAW	☐
30” - 54”	Kennedy	1450 Series	☐
3” - 24”	Kennedy	4500 Series	☐
16” - 20”	Mueller	LINSEAL III	☐
24” - 30”	Pratt	XR-70	☐
3” - 20”	Pratt	2B II	☐
16” - 30”	Pratt	Groundhog	☐

Sizes Furnished:

☐ 16”	☐ 30”	☐ 54”
☐ 18”	☐ 36”	
☐ 20”	☐ 42”	
☐ 24”	☐ 48”	

Comments: _____

_____

_____

Approved by: David Vazquez, PE

Title: Specifications Manager