



Product Specifications

Miami-Dade Water & Sewer Department  
 Address: 3071 SW 38th Ave, Miami, FL 33146  
 Phone: (305) 665-7477

Valves-Others



Bronze Globe Valve

Minimum Standards

- AWWA C800, ASTM B62, B584
- MDWASD Specifications: Section 15130, 15100

Other Requirements

- ANSI/NSF Standard 61
- Min Pressure Ratings
  - ✓ Small Pressure Reducing Valves : 250 psi
  - ✓ Globe Valves : 150 psi (working pressure)
  - ✓ Check Valves (Small) :125 psi (working pressure)
  - ✓ Gate Valves (Small) : 150 psi

Type of Valves Included as Others

- Check Valves (small)
- Gate Valves (small)
- Globe Valves
- Pressure Relief Valves

Applications

- Water

PRE-APPROVED MANUFACTURER

- |                   |                   |
|-------------------|-------------------|
| 1) Bell & Gossett | 4) Ford Meter Box |
| 2) Cash-Acme      | 5) NIBCO, Inc.    |
| 3) Crane Company  | 6) Stockham       |
|                   | 7) Matco-Norca    |

Issue Date:

4/4/2016

Revised Date:

11/29/2018

APPROVED PRODUCTS / MODELS

SIZE	MANUFACTURER	MODEL	SUBMITTED
¾" & 1"	Bell & Gossett	790 & 1170 (safety pressure relief valves)	<input type="checkbox"/>
¼" - 1¼"	Cash-Acme	Type K-10 (back pressure relief valve)	<input type="checkbox"/>
¼" - 3"	Crane Company	No. 37 (small swing check valve)	<input type="checkbox"/>
¼" - 2"	Crane Company	No. 1 (globe valve)	<input type="checkbox"/>
2"	Ford Meter Box	Blow-off Ball Valve (BLA18-777-TA-NL)	<input type="checkbox"/>
1/8" - 3"	NIBCO, Inc.	Class 150 Bronze Globe Valve	<input type="checkbox"/>
2"	Matco-Norca	240 Brass Angle Globe Valve	<input type="checkbox"/>
½" - 2"	Stockham	LBF- 103 gate valve	<input type="checkbox"/>

SIZE FURNISHED:

- |                                |                                |
|--------------------------------|--------------------------------|
| <input type="checkbox"/> 1/8 " | <input type="checkbox"/> 1½"   |
| <input type="checkbox"/> ¼"    | <input type="checkbox"/> 2"    |
| <input type="checkbox"/> ¾"    | <input type="checkbox"/> 3"    |
| <input type="checkbox"/> 1"    | <input type="checkbox"/> Other |

COMMENTS: \_\_\_\_\_

**Approved by:** MDWASD Departmental Standards, Specifications, and Product Committee

**Revision History:**

11-2018 – Angle Valves replaced by Ball Valves on Manual Air Release Valves and Flushing Valve Outlets; Added Matco-Norca;