



Sheet Number: 8.2

**Product Specifications**

Miami-Dade Water & Sewer Department  
 Address: 3071 SW 38th Ave, Miami, FL 33146  
 Phone: (786) 665-7477  
 Email: WASD-STANDARDS@miamidade.gov

**Water Services – Meter Couplings**



**Minimum Standards**

- AWWA C700, C800
- MDWASD Specifications: Section 33 05 98 (15065)

**Other Requirements**

- ANSI/NSF Standard 61
- No Lead – All brass components shall be marked “NL”

**Applications**

- Water

**PRE-APPROVED MANUFACTURER**

- 1) A.Y. McDonald
- 2) Ford
- 3) Mueller
- 4) Cambridge Brass

**Issue Date:** 4/4/2016

**Revised Date:** 3/28/2022

**APPROVED PRODUCTS / MODELS**

SIZE	MANUFACTURER	MODEL	SUBMITTED
5/8" - 1 x 2 13/16"	A.Y. McDonald	74624 meter swivel nut x MNPT	<input type="checkbox"/>
2"	A.Y. McDonald	7611-44 2 PVC Comp x MNPT	<input type="checkbox"/>
1 1/2" - 2"	A.Y. McDonald	7611-55 x IP Comp x MNPT	<input type="checkbox"/>
1"	A.Y. McDonald	74638-22 meter swivel nut x CTS	<input type="checkbox"/>
5/8" - 2"	A.Y. McDonald	74620 meter swivel nut with wire seal hole x MNPT	<input type="checkbox"/>
5/8" - 1"	Ford	C34-xx-NL style meter swivel nut x pack joint CTS	<input type="checkbox"/>
1 1/2" - 2"	Ford	CT35-xx-NL style Lok-Pak Meter Coupling	<input type="checkbox"/>
1/2" - 1"	Mueller	H10890N meter x MIP	<input type="checkbox"/>
3/4" - 2"	Mueller	H10891N meter nut x MIP	<input type="checkbox"/>
1/2" - 1"	Mueller	H10896N meter x MIP	<input type="checkbox"/>
3/4" - 1"	Mueller	H14201N meter swivel nut x CTS	<input type="checkbox"/>
5/8" - 1"	Cambridge Brass	417NL-TXBX meter swivel nut x CTS	<input type="checkbox"/>

**SIZE FURNISHED:**

Inlet Size: \_\_\_\_\_ Outlet Size: \_\_\_\_\_

**COMMENTS:** \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

**Approved by:** MDWASD Departmental Standards, Specifications & Products Committee

**Revision History:**

5-09-2018 – Added Cambridge Brass; Added Product Description to all Couplings.

3-28-2022 – Added size 1½" to A.Y. McDonald, Model 7611-55 x.