QUALITY. VALUE. ECONOMIC GROWTH.
WWW.MIAMIDADE.GOV/WATER

MIAMI-DADE COUNTY

Sheet Number: 8.3

Product Specifications

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477

Water Services – Corporation Stops

Minimum Standards

- AWWA C800
- MDWASD Specification: Section UC-075, UC-080, UC-085, 15065

Other Requirements

- ANSI/NSF Standard 61
- No Lead – All brass components shall be marked "NL"

Applications

- Water

PRE-APPROVED MANUFACTURER

1) A.Y. McDonald
2) Cambridge Brass
3) Ford
4) Mueller

Issue Date:

Revised Date:

APPROVED PRODUCTS / MODELS

SIZE	MANUFACTURER	MODEL	SUBMITTED
¾" - 2"	A.Y. McDonald	73121B	☐
½" - 2"	A.Y. McDonald	74701-22	☐
¾" - 2"	A.Y. McDonald	74704B-22	☐
¾" - 2"	A.Y. McDonald	73149B	☐
½" - 2"	A.Y. McDonald	74704-22	☐
5/8" - 2"	Cambridge Brass	301/301NL	☐
¾" - 1"	Cambridge Brass	302NL	☐
½" - 1"	Ford	F1000-x-NL style	☐
1½"	Ford	FB800-6-NL style	☐
1"	Ford	FB1000-4-NL style	☐
1"	Ford	FB1000-4-G-NL style	☐
1"	Ford	FB1100-7-G-NL style	☐
1¼" - 2"	Ford	FB1100-x-NL style	☐
¾" - 2"	Ford	FB1600-x-NL style	☐
¾" - 2"	Ford	FB1700-x-NL style	☐
¾" - 2"	Ford	FB800-x-NL style	☐
1"	Ford	F-600-x-NL	☐
1"	Mueller	H-15000N	☐
2"	Mueller	H-10003N	☐

SIZE FURNISHED:

Inlet Size: _____ Outlet Size: _____

COMMENTS: _____

_____

_____

Approved by: James B. Ferguson, PE

Title: Chief, Engineering and Design Division