



September 30, 2022

RFI NO. 3 - CLARIFICATION

Project Title: **Roadway Improvements to NE 151 Street from East of Railroad Tracks to Bay Vista Boulevard**
Project No.: **20210092 (Capital)**

Disregard in its entirety answer provided on question from RFI from Mr. Raul Cabrera, Florida Engineering; dated September 22, 2022 and replace with the following:

QUESTION: 7) There are several plug and abandons, that means that the existing drainage pipe is to be abandoned in place, correct? The question is due to sheet 5 in the Pay Item Notes saying that the pipes have to be removed.

RESPONSE: 7) The existing drainage pipe is to be plugged as shown in the plans and the remainder removed. Please refer to response no. 6, to the drainage structure sheets and to Revised Sheet for Addendum No. 5 for further clarification.

END OF CLARIFICATION FOR RFI No. 3

Sincerely,

A handwritten signature in blue ink, appearing to read "A/Muñoz".

Alfredo E. Muñoz, P.E.
Chief, Capital Improvements Division
Department of Transportation and Public Works (DTPW)

AM:kf

cc:

Katherine Fernandez, DTPW	Leandro Ona, P.E. DTPW	Jhonnatan Escalante ISD
Barbara Mesa, DTPW	Miguel Soria, P.E. DTPW	Project File
Fabiana Gonzalez, P.E	Jacqueline Fussell, ISD	Clerk of the Board