



July 5, 2023

RESPONSE LETTER NO. 1 TO REQUEST FOR INFORMATION

Project Title: **Replacement of Bridge 874420 Over C-100A Canal**
Project No.: **20230013 (MCC 7360 Plan)**

Question from Mr. Travis, Kiewit Infrastructure South Co. Request for Information from Pre-Bid Meeting dated 6/29/2023, 10:00 AM.

QUESTION: 1) Can you provide us a data base or link with a list of Miami Dade firms certify with the County?

RESPONSE: 1) As requested by a contractor at the pre-bid, please see link here to access the County's Business Management Workforce System:
<https://mdcsbd.gob2g.com/?TN=mdcsbd>

Question from Mr. El-Khamlichi, MCM. Request for Information dated 6/30/2023, 11:08 AM. Please see attachment.

QUESTION: 1) Please indicate if Inspector General fees apply to this project.

RESPONSE: 1) Yes, this Contract is subject to a ¼ of 1% deduction from payment to the Inspector General.

QUESTION: 2) Please indicate if UAP fees apply to this project.

RESPONSE: 2) Pursuant to Section 2-8.10 of the Code of Miami-Dade County, this Contract is also subject to a user access fee under the County's User Access Program (UAP) in the amount of two percent (2%). Please refer to article 1.14 Miami-Dade County's User Access Program (UAP) of the Supplementary Conditions in the Solicitation Documents.

QUESTION: 3) Is a field office required for this project?

RESPONSE: 3) Yes, Field Office is required for this project. Please refer to Section 2, General Construction on the Special Provision in the Solicitation Documents.

QUESTION: 4) Please indicate if Channel Excavation is required for this project. If yes, please provide proposed Canal cross sections and add a bid item for Channel Excavation.

RESPONSE: 4) This question to be answered under separate RFI.

QUESTION: 5) Please confirm that all testing will be provided and paid for by the County.

RESPONSE: 5) Yes, Testing will be paid by Miami-Dade County. Any failed test (retesting) will be paid by the contractor.



Question from Mr. Pappito, K. Request for Information dated 6/30/2023, 12:12 PM. Please see attachment.

QUESTION: 1) The Special Provisions Section 2.01.B.1: Field Office is requiring an office not less than 2000 square feet, given the size of this project this seems excessively large and expensive, can the requirement be revised to provide a smaller office that will hold the 2 desks and chairs that are to be supplied?

RESPONSE: 1) The field office should be no less than 360 SF, please refer to Addendum No. 1 for Field Office Space Modification.

QUESTION: 2) Does the County have land available in the vicinity of the project to locate the field office?

RESPONSE: 2) Miami Dade County is not aware of any available land on the vicinity of the project. A commercial office space will suffice. The field office shall be located within one (1) mile from the project site.

QUESTION: 3) On the Foundation Layout plan sheet (sheet 25 of 43) pile number 1 at end bent number 4 is located under the overhead electric lines, we don't see how this pile can be driven without temporarily moving those lines, please advise.

RESPONSE: 3) Overhead lines are currently being relocated to be underground, away from the proposed pile location. This effort is anticipated to be completed prior to the beginning of construction

QUESTION: 4) Please confirm that the approach slab sidewalks are paid as Approach Slab Concrete – Bid Item Number 400-2-10, they don't appear to be included in the bid quantity of 98.5 CY.

RESPONSE: 4) Answer: sidewalk concrete on the approach slabs is to be Class IV concrete, and the quantity is included in item 400-4-4 (Concrete Class IV)..

QUESTION: 5) Please confirm that the Inspector General Audit Fee of 0.25% is required in this contract

RESPONSE: 5) Yes, this Contract is subject to a ¼ of 1% deduction from payment to the Inspector General.



Department of Transportation and Public Works

111 NW 1st • Street Suite 1410

Miami, Florida 33128-1970

T 305-375-2930 F 305-375-2931

miamidade.gov

END OF REQUEST FOR INFORMATION No. 1

Sincerely,

A handwritten signature in blue ink, appearing to read "Alfredo E. Muñoz".

Alfredo E. Muñoz, P.E.

Chief, Capital Improvements Division

Department of Transportation and Public Works (DTPW)

AM:lh

c:

Laura Hernandez, DTPW
Gabriel Delgado, P.E, DTPW
Clerk of the Board

Jacqueline Fussell, ISD
Marcia Martin, ISD
Project File

Ryan Fisher, P.E. DTPW
Katherine Fernandez, DTPW

From: [Yassir El-Khamlichi](#)
To: [Hernandez, Laura \(DTPW\)](#)
Cc: [Clerk of the Board \(COC\)](#)
Subject: Replacement of Bridge 874420 Over C-100A Canal SW 136 Street - RFI's
Date: Friday, June 30, 2023 11:08:10 AM
Attachments: [image722288.png](#)
[image969510.png](#)
[image367031.png](#)
[image901511.png](#)

EMAIL RECEIVED FROM EXTERNAL SOURCE

Good Morning Laura,

We have the following RFI's for the above referenced project:

1. Please indicate if Inspector General fees apply to this project.
2. Please indicate if UAP fees apply to this project.
3. Is a field office required for this project?
4. Please indicate if Channel Excavation is required for this project. If yes, please provide proposed Canal cross sections and add a bid item for Channel Excavation.
5. Please confirm that all testing will be provided and paid for by the County.

Thank you,



YASSIR EL-KHAMLICH
PH: 305-541-3050 | M: 786-899-3560 | yassir@mcm-us.com
6201 SW 70 St., 1 Floor, Miami, FL 33143 | www.mcm-us.com



Please consider the environment before printing.
A reminder from MCM, Building Excellence.

Follow Us !



From: [Joseph.Papitto](#)
To: [Hernandez, Laura \(DTPW\)](#)
Cc: [Travis.Brilliant](#); [Clerk of the Board \(COC\)](#)
Subject: RPQ No. 20230013 - RFI Requests
Date: Friday, June 30, 2023 12:12:43 PM

EMAIL RECEIVED FROM EXTERNAL
SOURCE

Please review and respond to the following RFI requests for Project No 20230013 – SW 136 St. Bridge:

1. The Special Provisions Section 2.01.B.1: Field Office is requiring an office not less than 2000 square feet, given the size of this project this seems excessively large and expensive, can the requirement be revised to provide a smaller office that will hold the 2 desks and chairs that are to be supplied?
2. Does the County have land available in the vicinity of the project to locate the field office?
3. On the Foundation Layout plan sheet (sheet 25 of 43) pile number 1 at end bent number 4 is located under the overhead electric lines, we don't see how this pile can be driven without temporarily moving those lines, please advise.
4. Please confirm that the approach slab sidewalks are paid as Approach Slab Concrete – Bid Item Number 400-2-10, they don't appear to be included in the bid quantity of 98.5 CY.
5. Please confirm that the Inspector General Audit Fee of 0.25% is required in this contract.

Please contact me if you need any further information, thank you.

Joe Papitto

Kiewit Infrastructure South Co.

1580 Sawgrass Corporate Pkwy., Ste 300

Sunrise, FL 33323

954-835-2228, Cell: 954-205-4108