



September 6, 2024

RESPONSE LETTER NO. 1 TO REQUEST FOR INFORMATION

Project Title: **NW 22nd Avenue Movable Bridge No. 874383 Structural Repairs**
Project No.: **20240160**

Email from Mrs. Irene C. Tirikos, from Titan Civil Construction; on September 5, 2024, at 10:58 AM (Email Attached).

QUESTION No.1: We see SSPC standards referenced throughout the bid documents, will SSPC QP1-QP2 certification be required since this is a lead remediation project?

ANSWER No.1: The Key Sheet references FDOT Standard Specification for Road and Bridge Construction

Section 561-4 includes the requirement for SSPC QP1 and QP2. QP2 is required for removal of hazardous coatings.

General Note E.6.A states that the existing coatings may have heavy metals.

Therefore, the Contractor must submit a current SSPC QP2 certification with the Corporate QC Plan to meet the Contract Requirements.

END OF REQUEST FOR INFORMATION No. 1

Sincerely,

A blue ink handwritten signature, appearing to read "Alex Barrios", with a long horizontal line extending to the right.

Alex Barrios
Assistant Director, Construction & Maintenance.
Department of Transportation and Public Works (DTPW)

AM: mm

cc:

Marco Movilla, DTPW	Katherine Fernandez, DTPW
Laurie Johnson, SBD	Gabriel Delgado, DTPW
Caesar Suarez, SBD	Eric Perez, SBD
Ryan Fisher, DTPW	Clerk of the Board
Project File	

DEPARTMENT OF TRANSPORTATION AND PUBLIC WORKS

Project Name:

NW 22nd Avenue Movable Bridge No. 874383 Structural Repairs

RPQ NO. 20240160

REQUEST FOR INFORMATION NO.1
(RFI)

E-MAILS ATTACHED

From: [Irene Tirikos](#)
To: [Movilla, Marco \(DTPW\)](#)
Cc: [Clerk of the Board \(COC\)](#); [Chris Stamas](#)
Subject: RFI Contract No: MCC 7360 Plan-NW 22nd Avenue Movable Bridge No. 874383 Structural Repairs
Date: Thursday, September 5, 2024 11:00:57 AM
Attachments: [RFI.docx](#)

EMAIL RECEIVED FROM EXTERNAL
SOURCE

Good morning,

Please see the attached RFI for this project.

Thank you,

Irene C. Tirikos

Office Manager

Titan Civil Construction

1787 S. Pinellas Ave., Suite 600

Tarpon Springs, FL 34689

Phone: (727)330-2729 Direct: (727)493-5046

Email: itirikos@titancivilconstruction.com

Web: www.titancivilconstruction.com



Titan Construction Management LLC

1787 S. Pinellas Ave., Suite 600, Tarpon Springs, FL 34689 (727) 330-2729 itirikos@titancivilconstruction.com

September 5, 2024

RFI

CONTRACT NO.: MCC 7360 PLAN

NW 22nd Avenue Movable Bridge No. 874383 Structural Repairs

REQUEST FOR INFORMATION

We see SSPC standards referenced throughout the bid documents, will SSPC QP1-QP2 certification be required since this is a lead remediation project?
