

February 20, 2025

## RESPONSE LETTER NO. 2 TO REQUEST FOR INFORMATION


**Project Title:** Snowden Pedestrian Bridge No. 879043

**Project No.:** 20240235

**A. Email from Mr. Jay Yi, from Interstate Construction, LLC; on February 14, 2025, at 09:17 AM (Email Attached).**

**Question No. 1:** The plans are requesting to install pipe rail on the guardrail, however from what it shows the sidewalk/shared use path is going in front of the guardrail. This would remove the requirement of the pipe rail as there is no intention of having pedestrians passing behind the guardrail.

Picture:



**Answer No.1:** The new shared use path will be located behind the new guardrail, which will require pipe rail to be installed.

**Question No. 2:** On the right-hand side of the guardrail line it states to end guardrail with an approach transition. Could you clarify if a new wall will be constructed or will we be connecting to the existing wall (shown below).

Picture:




**Answer No. 2:** The new guardrail will need to be connected to the existing rigid barrier.

**Question No. 3:** Are we expected to remove the existing Pipe rail & sidewalk w/ curb? (pictured above, East side south end) if so, which pay item does it go under?

**Answer No. 3:** The existing sidewalk and pedestrian railing (outside of the bridge) should be removed to the nearest sidewalk flag joint as depicted in the limits of the plan sod pattern. Provide a 3-foot curb transition at curb ends. The final condition should match the existing sidewalk and railing on the other side of the bridge (Southbound), see picture below. This is to be paid under Pay item 110 1 1B CLEARING & GRUBBING.

Picture:





**D. Email from Mr. Jordan M. Zahlene, from Zahlene Enterprises, Inc; on February 18, 2025, at 11:40 AM (Email Attached).**

**Question No.1:** I see that the bidders list on the solicitation page is empty.  
Where can we view the current bidders list?

**Answer No. 1:** See attached file below – demonstrating the latest bidder's list.

**Question No. 2:** How do we get on the bidders list?

**Answer No. 2:** See attached page below providing instructions on how to register as vendor to Miami-Dade County.

**Question No. 3:** Do you need to be on the bidders list to submit a bid?

**Answer No. 3:** No. The Bidder's List solely demonstrates the list of vendors who have shown interest through the MDC's Procurement Site.

**END OF REQUEST FOR INFORMATION No. 2**

Sincerely,



Tiondra Wright  
Chief, Capital Improvement Division.  
Department of Transportation and Public Works (DTPW)

TW: tw

cc:

Marco Movilla, DTPW  
Gabriel Delgado, P.E., DTPW  
Laurie Johnson, SBD  
Caesar Suarez, SBD  
Project File

Katherine Fernandez, DTPW  
Ryan Fisher, P.E., DTPW  
Maylin Torres, SBD  
Eric Perez, SBD  
Clerk of the Board



**Snowden Pedestrian Bridge No. 879043**

**RPQ No. 20240235**

**Request for Information No.2  
(RFI)**

**Bidder's List  
(Latest)**

# Bidder List for RPQ DTPW 7360 20240235

<b>Email</b>	<b>Category</b>	<b>Company</b>
andresfonte@aafonte.com	General Engineering	A & A FONTE INC
service74@outlook.com	General Engineering	AA EQUIPMENT & SERVICES, INC.
joseangelbustos@acreconstruction.com	General Engineering	Acre Engineering and Construction, Inc.
dgolding@act-services.com	General Engineering	ACT SERVICES INC
steve@anzacontractors.com	General Engineering	Anzac Contractors, Inc.
javier.bustos@cebengineering.com	General Engineering	C E B Construction, Inc.
kbaer@centralcivil.com	General Engineering	Central Civil Construction Co.
jsierra@comtecheng.com	General Engineering	Comtech Engineering, Inc.
Jfkenn2002@aol.com	Structural	Construction Affairs Inc.
scott@ebsaryfoundationco.com	Structural	EBSARY FOUNDATION COMPANY
jose@floridaengineering.net	General Engineering	Florida Engineering and Development Corp.
curtis@generalasphalt.com	General Engineering	General Asphalt Co., LLC
bids@homesteadconcrete.com	General Engineering	Homestead Concrete & Drainage, Inc.
jmsanchez@hcimail.net	General Engineering	HORIZON CONTRACTORS INC
gusgraupera@interstate13.com	Structural	INTERSTATE CONSTRUCTION, LLC
gl@lambertbros.net	Structural	Lambert Bros., Inc.
cvarela.meca@gmail.com	General Engineering	MAC195 ENGINEERING CORPORATION
mariohipo@yahoo.com	General Engineering	MAGGOLC, INC.
oclaro@masterroadfinishers.com	General Engineering	MASTER ROAD FINISHERS CORP
Rmaytin@maytin.com	General Engineering	Maytin Engineering Corp.
delio@metroexpresscorp.com	General Engineering	Metro Express Inc.
morlicc@aol.com	Structural	Morlic Engineering Corp.
sgil202433@aol.com	General Engineering	OVERNIGHT SUCCESS INC
Persant@att.net	General Engineering	PERSANT CONSTRUCTION CO INC
julio.amoedo@proservicegroupgc.com	General Engineering	Pro Service Group General Construction Inc
gbustos@qcpdirect.com	General Engineering	QUALITY CONSTRUCTION PERFORMANCE INC

reporbros@gmail.com	General Engineering	REPOR BROTHERS INC.
info@rjrconstruction.com	General Engineering	RJR CONSTRUCTION INC
silvio@roadway-construction.com	General Engineering	ROADWAY CONSTRUCTION LLC
Tony@shorelinefoundation.com	Structural	Shoreline Foundation Inc.
aduart@SHC-US.COM	Structural	STONEHENGE CONSTRUCTION LLC
david.maring@redlandcompany.com	General Engineering	The Redland Company, Inc.
jsanchez@thestoutgroup.com	Structural	THE STOUT GROUP LLC
jmelo@transflorida.net	General Engineering	TRANS FLORIDA DEVELOPMENT CORP
urvejj@yahoo.com	General Engineering	URVE ENGINEERING COMPANY
Felix@veccorp.net	General Engineering	V ENGINEERING CORP
gv@vgconsolutions.com	General Engineering	V&G Construction Solutions, Corp
rafa@wrangler-construction.com	General Engineering	Wrangler Construction Inc.

**Snowden Pedestrian Bridge No. 879043**

**RPQ No. 20240235**

**Request for Information No.2  
(RFI)**

**New Vendor Registration Instructions  
& Information  
*(Informative Information only)***





# New Vendor Registration and Bid/Proposal Contract Language

## 1.1. DEFINITIONS FOR VENDOR REGISTRATION

**Bid** – shall refer to any offer(s) submitted in response to this solicitation.

**Bidder** – shall refer to anyone submitting a Bid in response to this solicitation.

**Bid Solicitation** – shall mean this solicitation documentation, including any and all addenda.

**Bid Submittal Form** – defines the requirement of items to be purchased, and must be completed and submitted with Bid. The Bidder should indicate its name in the appropriate space on each page.

**County** – shall refer to Miami-Dade County, Florida

**DPM** – shall refer to Miami-Dade County's Department of Procurement Management.

**Enrolled Vendor** – shall refer to a firm that has completed the necessary documentation in order to receive Bid notifications from the County.

**Registered Vendor** – shall refer to a firm that has completed the Miami-Dade County Business Entity Registration Application and has satisfied all requirements to enter into business agreements with the County.

**The Vendor Registration Package** – shall refer to the Business Entity Registration Application.

For additional information about on-line vendor enrollment or vendor registration contact the Vendor Assistance Unit at 111 N.W. 1<sup>st</sup> Street, 13<sup>th</sup> Floor, Miami, FL 33128, Phone 305-375-5773. Vendors can enroll online and obtain forms to register by visiting our web site at [www.miamidade.gov/dpm](http://www.miamidade.gov/dpm)

## 1.2. INSTRUCTIONS TO BIDDERS

### A. Bidder Qualification

It is the policy of the County to encourage full and open competition among all available qualified vendors. All vendors regularly engaged in the type of work specified in the Bid Solicitation are encouraged to submit Bids. Vendors may enroll with the County to be included on a notification list for selected categories of goods and services. To be eligible for award of a contract (including small purchase orders), Bidders must become a Registered Vendor. Only Registered Vendors can be awarded County contracts. Vendors are required to register with the County by contacting the Vendor Assistance Unit. The County endeavors to obtain the participation of all qualified small business enterprises. For information and to apply for certification, contact the Department of Small Business Development at 111 N.W. 1<sup>st</sup> Street, 19<sup>th</sup> Floor, Miami, FL 33128-1900, or telephone at 305-375-3111. County employees and board members wishing to do business with the County are referred to Section 2-11.1 of the Miami-Dade County Code relating to Conflict of Interest and Code of Ethics.

### B. Vendor Registration

To be recommended for award the County requires that vendors complete a Miami-Dade County Vendor Registration Package. Effective June 1, 2008, a new Vendor Registration Package, including a Uniform Affidavit Packet (Affidavit form), must be completed by vendors and returned to the Department of Procurement Management (DPM), Vendor Assistance Unit, within fourteen (14) days of notification of the intent to recommend for award. In the event the Vendor Registration Package is not properly completed and returned within the specified time, the County may in its sole discretion, award to the next lowest responsive, responsible Bidder. The Bidder is responsible for obtaining the Vendor Registration Package, including all affidavits by downloading from the DPM website at [www.miamidade.gov](http://www.miamidade.gov) or from the Vendor Assistance Unit at 111 N.W. 1<sup>st</sup> Street, 13<sup>th</sup> Floor, Miami, FL 33128.

Bidders are required to affirm that all information submitted with the Vendor Registration Package is current, complete and accurate, at the time they submit a response to a Bid Solicitation, by completing the provided Affirmation of Vendor Affidavit form.

In becoming a Registered Vendor with Miami-Dade County, the vendor confirms its knowledge of and commitment to comply with the following:

1. **Miami-Dade County Ownership Disclosure Affidavit**  
(Sec. 2-8.1 of the County Code)
2. **Miami-Dade County Employment Disclosure Affidavit**  
(County Ordinance No. 90-133, amending Section 2-8.1(d)(2) of the County Code)
3. **Miami-Dade County Employment Drug-free Workplace Certification**  
(Section 2-8.1.2(b) of the County Code)
4. **Miami-Dade Disability and Nondiscrimination Affidavit**  
(Article 1, Section 2-8.1.5 Resolution R182-00 Amending R-385-95)
5. **Miami-Dade County Debarment Disclosure Affidavit**  
(Section 10.38 of the County Code)
6. **Miami-Dade County Vendor Obligation to County Affidavit**  
(Section 2-8.1 of the County Code)
7. **Miami-Dade County Code of Business Ethics Affidavit**  
(Article 1, Section 2-8.1(i) and 2-11(b)(1) of the County Code through (6) and (9) of the County Code and County Ordinance No 00-1 amending Section 2-11.1(c) of the County Code)
8. **Miami-Dade County Family Leave Affidavit**  
(Article V of Chapter 11 of the County Code)

9. **Miami-Dade County Living Wage Affidavit**  
(Section 2-8.9 of the County Code)

10. **Miami-Dade County Domestic Leave and Reporting Affidavit**  
(Article 8, Section 11A-60 11A-67 of the County Code)

11. **Subcontracting Practices**  
(Ordinance 97-35)

12. **Subcontractor /Supplier Listing**  
(Ordinance 97-104)

13. **Environmentally Acceptable Packaging**  
Resolution (R-738-92)

14. **W-9 and 8109 Forms**  
The vendor must furnish these forms as required by the Internal Revenue Service.

15. **Social Security Number**  
In order to establish a file for your firm, you must provide your firm's Federal Employer Identification Number (FEIN). If no FEIN exists, the Social Security Number of the owner or individual must be provided. This number becomes your "County Vendor Number". To comply with Section 119.071(5) of the Florida Statutes relating to the collection of an individual's Social Security Number, be aware that DPM requests the Social Security Number for the following purposes:

- Identification of individual account records
- To make payments to individual/vendor for goods and services provided to Miami-Dade County
- Tax reporting purposes
- To provide a unique identifier in the vendor database that may be used for searching and sorting departmental records

16. **Office of the Inspector General**  
Pursuant to Section 2-1076 of the County Code.

17. **Small Business Enterprises**  
The County endeavors to obtain the participation of all small business enterprises pursuant to Sections 2-8.2, 2-8.2.3 and 2-8.2.4 of the County Code and Title 49 of the Code of Federal Regulations.

18. **Antitrust Laws**  
By acceptance of any contract, the vendor agrees to comply with all antitrust laws of the United States and the State of Florida.

### C. PUBLIC ENTITY CRIMES

To be eligible for award of a contract, firms wishing to do business with the County must comply with the following:

Pursuant to Section 287.133(2)(a) of the Florida Statutes, a person or affiliate who has been placed on the convicted vendor list following a conviction for a public entity crime may not submit a Bid on a contract to provide any goods or services to a public entity, may not submit a Bid on a contract with a public entity for the construction or repair of a public building or public work, may not submit Bids on leases of real property to a public entity, may not be awarded or perform work as a contractor, supplier, subcontractor, or consultant under a contract with any public entity, and may not transact business with any public entity in excess of the threshold amount provided in Section 287.017 of the Florida Statutes, for CATEGORY TWO for a period of 36 months from the date of being placed on the convicted vendor list.

**Snowden Pedestrian Bridge No. 879043**

**RPQ No. 20240235**

**Request for Information No.2  
(RFI)**


**E-mails Attached**

EMAIL RECEIVED FROM EXTERNAL SOURCE

Marco,

There are few questions that we are seeking answers to;

1. The plans are requesting to install pipe rail on the guardrail, however from what it shows the sidewalk/shared use path is going in front of the guardrail. This would remove the requirement of the pipe rail as there is no intention of having pedestrians passing behind the guardrail.



2. On the right hand side of the guardrail line it states to end guardrail with an approach transition. Could you clarify if a new wall will be constructed or will we be connecting to the existing wall (shown below).



3. Are we expected to remove the existing Pipe rail & sidewalk w/ curb? (pictured above, East side south end) if so, which pay item does it go under?

Thank you.

**Jay Yi**

Senior Estimator



**INTERSTATE CONSTRUCTION, LLC**

2501 SW 160<sup>th</sup> Ave - Suite 400

Miramar, FL 33027

Tel.: 754-208-2525

Fax: 754-200-2925



**From:** [Steve McNamara](#)  
**To:** [Movilla, Marco \(DTPW\)](#)  
**Cc:** [Clerk of the Board \(COC\)](#)  
**Subject:** RE: SNOWDEN PEDESTRIAN BRIDGE - PREBID RFI  
**Date:** Friday, February 14, 2025 11:28:01 AM  
**Attachments:** [image001.png](#)  
[image003.png](#)

---

EMAIL RECEIVED FROM EXTERNAL  
SOURCE

Hi Marco,

Is there a Bid Item for Channel Excavation to cover the required canal dredging?

Thanks,

***Steven R. McNamara***  
*President*

**ANZAC CONTRACTORS, INC.**

7475 SW 50<sup>th</sup> Terrace  
Miami, FL 33155

305.669.1986 Office

305.986.0480 Cell

[Steve@AnzacContractors.com](mailto:Steve@AnzacContractors.com)

[www.AnzacContractors.com](http://www.AnzacContractors.com)



---

**From:** Movilla, Marco (DTPW) <marco.movilla@miamidade.gov>  
**Sent:** Tuesday, February 4, 2025 11:31 AM  
**To:** Steve McNamara <Steve@anzaccontractors.com>  
**Cc:** Clerk of the Board (COC) <Clerk.Board@miamidadeclerk.gov>  
**Subject:** RE: SNOWDEN PEDESTRIAN BRIDGE - PREBID RFI

Good morning, Mr. McNamara.

Received – Please, next time your Company would like to submit a RFI to our offices, make sure to Cc Miami-Dade County, Clerk of the Board (COC) since this particular project still is under the Cone of Silence.

**From:** [Jordan Zahlene](#)  
**To:** [Movilla, Marco \(DTPW\)](#)  
**Cc:** [Clerk of the Board \(COC\)](#); [Jawaid Karamat](#)  
**Subject:** RPQ No. 20240235 - RFI  
**Date:** Saturday, February 15, 2025 8:37:40 AM

---

EMAIL RECEIVED FROM EXTERNAL  
SOURCE

Good Morning,

The Roadway plans show the limits of the Dredging "Bottom of Design Canal Section Prop. Dredging to Design Cross Section See Roadway Profile". This section runs through the bottom of the existing bridge. On the sam page there is another note that says, "Canal Dredging 50' Each Way from the Bridge". Please clarify if the dredging is to be performed 50' each way from the bridge or the new pedestrian bridge only, or must the contractor also dredge underneath the existing bridge as well as the new proposed pedestrian bridge.

Thank you,

JORDAN M. ZAHLENE  
VICE PRESIDENT  
ZAHLENE ENTERPRISES INC.  
11300 NW 97th Ave  
Medley, FL 33178  
O:305-805-6858  
F:305-805-6857  
C:305-772-5739  
[www.zahlene.com](http://www.zahlene.com)

**From:** [Jordan Zahlene](#)  
**To:** [Movilla, Marco \(DTPW\)](#)  
**Cc:** [Clerk of the Board \(COC\)](#); [Jawaid Karamat](#)  
**Subject:** Re: RPQ No. 20240235 - RFI  
**Date:** Tuesday, February 18, 2025 11:40:31 AM  
**Attachments:** [image002.png](#)

---

EMAIL RECEIVED FROM EXTERNAL  
SOURCE

Good Morning Marco,

I see that the bidders list on the solicitation page is empty.

1. Where can we view the current bidders list?
2. How do we get on the bidders list?
3. Do you need to be on the bidders list to submit a bid?

Thank you,

JORDAN M. ZAHLENE  
VICE PRESIDENT  
ZAHLENE ENTERPRISES INC.  
11300 NW 97th Ave  
Medley, FL 33178  
O:305-805-6858  
F:305-805-6857  
C:305-772-5739  
[www.zahlene.com](http://www.zahlene.com)

---

**From:** Movilla, Marco (DTPW) <Marco.Movilla@miamidade.gov>  
**Sent:** Monday, February 17, 2025 2:57 PM  
**To:** Jordan Zahlene <jordan@zahlene.com>  
**Cc:** Clerk of the Board (COC) <Clerk.Board@miamidadeclerk.gov>; Jawaid Karamat <jkaramat@zahlene.com>  
**Subject:** RE: RPQ No. 20240235 - RFI

Good afternoon, Mr. Zahlene.

Received.

Best regards,

**Marco Movilla, Engineer II**  
Capital Improvements Division, Procurement.